

FDID	State	Date	Station	Incident No	Exposure
14555	California	02-06-2015	BDU	000 1662	38

Basic

Incident Type

Building fire

Incident Aid

Aid Given or Received: None

Incident Dates

Alarm: 02-06-2015 14:07:00

Arrival: 02-06-2015 14:16:00

CAD Reported Contained

Time:

Actual Contained Time:

Controlled:

Last Unit Cleared: 02-15-2015 15:00:00

Shifts & Alarms

Shift or Platoon:

Alarms:

District:

Actions Taken

1 : Action taken, other

Resources

	Apparatus	Personnel
Suppression:	0	0
EMS:		0
Other:	0	0

Resource counts do not include aid received in resources.

Losses

	Losses	Prefire Value
Property:	206872	206872
Content:	80000	80000

Casualties

	Deaths	Injuries
Fire Service:	0	0
Civilian/Other Service:	0	0

Other Information

Detector Alerted Occupants:

Hazardous Materials

Released:

Mixed Use Property:

Property Use: 1 or 2 family dwelling

Location

Location Type: **Street address**
 Lat/Long: **37.511833 / -118.645883**
 Street Address: **1450 Swall Meadows Road**
 Apt./Suite/Room:
 City: **Bishop**
 State: **California**
 ZipCode: **93514**

Officer in Charge

ID: **1003454**
 Name: **Matthew J Franklin**
 Position or rank: **FC**
 Assignment: **Bishop FFS**
 Date Signed Off: **02-06-2015**

Reporter

ID: **1003454**
 Name: **Matthew J Franklin**
 Position or rank: **FC**
 Assignment: **Bishop FFS**
 Date Signed Off: **02-06-2015**

Remarks

House and 2 vehicles burned due to exposure to the Round vegetation fire.

Fire

Property Details

Number of Living Units in
 Bldg of Origin: **1**
 Number of buildings
 involved:
 Acres burned (outside fires):

On-Site Materials or Products

On-Site Material	Material Storage Use
1: None	None
2:	
3:	

Ignition

Area of fire Origin: **Undetermined**
 Heat Source: **Undetermined**
 Confined to Object of Origin: **No**
 Item First Ignited: **Undetermined**
 Type of Material First
 Ignited: **Undetermined**
 Cause of Ignition: **Other**

Factors Contributing To Ignition

1 : **Exposure fire**

Human Factors Contributing To Ignition

Estimated Age of Person

Involved:

Sex of Person Involved:

Equipment Involved In Ignition

Equipment Involved: **None**

Fire Suppression Factors

1 : **Urban-Wildland Interface Area**

Mobile Property Involved:

Mobile Property: **None**

Local Use (Reports):

Prefire Plan Available: **No**

Reports Attached **None Specified**

Structure

Structure Type: **Enclosed building**

Building Status: **In normal use**

Building Height

stories at or above grade: **1**

stories below grade: **0**

Main Floor Size

Total square feet: **1500**

OR

Length in feet:

WIDTH in feet:

Fire Origin

Story of fire origin: **1**

Fire Spread: **Beyond building of origin**

Number of Stories Damaged By Flame

Minor damage (<25%): **0**

Significant damage (25-49%): **0**

Heavy damage (50-85%): **0**

Extreme damage (75-100%): **1**

Material Contributing Most To Flame Spread

No flame spread OR Same as material first ignited OR unable to determine

Detectors

Undetermined

Automatic Extinguishment System(AES)

Type of AES:

AES Operation:

Number of Sprinkler Heads:

AES Failure Reason:

FDID	State	Date	Station	Incident No	Exposure
14555	California	02-06-2015	BDU	000 1662	39

Basic

Incident Type

Building fire

Incident Aid

Aid Given or Received: None

Incident Dates

Alarm: 02-06-2015 14:07:00

Arrival: 02-06-2015 14:16:00

CAD Reported Contained

Time:

Actual Contained Time:

Controlled:

Last Unit Cleared: 02-15-2015 15:00:00

Shifts & Alarms

Shift or Platoon:

Alarms:

District:

Actions Taken

1 : Action taken, other

Resources

	Apparatus	Personnel
Suppression:	0	0
EMS:		0
Other:	0	0

Resource counts do not include aid received in resources.

Losses

	Losses	Prefire Value
Property:	2000	2000
Content:	1000	1000

Casualties

	Deaths	Injuries
Fire Service:	0	0
Civilian/Other Service:	0	0

Other Information

Detector Alerted Occupants:

Hazardous Materials

Released:

Mixed Use Property:

Property Use: Open land or field

Location

Location Type: **Street address**
 Lat/Long: **37.454017 / -118.583667**
 Street Address: **2164 Old Sherwin Grade**
 Apt./Suite/Room:
 City: **Bishop**
 State: **California**
 ZipCode: **93514**

Officer in Charge

ID: **1003454**
 Name: **Matthew J Franklin**
 Position or rank: **FC**
 Assignment: **Bishop FFS**
 Date Signed Off: **02-06-2015**

Reporter

ID: **1003454**
 Name: **Matthew J Franklin**
 Position or rank: **FC**
 Assignment: **Bishop FFS**
 Date Signed Off: **02-06-2015**

Remarks

Outbuilding burned due to exposure to the Round vegetation fire.

Fire

Property Details

Number of Living Units in Bldg of Origin: **0**
 Number of buildings involved: **0**
 Acres burned (outside fires): **0**

On-Site Materials or Products

On-Site Material	Material Storage Use
1: None	None
2:	
3:	

Ignition

Area of fire Origin: **Undetermined**
 Heat Source: **Undetermined**
 Confined to Object of Origin: **No**
 Item First Ignited: **Undetermined**
 Type of Material First Ignited: **Undetermined**

Cause of Ignition: **Other**

Factors Contributing To Ignition1 : **Exposure fire**

Human Factors Contributing To IgnitionEstimated Age of Person
Involved:Sex of Person Involved:

**Equipment Involved In
Ignition**Equipment Involved: **None**

Fire Suppression Factors1 : **Urban-Wildland Interface Area**

Mobile Property Involved:Mobile Property: **None**

Local Use (Reports):Prefire Plan Available: **No**Reports Attached **None Specified**

Structure

Structure Type: **Enclosed building**Building Status: **In normal use**

Building Height# stories at or above grade: **1**# stories below grade: **0**

Main Floor SizeTotal square feet: **200**

OR

Length in feet:

WIDTH in feet:

Fire OriginStory of fire origin: **1**Fire Spread: **Beyond building of origin**

Number of Stories Damaged By FlameMinor damage (<25%): **0**Significant damage (25-
49%): **0**Heavy damage (50-85%): **0**Extreme damage (75-100%): **1**

Material Contributing Most To Flame Spread**No flame spread OR Same as material first ignited OR unable to determine**

Detectors**Undetermined**

Automatic Extinguishment System(AES)

Type of AES:

AES Operation:

Number of Sprinkler Heads:

AES Failure Reason:

FDID	State	Date	Station	Incident No	Exposure
14555	California	02-06-2015	BDU	000 1662	40

Basic

Incident Type

Building fire

Incident Aid

Aid Given or Received: None

Incident Dates

Alarm: 02-06-2015 14:07:00

Arrival: 02-06-2015 14:16:00

CAD Reported Contained

Time:

Actual Contained Time:

Controlled:

Last Unit Cleared: 02-15-2015 15:00:00

Shifts & Alarms

Shift or Platoon:

Alarms:

District:

Actions Taken

1 : Action taken, other

Resources

	Apparatus	Personnel
Suppression:	0	0
EMS:		0
Other:	0	0

Resource counts do not include aid received in resources.

Losses

	Losses	Prefire Value
Property:	1476466	1476466
Content:	50000	50000

Casualties

	Deaths	Injuries
Fire Service:	0	0
Civilian/Other Service:	0	0

Other Information

Detector Alerted Occupants:

Hazardous Materials Released:

Mixed Use Property:

Property Use: Open land or field

Location

Location Type: **Street address**
 Lat/Long: **37.460217 / -118.593467**
 Street Address: **2180 Old Sherwin Grade**
 Apt./Suite/Room:
 City: **Bishop**
 State: **California**
 ZipCode: **93514**

Officer in Charge

ID: **1003454**
 Name: **Matthew J Franklin**
 Position or rank: **FC**
 Assignment: **Bishop FFS**
 Date Signed Off: **02-06-2015**

Reporter

ID: **1003454**
 Name: **Matthew J Franklin**
 Position or rank: **FC**
 Assignment: **Bishop FFS**
 Date Signed Off: **02-06-2015**

Remarks

Shop building burned due to exposure to the Round vegetation fire.

Fire

Property Details

Number of Living Units in Bldg of Origin: **0**
 Number of buildings involved: **0**
 Acres burned (outside fires): **0**

On-Site Materials or Products

On-Site Material	Material Storage Use
1: None	None
2:	
3:	

Ignition

Area of fire Origin: **Undetermined**
 Heat Source: **Undetermined**
 Confined to Object of Origin: **No**
 Item First Ignited: **Undetermined**
 Type of Material First Ignited: **Undetermined**
 Cause of Ignition: **Other**

Factors Contributing To Ignition

1 : Exposure fire

Human Factors Contributing To Ignition

Estimated Age of Person
Involved:
Sex of Person Involved:

Equipment Involved In Ignition

Equipment Involved: None

Fire Suppression Factors

1 : Urban-Wildland Interface Area

Mobile Property Involved:

Mobile Property: None

Local Use (Reports):

Prefire Plan Available: No
Reports Attached None Specified

Structure

Structure Type: Enclosed building
Building Status: In normal use

Building Height

stories at or above grade: 1
stories below grade: 0

Main Floor Size

Total square feet: 1000
OR
Length in feet:
WIDTH in feet:

Fire Origin

Story of fire origin: 1
Fire Spread: Beyond building of origin

Number of Stories Damaged By Flame

Minor damage (<25%): 0
Significant damage (25-49%): 0
Heavy damage (50-85%): 0
Extreme damage (75-100%): 1

Material Contributing Most To Flame Spread

No flame spread OR Same as material first ignited OR unable to determine

Detectors

Undetermined

Automatic Extinguishment System(AES)

Type of AES:
AES Operation:
Number of Sprinkler Heads:
AES Failure Reason:

FDID	State	Date	Station	Incident No	Exposure
14555	California	02-06-2015	BDU	000 1662	41

Basic

Incident Type

Building fire

Incident Aid

Aid Given or Received: None

Incident Dates

Alarm: 02-06-2015 14:07:00

Arrival: 02-06-2015 14:16:00

CAD Reported Contained

Time:

Actual Contained Time:

Controlled:

Last Unit Cleared: 02-15-2015 15:00:00

Shifts & Alarms

Shift or Platoon:

Alarms:

District:

Actions Taken

1 : Action taken, other

Resources

	Apparatus	Personnel
Suppression:	0	0
EMS:		0
Other:	0	0

Resource counts do not include aid received in resources.

Losses

	Losses	Prefire Value
Property:	244665	244665
Content:	50000	50000

Casualties

	Deaths	Injuries
Fire Service:	0	0
Civilian/Other Service:	0	0

Other Information

Detector Alerted Occupants:

Hazardous Materials

Released:

Mixed Use Property:

Property Use: 1 or 2 family dwelling

Location

Location Type: **Street address**
 Lat/Long: **37.477817 / -118.608267**
 Street Address: **4866 Deer Peak Trail**
 Apt./Suite/Room:
 City: **Bishop**
 State: **California**
 ZipCode: **93514**

Officer in Charge

ID: **1003454**
 Name: **Matthew J Franklin**
 Position or rank: **FC**
 Assignment: **Bishop FFS**
 Date Signed Off: **02-06-2015**

Reporter

ID: **1003454**
 Name: **Matthew J Franklin**
 Position or rank: **FC**
 Assignment: **Bishop FFS**
 Date Signed Off: **02-06-2015**

Remarks

House burned due to exposure to the Round vegetation fire.

Fire

Property Details

Number of Living Units in Bldg of Origin: **1**
 Number of buildings involved:
 Acres burned (outside fires):

On-Site Materials or Products

On-Site Material	Material Storage Use
1: None	None
2:	
3:	

Ignition

Area of fire Origin: **Undetermined**
 Heat Source: **Undetermined**
 Confined to Object of Origin: **No**
 Item First Ignited: **Undetermined**
 Type of Material First Ignited: **Undetermined**
 Cause of Ignition: **Other**

Factors Contributing To Ignition1 : Exposure fire

Human Factors Contributing To IgnitionEstimated Age of Person
Involved:Sex of Person Involved:

**Equipment Involved In
Ignition**Equipment Involved: None

Fire Suppression Factors1 : Urban-Wildland Interface Area

Mobile Property Involved:Mobile Property: None

Local Use (Reports):

Prefire Plan Available: No

Reports Attached None Specified

Structure

Structure Type: Enclosed building

Building Status: In normal use

Building Height

stories at or above grade: 2

stories below grade: 0

Main Floor Size

Total square feet: 1500

OR

Length in feet:

WIDTH in feet:

Fire Origin

Story of fire origin: 1

Fire Spread: Beyond building of origin

Number of Stories Damaged By Flame

Minor damage (<25%): 0

Significant damage (25-
49%): 0

Heavy damage (50-85%): 0

Extreme damage (75-100%): 2

Material Contributing Most To Flame SpreadNo flame spread OR Same as material first ignited OR unable to determine

DetectorsUndetermined

Automatic Extinguishment System(AES)

Type of AES:

AES Operation:

Number of Sprinkler Heads:

AES Failure Reason:

10.8 - CALFIRE LE-66 Preliminary Fire Investigation

State of California CAL FIRE LE-66a (REV.10-2013)	Wildland Fire Investigation	Incident Number	15CABDU001662
		Incident Date	Feb 06, 2015

Location

Fire Name	Region	Unit	Batt	County	City/Area	Fire Cause Class
ROUND	CSR	BDU	04	Inyo	Bishop	
Origin Location				Latitude	Longitude	
Lower Rock Creek RD Bishop CA 93514 Approximately 1 mile North of				37 27.1960	-118 34.9060	
Property Burned				Authority	Time Reported	
wildland vegetation, numerous houses, outbuildings and vehicles.				SRA	02:07 PM	Friday, Feb 06, 2015
				Response Area	Est. Time Ign	Date of Ignition
				P1	02:05 PM	Friday, Feb 06, 2015

Conditions

Red Flag	Weather Observer	Device	Weather Observation	Date	Time	Temp °F	RH %	Wind Dir.	MPH
N	Owens Valley RAWS	Digital	Clear, less than 1/10	Feb 06, 2015	04:00 AM	74	5	Shifting	14
Elevation	Slope %	Aspect	Material First Ignited	Arrival Fire Size ac.	Control Fire Size ac.	Suppression Actions Prior to FD			
4500	0	None	Undetermined	7000.00	7000.00	No			

Cause Class

ARSON	CAMPFIRE	DEBRIS BURNING	ELECTRICAL POWER	EQUIPMENT	LIGHTNING
Included	Excluded	Excluded	Included	Excluded	Excluded
PLAYING WITH FIRE	RAILROAD	SMOKING	VEHICLE	OTHER/MISC	
Excluded	Excluded	Excluded	Excluded	Included	

Ignition Source

Undetermined after preliminary fire investigation.

Victim, Witness, Subject

Vehicle/Equipment

State of California CAL FIRE LE-66a (REV.10-2013)	Wildland Fire Investigation	Incident Number	15CABDU001662
		Incident Date	Feb 06, 2015

NARRATIVE
Details of the investigation.

February 6, 2015, at 2:07 P.M., E3561 was dispatched as part of a wildland dispatch, to a reported vegetation fire on Lower Creek Rd approximately 1 mile North of Gorge Rd. Upon arrival, I observed approximately 2-3 acres of vegetation burning with an approximately 70 MPH South to South East wind pushing the fire in a Northerly direction. I observed numerous trees down in the area of the fire origin. E3561 engaged in fire supression activity, and was unable to complete a preliminary fire investigation. Investigation was completed by P3522 TOMINAGA.

Wildland Fire Investigation

Incident Number

15CABDU001662

Incident Date

Feb 06, 2015

DISPATCH RPT FC-34 FIRE RPT FC-18 PHOTOS CHP RPT SKETCH DIAGRAM

SUPPLEMENTAL RPT LE-71 EVID RPT LE-75e PHOTOS LE-75p MAPS OTHER:

Reporting Officer: Matthew J Franklin Signature:

Date Report Completed: Apr 20, 2015 Badge Number: 4332

Reviewing Officer: Brian A Tominaga Signature:

10.9 - Damage Summary

**ROUND Incident
Damage Inspection Summary
15-CA-BDU-001662**



February 6, 2015

Submitted by: Debbie Chapman Lead DINS

Team: BDU

TABLE OF CONTENTS

INTENT AND SCOPE	1
BACKGROUND	1
Synopsis.....	2
Weather	2
Fuels and Fire Behavior	4
Initial Attack	5
Damage Inspection Team Narrative	5
Day 1 – Saturday 2/7/14	6
Day 2 – Sunday 2/8/15	6
Day-3 Monday 2/9/15.....	7
Day-4 Tuesday 2/10/15.....	7
Findings	8
Assets at Risk	9
Pre Fire Activities	9
Vegetation Management Effects on the Fire	10
Conclusion	11
Attachment A - Detailed Damage Inspection Form	12
Attachment B - Fire Damage Spreadsheet	14
Attachment C – LRA/SRA Map	16
Attachment D – Fire Perimeter Map	17
Attachment E – Fire Perimeter Damage Parcel, DPA	18
Attachment F – Fire History	19
Attachment G – Fire Progression	20
Attachment h – Damage Inspection Team	21
Attachment I – Aerial Photos	21
Attachment J – Individual Damage Inspection Reports	21

INTENT AND SCOPE

The Intent of this document is to report damage resulting from the Round Incident (CABDU 001662) that occurred on February 6, 2015 west of Hwy 395 at Sherwin Grade within Inyo and Mono counties.

This report evaluates fire damage to habitable structures. It does not evaluate fire damage to infrastructure, mobile property, and miscellaneous parcel improvements. The report also identifies defensible space inspections, Fire Hazard Fuel Reduction Projects, within the fire perimeter.

BACKGROUND



The Owens Valley Battalion lies to the north of San Bernardino County along the Highway 395 corridor. The valley is surrounded by the White Mountain Range and the Inyo Mountain to the east with peaks as high as 14,286 feet and the Sierra Nevada's on the west with peaks as high as 14,375. The Owens Valley is well known for its outdoor recreation, and boast's world class fishing, snow skiing, hiking and camping which draws a crowd through the holiday season and the weekends that increases the local population by an estimated 30,000. The Battalion encompasses the counties of Inyo and Mono, which protects 540,000 acres of SRA lands in and around the communities of Bishop, Big Pine, Starlite, Rovana, 40 Acres, Mustang Mesa, Independence, Aspendale, South Fork, Lone Pine, Keeler, Cartago and Olancho in Inyo County, and Paradise, Toms Place, Swall Meadows, Benton, Chalfant, and Lake Crowley in Mono County. The Owens Valley is considered a deep valley bottom, with varied deep canyon

drainages extending down the mountain slopes from the Sierra Nevada Mountain Range on the west and the White and Inyo Mountain Range on the east. With an average annual rainfall of 6 to 8 inches the Owens Valley is considered by most to be rain sheltered.

SYNOPSIS




The Round incident started at 1400 on February 6, 2015, West of Hwy 395 at the Sherwin Grade, 9 miles West of Bishop in Inyo County. Communities of Swall Meadows, Paradise, Tom's Place and Sunny Slopes, Private Ranchland and Mule Deer winter range. The fire burned 7000 acres of which 3425 acres on State Responsibility Area and 3112 acres on Federal land. The fire consumed a total of 53 structures (35 residential and 18 nonresidential). 41 of those structures were in FRA while 18 were in SRA. The Fire Management Assistance Declaration (FM-5079) was not approved for the Round Fire. Contact the Office of Emergency Services (OES) for more information.

WEATHER


Bishop and Owens Valley has an arid climate, getting an average rainfall of 5.18 inches, and an average snowfall of 6.8 inches. The majority of the area's precipitation occurs in December, January and February. Bishop usually received about 3 inches of precipitation in the winter months, but there has been less than 0.2 inches to date this winter. The average high temperatures for February are 57.9 degree Fahrenheit, while the average lows are 26 degree Fahrenheit. During the week leading up to the fire, the RAWS weather data shows the maximum air temperatures had been in the low 60's and average relative humidity was around 30% , No significant rainfall had occurred since December 12, 2014, when 0.13 inches was recorded by Owens Valley

RAWS. On February 6th the average relative humidity was 31%; the temperature peaked at 65 deg F. Average wind speeds were around 7MPH earlier in the day on February 6th, but began picking up with gusts peaking around 20:00, recorded at up to 51 MPH at the Rock Creek RAWs, although there is anecdotal evidence that they reached up to 70 MPH.



On Friday afternoon rain and high elevation snow were expected in the Sierra due to an atmospheric river moving into Northern California. The storm moved in slower than expected, but high winds were leading it. Precipitation was not seen in Owens Valley until Saturday, February 7th.

Precipitation



FUELS AND FIRE BEHAVIOR



The fuels within the Battalion consist of timber transitioning to juniper, pine and sage bitterbrush in Mono County, to scattered sage and rabbit brush with salt grass understory and a Tule base around the riparian areas in the valley floor and heavy sage with rabbit brush and bitterbrush along the western slopes in Inyo County. The local winds in the area are very susceptible to change and are influenced by terrain to such an extent that any given area can be opposite of what you might expect. Diurnal changes are extreme and strong, down slope winds can be expected, driving wildland fires rapidly downhill and across the flats. Flame lengths of 15 to 60 feet have been observed and rates of spread 10,000 feet an hour, in the sage are seen during periods of high winds, with spotting as far as 3/4 miles. Notable fires in the area include the Paradise #2 Fire in 1958 burning 341 acres, the Swall Fire in 1974 burning 666 acres, the Swall Fire in 1981 burning 3159 acres and the Birch Fire 2002 burning 2549 acres.

INITIAL ATTACK



The first arriving resources, Chief 101, Chief 3900, B3514B and two engines observed approximately 3-5 acres on both sides of lower rock creek road, burning northeast towards Hwy 395, with power lines down. The fire then spotted back across Lower Rock Creek to the west and started to burn towards the Community of Paradise. Mono SO started a mandatory evacuation of Paradise. The fire continued to spread after a frontal passage moved in with gusts to 50mph, and extreme fire behavior with very rapid rates of spread, group torching, long range spotting (1/4 mile+). B3514B measured the wind at 71 mph with a Kestrel hand held wind meter. The incident continued to grow rapidly as the fire consumed vegetation and residential structures in the Paradise and Swall Meadows communities.


DAMAGE INSPECTION TEAM NARRATIVE

The Round Fire started on Friday February 6, 2015, at 1401. Mono County Building Official Tom Perry and Mono County Building Inspector/Plans Examiner Jim Shoffner on an initial assessment of damage to structures, in the communities of Paradise Estates and Swall Meadows. On February 7, 2014, additional personal were requested to create a DINS team to assess structural fire damage which consisted of a DINS lead, 1 GISS, and 4 Field observers.

DAY 1 – SATURDAY 2/7/14

On Saturday February 7th, 2015 Captain Pete Hein escorted Mono County Building Official Tom Perry and Mono County Building Inspector/Plans Examiner Jim Shoffner on an initial assessment of damage to structures, in the communities of Paradise Estates and Swall Meadows. The objective was to identify and document structures which were a total loss, and structures which had been damaged by the fire and/or subsequent fire suppression activities. Mr. Perry also determined which damaged residences could be re-inhabited and which could not. The team conducted the tour using a Google Map of Paradise Estates and a Wheeler Crest Fire Protection District Address Location Map of Swall Meadows. They identified and documented destroyed Single Family Residences and Garages with notes on the maps, took GPS coordinates, (WGS84), at the intersection of driveway and street, and took one representative photograph of each destroyed residence. A walk around of intact structures was conducted to determine extent of fire and/or suppression damage. The pre-assessment tour was hindered by smoke, down power lines, hazard trees, rain and failing daylight. In the Sky Meadow Rd. and Pine Rd. area, no photos were taken due to lack of ambient light. Notes and maps collected for the pre-assessment were used the following day by Captain Debbie Chapman and her teams for Damage Assessment field data collection. On February 7, 2014, at 1700 hours, additional personnel were requested to create a DINS team to access structural fire damage which consisted of a DINS lead, 1 GISS, and 4 Field observers.

DAY 2 – SUNDAY 2/8/15



The DINS team was divided into three teams to conduct the Damage assessment inspections in the Swall Meadow and Paradise communities. Three colors were utilized to distinguish the teams and the areas that were responsible for collecting data in: Blue, Yellow and Orange. The ESRI Collector application was downloaded on each team's phone to use as a tool to collect points, pictures and damage assessment information

for each damaged or destroyed structure. Damage inspector teams were given a briefing on safety and how to use the Collector app. Additionally, each team had a map of the vicinity and paper inspection forms as a backup if cellular service was not available. Lack of cellular service was only an issue in Paradise. The team used the corresponding "team" color flagging to mark each destroyed structure with the respective address, date, team name and time. Some of the challenges during the data collection process, included attempting to use the Collector application while it was raining, down power lines, fire engines, hand crews and utility crews working in the fire area and potential fire weakened trees within the fire perimeter. At approximately 1330 hours, Debbie Chapman and Tiffany Meyer conducted a recon flight on H-305 to access the destroyed structures within the fire area.



DAY-3 MONDAY 2/9/15

The data and photos that were collected by the Collector app were downloaded as an ArcGIS geodatabase point dataset from the Damage Inspection Data Collection secure web service where they were being stored during data collection. The point data was then brought into ArcMap for reconciliation, and compared against imagery and parcel data to confirm that they were in the correct place with the correct address and that data was collected for the mandatory fields. Some points were found not to have complete data or photos attached to them. This was due to: a) software glitch, b) user error c) phone connectivity to cell service. Field observers were sent back to the field to fill in the missing data and photos. FOBS revisited 9 sites. Parcel data was then joined to the damage inspection point data to acquire parcel APN numbers and other assessor information for each affected property. Maps and reports were produced to display pertinent data.

DAY-4 TUESDAY 2/10/15


The DINS team continued their efforts gathering information for reports, maps and collecting post inspection data on non-damaged structures in the Swall Meadow and Paradise communities. (See supplemental report – Post Fire Non-Damaged Structure Data Collection)

FINDINGS

The fire consumed a total of 53 structures (35 residential and 18 nonresidential). All of the residential damage was in Mono County. Two of the 53 structures were in Inyo County. One was a large shop and the other was a small outbuilding.

The damage assessment found 41 affected structures in FRA and 18 in SRA.

Damaged and destroyed structures by responsibility area.



Damage inspectors attempted to identify some structure features of the damaged/destroyed structures, based on remaining debris, when possible. The following tables are based on the data collected; post-fire, of just residences that were destroyed.

Combustible and Non-Combustible Roofs and Exterior Siding (estimated):

	Homes Roof Construction	Home Exterior Siding
Combustible	1	8
Non-Combustible	29	15
unknown	5	12
Grand Total	35	35

Deck or Porch Material Types of destroyed homes (estimated):

Deck or porch material types	Number Homes
Masonry	1
Not-Applicable	2
unknown	21
Wood	11
Grand Total	35

ASSETS AT RISK

Communities of Swall Meadow, Paradise, Tom's Place, Sunny Slopes, Private ranchland and mule deer winter range.

PRE FIRE ACTIVITIES

The defensible space inspection program, PRC-4291, have continued in both Mono and Inyo counties. The property inspections performed by the CAL FIRE personnel have been instrumental in pre-fire management. Additionally, the annual Bishop Mule Days provides outreach to communities in Inyo and Mono Counties for fire prevention and defensible space education.


A post fire vegetation clearance evaluation was done for all destroyed homes. 22 of the 35 homes were found to have a clearance of 0-30 feet.

Vegetation Clearance of destroyed homes:

Vegetation Clearance	Number Homes
>100	1
0-30	22
30-60	4
60-100	6
unknown	2
Grand Total	35

VEGETATION MANAGEMENT EFFECTS ON THE FIRE

The Wheeler Fire Safe Council and cooperators CAL FIRE, Bishop BLM and Inyo National Forest have completed various fuel reduction projects in the Swall Meadow area. In 2003, a fuel break was constructed on Sky Meadows Road. Subsequently, in 2009 and 2011 the fuel break was maintained by hand piling and thinning the area. In 2009 and 2011, the Wheeler Fire Safe Council were awarded grants for chipping and the manipulation of fuels by reducing the density and continuity of the fuel while increasing overall health of the vegetation community in the Swall Meadow community. (See map below)



CONCLUSION

The DINS team worked together to locate and record data regarding damaged and destroyed structures on the Round Fire. The damage spanned across both Mono and Inyo Counties. During the inspections process there were 35 habitable structures and 18 non habitable structures identified as destroyed. Data was captured using the ESRI Collector Application.

ATTACHMENT A - DETAILED DAMAGE INSPECTION FORM



State of California
 Department of Forestry and Fire Protection

Pre and Post Fire Inspection (PPFIS) Worksheet

Report Type (check only one): <input type="checkbox"/> DEFENSIBLE SPACE INSPECTION <input type="checkbox"/> DAMAGE REPORT INSPECTION	
Inspector's Name (print): _____ Date: _____	
PROPERTY	Physical Address
	Latitude (Degree Decimal Minutes): _____ Longitude (Degree Decimal Minutes): _____
	Address Number (e.g., 1234): _____ Address Road ¹ : _____
	Address Suffix ² : _____ City: _____ State: _____ Zip Code: _____
	Unit: _____ Battalion ³ : _____
	Community ⁴ : _____ County: _____
	Mailing Address (if different from physical address)
	Address Number (e.g., 1234): _____ Address Road: _____
	Address Suffix ⁵ : _____ City: _____ State: _____ Zip Code: _____
	Can the Inspector access the property? <input type="checkbox"/> Yes <input type="checkbox"/> No
If No, (check only one item below) <input type="checkbox"/> Uncooperative Property Owner <input type="checkbox"/> Inaccessible <input type="checkbox"/> Animals <input type="checkbox"/> Noted Fortification <input type="checkbox"/> Other with explanation _____	
If Yes, answer the questions below:	
Dominant Topography (check only one) <input type="checkbox"/> Flat Ground <input type="checkbox"/> Slope <input type="checkbox"/> Ridge Top <input type="checkbox"/> Saddle <input type="checkbox"/> Chimney	
Is the Address Visible: <input type="checkbox"/> Yes <input type="checkbox"/> No	
Is the Address Reflective: <input type="checkbox"/> Yes <input type="checkbox"/> No	
Water Storage: <input type="checkbox"/> Yes <input type="checkbox"/> No	
Water Storage Gallons (check only one): <input type="checkbox"/> 1500 <input type="checkbox"/> 2000 <input type="checkbox"/> 2500 <input type="checkbox"/> 5000 <input type="checkbox"/> over 5000	
# of Structures (complete back of form): _____	
Can property be inspected? <input type="checkbox"/> Yes <input type="checkbox"/> No	
If Yes, Occupant's Name (First and Last Name): _____ Contact Phone Number: _____	
Email Address: _____ Occupant Home: <input type="checkbox"/> Yes <input type="checkbox"/> No	
If No, Do you want to reschedule the inspection? <input type="checkbox"/> Yes <input type="checkbox"/> No	
If Yes, Re-inspection date: _____	
If No, Reason to escalate to the Inspection Coordinator: (check only one) <input type="checkbox"/> Uncooperative Property Owner <input type="checkbox"/> Inaccessible ⁶ <input type="checkbox"/> Animals <input type="checkbox"/> Noted Fortification ⁷ <input type="checkbox"/> Other _____	
# of hours the Inspector spent with Home Owner (check only one) <input type="checkbox"/> 0:00 <input type="checkbox"/> 0:15 <input type="checkbox"/> 0:30 <input type="checkbox"/> 0:45 <input type="checkbox"/> 1:00 <input type="checkbox"/> 1:15 <input type="checkbox"/> 1:30	
Delivery Notification Method: <input type="checkbox"/> Email <input type="checkbox"/> Mailed <input type="checkbox"/> Hardcopy	
Escalate failed inspection record to the Inspection Coordinator <input type="checkbox"/> Yes <input type="checkbox"/> No	
Comment: _____	
DAMAGE	Incident Number: (e.g. 2001 CARRU 999999) _____ Incident Name: _____
	Incident Start Date: _____ Vegetation clearance around habitable structure (check only one): <input type="checkbox"/> 0-30 <input type="checkbox"/> 30-100
	Comment: _____
Turn page over and complete the back.	

PPFIS Worksheet (rev date: 7/10/2014)

¹ Address Road (e.g., Court, Hwy 50, Blvd)
² Address Suffix (e.g., apartment, building a, b, or c, lot 12)
³ Unit Geographic Areas (e.g., 1-30)
⁴ Community (e.g., focus area)
⁵ Address Suffix (e.g., apartment, building a, b, or c, lot 12)
⁶ Inaccessible (e.g., locked gate)
⁷ Noted Fortification (e.g., keep out, no trespassing)

Structure Type	Year	Structure #						
		1	2	3	4	5	6	7
1) Single Family Residence								
a) Single Story								
b) Multi Story								
2) Multi-Family Residence ⁸								
a) Single Story								
b) Multi Story								
3) Mobile Home								
a) Single Wide								
b) Double Wide								
c) Triple Wide								
d) Motor Home ⁹								
4) Commercial Building								
a) Single Story								
b) Multi Story								
5) Non-Inhabitable								
a) Shop								
b) Barn								
c) Detached Garage								
d) Outbuilding greater than 10'x12'								
6) Other (Describe)								
Construction Categories		1	2	3	4	5	6	7
1) Roof Construction								
a) Combustible								
b) Non-Combustible								
2) Window Panes								
a) Single								
b) Multi-Pane								
c) Unknown								
3) Exterior Siding								
a) Combustible								
b) Non-Combustible								
4) Eaves								
a) Enclosed								
b) Un-Enclosed								
c) Not Applicable								
5) Deck or Porches								
a) Masonry								
b) Composite								
c) Wood								
d) Not Applicable								
6) Eave Vent Screen								
a) Yes								
b) No								
Damage Report		1	2	3	4	5	6	7
Damaged ¹⁰								
Destroyed ¹¹								
Estimated \$ Loss								

⁸ Multi-Family Residence (e.g. apartment buildings)

⁹ Motor Home (if used as a residence)

¹⁰ Damaged Percentages 10%, 25%, 50% 75%

¹¹ Destroyed Percentage greater than 75%


ATTACHMENT B - FIRE DAMAGE SPREADSHEET

ID no	latitude	longitude	APN	St no	St Name	St Type	Community	County
9-1	37.51036895	-118.6339826	64190008000	9	Wilson	Road	Swall Meadows	Mono
11-1	37.51025709	-118.6343222	64190008000	9	Wilson	Road	Swall Meadows	Mono
45-1	37.5113342	-118.6338844	64190007000	45	Pine	Dr	Swall Meadows	Mono
45-2	37.51147994	-118.633993	64190007000	45	Pine	Dr	Swall Meadows	Mono
55-1	37.50593632	-118.6275047	64200002000	55	Pinon	Dr	Swall Meadows	Mono
59-1	37.50969164	-118.6339662	64100021000	59	Valley View	Road	Swall Meadows	Mono
59-2	37.50968849	-118.634633	64100021000	59	Valley View	Road	Swall Meadows	Mono
67-1	37.51232614	-118.6375207	64180001000	67	N Valley View	Rd	Swall Meadows	Mono
72-1	37.51247202	-118.636517	64180011000	72	N Valley View		Swall Meadows	Mono
75-1	37.51270599	-118.6374764	64180002000	75	N Valley View	Rd	Swall Meadows	Mono
89-1	37.51001544	-118.6356201	64190009000	89	Wilson	Road	Swall Meadows	Mono
94-1	37.51338343	-118.6390455	64160003000	94	Mountain View	Rd	Swall Meadows	Mono
94-2	37.51351871	-118.6392349	64160003000	94	Mountain View	Rd	Swall Meadows	Mono
97-1	37.50879201	-118.6345534	64100022000	97	Valley View	Road	Swall Meadows	Mono
105-1	37.50410968	-118.6318527	64100046000	105	Sierra way		Swall Meadows	Mono
130-1	37.5083106	-118.635869	64100057000	130	Valley View	Road	Swall Meadows	Mono
140-1	37.50891213	-118.6396641	64100016000	140	Willow	Road	Swall Meadows	Mono
153-1	37.51095769	-118.6464363	64110002000	153	Foothill	Rd	Swall Meadows	Mono
159-1	37.50931883	-118.6379893	64100017000	159	Willow	Road	Swall Meadows	Mono
171-1	37.51277026	-118.635702	64180010000	171	Pine	Dr	Swall Meadows	Mono
175-1	37.51083413	-118.6469486	64110003000	175	Foothill	Rd	Swall Meadows	Mono
175-2	37.5110249	-118.6469609	64110003000	175	Foothill	Dr	Swall Meadows	Mono
193-1	37.51080288	-118.6473743	64110004000	193	Foothill	Rd	Swall Meadows	Mono
193-2	37.51068032	-118.6472455	64110004000	193	Foothill	Rd	Swall Meadows	Mono
255-1	37.50619015	-118.6304878	64100032000	255	Rimrock	Rd	Swall Meadows	Mono
280-1	37.50358126	-118.6250512	64200013000	280	Pinon	Dr	Swall Meadows	Mono
301-1	37.50606864	-118.6297434	64100031000	301	Rimrock	Dr	Swall Meadows	Mono
320-1	37.51343939	-118.6426072	64150004000	320	Mountain View	Rd	Swall Meadows	Mono
320-2	37.51323795	-118.6425853	64150004000	320	Mountain View	Rd	Swall Meadows	Mono
346-1	37.5059658	-118.6366194	64100013000	346	Valley View	Road	Swall Meadows	Mono
346-2	37.5061541	-118.6370304	64100013000	346	Valley View	Road	Swall Meadows	Mono


ROUND INCIDENT CABDU-001662
Damage Inspection Summary
Page 15 of 24

370-1	37.50495835	-118.6288703	64200018000	370	Rimrock	Dr	Swall Meadows	Mono
370-2	37.50490235	-118.628723	64200018000	370	Rimrock	Dr	Swall Meadows	Mono
370-3	37.50523595	-118.6291473	64200025000	370	Rimrock	Dr	Swall Meadows	Mono
460-1	37.50407992	-118.6284066	64200019000	460	Rimrock	Dr	Swall Meadows	Mono
461-1	37.51242693	-118.6454245	64130007000	461	Mountain View	Rd	Swall Meadows	Mono
507-1	37.50405523	-118.6370601	64100010000	507	Willow	Rd	Swall Meadows	Mono
519-1	37.50347605	-118.6383585	64100009000	519	Willow	Rd	Swall Meadows	Mono
519-2	37.50322667	-118.6382227	64100009000	519	Willow	Rd	Swall Meadows	Mono
519-3	37.5033895	-118.637955	64100009000	519	Willow	Rd	Swall Meadows	Mono
739-1	37.51136828	-118.6495304	64110008000	739	Mountain View	Rd	Swall Meadows	Mono
788-1	37.51259858	-118.6482395	64120018000	788	Mountain View	Rd	Swall Meadows	Mono
788-2	37.51266575	-118.6485354	64120018000	788	Mountain View	Rd	Swall Meadows	Mono
818-1	37.51300195	-118.6482055	64120019000	818	Mountain View	Rd	Swall Meadows	Mono
826-1	37.51132252	-118.6344767	64190006000	826	Swall Meadows	Rd	Swall Meadows	Mono
926-1	37.51817604	-118.646506	64090014000	926	Sky Meadows	Rd	Swall Meadows	Mono
926-2	37.51849926	-118.6465879	64090014000	926	Sky Meadows	Rd	Swall Meadows	Mono
931-1	37.5112374	-118.6365688	64190003000	931	Swall Meadows	Rd	Swall Meadows	Mono
1046-1	37.51212537	-118.6387521	64170004000	1046	Swall Meadows	Rd	Swall Meadows	Mono
1046-2	37.51179703	-118.6388415	64170004000	1046	Swall Meadows	Rd	Swall Meadows	Mono
1046-3	37.51219985	-118.6388345	64170004000	1046	Swall Meadows	Rd	Swall Meadows	Mono
1274-1	37.51191082	-118.6427324	64140006000	1274	Swall Meadows	Rd	Swall Meadows	Mono
1274-2	37.51181168	-118.6425176	64140006000	1274	Swall Meadows	Rd	Swall Meadows	Mono
1430-1	37.51193654	-118.6453124	64130004000	1430	Swall Meadows	Rd	Swall Meadows	Mono
1430-2	37.51216722	-118.645457	64130004000	1430	Swall Meadows	Rd	Swall Meadows	Mono
1450-1	37.51184491	-118.6458916	64130002000	1450	Swall Meadows	Rd	Swall Meadows	Mono
2164-1	37.45402833	-118.5836803	911005	2164	Old Sherwin	Grade	Round Valley	Inyo
2180-1	37.46022534	-118.5934683	911003	2180	Old Sherwin	Grade	Paradise	Inyo
4866-1	37.47781745	-118.6082761	26380029000	4866	Deer Peak	TR	Paradise	Mono


ATTACHMENT C – LRA/SRA MAP




ATTACHMENT D – FIRE PERIMETER MAP




ATTACHMENT E – FIRE PERIMETER DAMAGE PARCEL, DPA



ATTACHMENT F – FIRE HISTORY



ATTACHMENT G – FIRE PROGRESSION



ATTACHMENT H – DAMAGE INSPECTION TEAM

Debbie Chapman – Lead DINS, Tiffany Meyer – GISS, Kevin Lindo FOBS, Gene Potkey FOBS, Tom Knecht FOBS

ATTACHMENT I – AERIAL PHOTOS



ATTACHMENT J – INDIVIDUAL DAMAGE INSPECTION REPORTS

Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 926-1

APN 64090014000 Address 926 Sky Meadows Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage Destroyed

Assessed Improvement Value \$35,922.00

ACREAGE 11.24

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present

unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 1352D70B-C3B0-439A-B19C-FA11EA0DF176.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round Incident Number CA-BDU-1662
Record ID 926-2

APN 64090014000 Address 926 Sky Meadows Rd
City CA CA Zip 93514

Structure Type Non-Inhabitable-Detached Garage Damage Destroyed
Assessed Improvement Value \$35,922.00 ACREAGE 11.24
Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction unknown Deck or Porch present unknown
Window Panes unknown Eave Vent Screen
Eaves unknown

photoID ASD1C571-6F0A-4ED7-A6ED-063E74816821.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 97-1

APN 64100022000 Address 97 Valley View Road

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$177,602.00

ACREAGE 2.05

Post Fire - Estimated Vegetation Clearance 30-60

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes Multi-Pane

Eave Vent Screen

Eaves unknown

photoID 7A089789-55B0-42B4-B563-E14369B00901.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 159-1

APN 64100017000 Address 159 Willow Road

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$249,566.00

ACREAGE 5.97

Post Fire - Estimated Vegetation Clearance 60-100

Roof Construction Non-Combustible Deck or Porch present unknown

Window Panes Multi-Pane Eave Vent Screen

Eaves unknown

photoID C5031042-FF0D-4AC5-A288-3390C8D1ECCD.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round Incident Number CA-BDU-1662
Record ID 94-1

APN 64160003000 Address 94 Mountain View Rd
City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story Damage Destroyed
Assessed Improvement Value \$132,721.00 ACREAGE 1.29
Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction unknown Deck or Porch present unknown
Window Panes unknown Eave Vent Screen
Eaves unknown

photoID BE6C0F8F-D790-4DCB-A05D-B15F474D36F1.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 94-2

APN 64160003000 Address 94 Mountain View Rd

City CA CA Zip 93514

Structure Type Non-Inhabitable-Detached Garage

Damage Destroyed

Assessed Improvement Value \$132,721.00

ACREAGE 1.29

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction unknown

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID A59FB4EA-B891-48A1-A93C-CBC0B1CD3BE3.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662

Record ID 461-1

APN 64130007000 Address 461 Mountain View Rd

City CA CA Zip 93514

Structure Type Non-Inhabitable-Detached Garage

Damage Destroyed

Assessed Improvement Value \$226,872.00

ACREAGE 1.21

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present

Not-Applicable

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 7A3FE2AF-28E5-4432-B4C3-C48CA92CF3BF.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662

Record ID 739-1

APN 64110008000 Address 739 Mountain View Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$271,190.00

ACREAGE 0.82

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 2A55721E-0343-474A-8462-EDF0DF98AE53.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 1-Sep

APN 64190008000 Address 11 Wilson Road

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$367,123.00

ACREAGE 1.53

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible Deck or Porch present

Wood

Window Panes Multi-Pane Eave Vent Screen

Eaves unknown

photoID 581200EB-30EC-40EE-94C6-21D4BDA6640F.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round Incident Number CA-BDU-1662
Record ID 1-Nov

APN 64190008000 Address 9 Wilson Road

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$367,123.00

ACREAGE 1.53

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present

Wood

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID A9F2328C-8E6F-4DB9-A41D-824CFBDFCFC1.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 519-1

APN 64100009000 Address 519 Willow Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$223,596.00

ACREAGE 7.88

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 11D30136-18D5-46C4-A2CD-D8BC83E67F76.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 519-3

APN 64100009000 Address 519 Willow Rd

City CA CA Zip 93514

Structure Type Non-Inhabitable-Barn

Damage Destroyed

Assessed Improvement Value \$223,596.00

ACREAGE 7.88

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 446EBE43-7BC3-45C1-8A95-2F7DEECA1B96.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662

Record ID 519-2

APN 64100009000 Address 519 Willow Rd

City CA CA Zip 93514

Structure Type Non-Inhabitable-Barn

Damage Destroyed

Assessed Improvement Value \$223,596.00

ACREAGE 7.88

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible Deck or Porch present unknown

Window Panes unknown Eave Vent Screen

Eaves unknown photoID

Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 2180

APN 911003 Address 2180 Old Sherwin Grade

City CA CA Zip 93514

Structure Type Non-Inhabitable-Shop

Damage Destroyed

Assessed Improvement Value \$1,476,466.00

ACREAGE 0.00

Post Fire - Estimated Vegetation Clearance unknown

Roof Construction unknown

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID Sherwinaerial.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 2164

APN 911005 Address 2164 Old Sherwin Grade

City Ca CA Zip 93514

Structure Type Outbuilding gt 10'X12'

Damage Destroyed

Assessed Improvement Value \$0.00

ACREAGE 0.00

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present

Window Panes

Eave Vent Screen

Eaves

photoID oldsherwin_shed.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round Incident Number CA-BDU-1662
Record ID 1046

APN 64170004000 Address 1046 Swall Meadows Rd
City CA CA Zip 93514

Damage Destroyed

Assessed Improvement Value \$260,000.00 ACREAGE 0.82

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible Deck or Porch present Not-Applicable

Window Panes unknown Eave Vent Screen

Eaves unknown

photoID 1046_swall_garage.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 1046

APN 64170004000 Address 1046 Swall Meadows Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$260,000.00

ACREAGE 0.82

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present

unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 1046swall_house



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 1046

APN 64170004000 Address 1046 Swall Meadows Rd

City CA CA Zip 93514

Structure Type Outbuilding gt 10'X12'

Damage Destroyed

Assessed Improvement Value \$260,000.00

ACREAGE 0.82

Post Fire - Estimated Vegetation Clearance unknown

Roof Construction Non-Combustible Deck or Porch present unknown

Window Panes unknown Eave Vent Screen

Eaves unknown photoID

Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 507-1

APN 64100010000 Address 507 Willow Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$274,141.00

ACREAGE 7.49

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Combustible

Deck or Porch present

Wood

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID DCAF5942-57A0-46AB-8014-50C33A787973.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 67-1

APN 64180001000 Address 67 N Valley View Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$457,562.00

ACREAGE 0.90

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present

unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 17670F54-3D3F-4783-925F-3FAA33C63B5B.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round Incident Number CA-BDU-1662
Record ID 346-2

APN 64100013000 Address 346 Valley View Road
City CA CA Zip 93514

Structure Type Non-Inhabitable-Detached Garage

Damage Destroyed

Assessed Improvement Value \$452,449.00

ACREAGE 10.26

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible Deck or Porch present

unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID {38978D65-786F-42F7-B9FD-2F59A3CFDE08}

Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 346-1

APN 64100013000 Address 346 Valley View Road

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$452,449.00

ACREAGE 10.26

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present

unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 40483FED-41F5-45D6-B311-672ACA3E3B36.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 75-1

APN 64180002000 Address 75 N Valley View Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage 10-25%

Assessed Improvement Value \$203,738.00

ACREAGE 0.90

Post Fire - Estimated Vegetation Clearance 30-60

Roof Construction Non-Combustible Deck or Porch present Wood

Window Panes Multi-Pane Eave Vent Screen

Eaves Enclosed

photoID 384B0529-E358-4B00-A633-739CD45C362F.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 59-2

APN 64100021000 Address 59 Valley View Road

City CA CA Zip 93514

Structure Type Non-Inhabitable-Shop

Damage Destroyed

Assessed Improvement Value \$250,561.00

ACREAGE 2.05

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 3897FC4A-B6AF-459D-9C8D-53113EB2D949.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 59-1

APN 64100021000 Address 59 Valley View Road

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$250,561.00

ACREAGE 2.05

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 5D60A232-B3A1-47BD-BA1A-4230E5ECED77.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 72-1

APN 64180011000 Address 72 N Valley View

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$469,988.00

ACREAGE 1.93

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 72NValleyView.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round Incident Number CA-BDU-1662
Record ID 460-1

APN 64200019000 Address 460 Rimrock Dr
City CA CA Zip 93514

Damage Destroyed

Assessed Improvement Value \$218,342.00 ACREAGE 2.10

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible Deck or Porch present Wood

Window Panes unknown Eave Vent Screen

Eaves unknown

photoID 2E876732-030F-4E3C-9F1E-4938D26A35A2.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round Incident Number CA-BDU-1662
Record ID 826-1

APN 64190006000 Address 826 Swall Meadows Rd
City CA CA Zip 93514

Structure Type Single Family Residence-Single Story Damage Destroyed

Assessed Improvement Value \$295,419.00 ACREAGE 0.89

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible Deck or Porch present Wood

Window Panes unknown Eave Vent Screen

Eaves unknown photoID 826SwallMeadow



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 1450

APN 64130002000 Address 1450 Swall Meadows Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$206,872.00

ACREAGE 0.75

Post Fire - Estimated Vegetation Clearance 60-100

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 8E516925-5082-497A-9CBC-6BC6759A3366.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 153-1

APN 64110002000 Address 153 Foothill Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$295,000.00

ACREAGE 0.91

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present

Not-Applicable

Window Panes Multi-Pane

Eave Vent Screen

Eaves unknown

photoID 028F0C23-9127-4005-A718-41546C6CFC96.jpg





Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round Incident Number CA-BDU-1662
Record ID 55-1

APN 64200002000 Address 55 Pinon Dr

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$215,109.00

ACREAGE 2.02

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present

Wood

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 55Pinon



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 45-1

APN 64190007000 Address 45 Pine Dr

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$135,980.00

ACREAGE 0.95

Post Fire - Estimated Vegetation Clearance unknown

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 45Pine



Individual Damage Inspection Detail

Art Date	2/6/2015	Incident Name	Round	Incident Number	CA-BDU-1662
				Record ID	45-2

APN 64190007000 Address 45 Pine Dr

City CA CA Zip 93514

Structure Type Non-Inhabitable-Detached Garage

Damage Destroyed

Assessed Improvement Value \$135,980.00

ACREAGE 0.95

Post Fire - Estimated Vegetation Clearance unknown

Roof Construction unknown

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID {E718B251-FA29-4900-AA71-0B0DC734BF87}

Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 370-1

APN 64200018000 Address 370 Rimrock Dr

City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage Destroyed

Assessed Improvement Value \$500,000.00

ACREAGE 2.11

Post Fire - Estimated Vegetation Clearance unknown

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 370RockRim



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 370-2

APN 64200018000 Address 370 Rimrock

City CA CA Zip 93514

Structure Type Non-Inhabitable-Detached Garage

Damage Destroyed

Assessed Improvement Value \$500,000.00

ACREAGE 2.11

Post Fire - Estimated Vegetation Clearance 60-100

Roof Construction Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photo 370rimrock_garage



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662

Record ID 171-1

APN 64180010000 Address 171 Pine Dr

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$122,585.00

ACREAGE 2.00

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible Deck or Porch present unknown

Window Panes unknown Eave Vent Screen

Eaves unknown photoID 171Pine



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 320-2

APN 64150004000 Address 320 Mountain View Rd

City CA CA Zip 93514

Structure Type Non-Inhabitable-Detached Garage

Damage Destroyed

Assessed Improvement Value \$372,847.00

ACREAGE 1.29

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction unknown

Deck or Porch present

Not-Applicable

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 04629549-7250-4957-B161-12AFF6623202.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 320-1

APN 64150004000 Address 320 Mountain View Rd
City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage 10-25%

Assessed Improvement Value \$372,847.00

ACREAGE 1.29

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible Deck or Porch present Wood

Window Panes Multi-Pane Eave Vent Screen

Eaves Enclosed

photoID 89611AE0-E730-4C8C-BDC3-0EB2F8EEBCBD.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 788-1

APN 64120018000 Address 788 Mountain View Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage 10-25%

Assessed Improvement Value \$435,468.00

ACREAGE 0.78

Post Fire - Estimated Vegetation Clearance unknown

Roof Construction Non-Combustible

Deck or Porch present

Wood

Window Panes Multi-Pane

Eave Vent Screen

Eaves Enclosed

photoID 616328DF-0E7E-4A10-8420-9207CD5A33BF.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 788-2

APN 64120018000 Address 788 Mountain View Rd
City CA CA Zip 93514

Structure Type Non-Inhabitable-Detached Garage

Damage Destroyed

Assessed Improvement Value \$435,468.00

ACREAGE 0.78

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present

Not-Applicable

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 6876F5BE-9758-4B9A-9D2D-70EB0E433804.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 370-3

APN 64200025000 Address 370 Rimrock

City CA CA Zip 93514

Structure Type Outbuilding gt 10'X12'

Damage Destroyed

Assessed Improvement Value \$0.00

ACREAGE 0.18

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 8C698FB8-2EF6-46C5-B778-3D251FE65DD6.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 193-1

APN 64110004000 Address 193 Foothill Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage 10-25%

Assessed Improvement Value \$160,261.00

ACREAGE 1.14

Post Fire - Estimated Vegetation Clearance 30-60

Roof Construction Non-Combustible

Deck or Porch present

Wood

Window Panes Single

Eave Vent Screen

Eaves Un-Enclosed

photoID 3A23D66F-F719-44D9-A49E-1F45C3E4B7BC.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 193-2

APN 64110004000 Address 193 Foothill Rd
City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$160,261.00

ACREAGE 1.14

Post Fire - Estimated Vegetation Clearance 30-60

Roof Construction Non-Combustible Deck or Porch present unknown

Window Panes unknown Eave Vent Screen

Eaves unknown

photoID A0817C7E-B585-4283-87B2-F31B3D12AE31.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 4866

APN 26380029000 Address 4866 Deer Peak TR

City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage Destroyed

Assessed Improvement Value \$244,665.00

ACREAGE 0.39

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID DeerPeak.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 280-1

APN 64200013000 Address 280 Pinon Dr

City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage Destroyed

Assessed Improvement Value \$310,735.00

ACREAGE 2.00

Post Fire - Estimated Vegetation Clearance 60-100

Roof Construction Non-Combustible

Deck or Porch present

Not-Applicable

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 280Pinon



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 818-1

APN 64120019000 Address 818 Mountain View Rd
City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage Destroyed

Assessed Improvement Value \$125,567.00

ACREAGE 0.99

Post Fire - Estimated Vegetation Clearance 30-60

Roof Construction Non-Combustible

Deck or Porch present

Wood

Window Panes Multi-Pane

Eave Vent Screen

Eaves unknown

photoID B122DB2B-CA49-4614-A793-7676EC5B7BFA.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 140-1

APN 64100016000 Address 140 Willow Road

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$331,956.00

ACREAGE 20.35

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present

Wood

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 3C47D8F4-3E0E-4917-81DA-B97B425A4539.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 1274

APN 64140006000 Address 1274 Swall Meadows Rd
City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$136,761.00

ACREAGE 0.81

Post Fire - Estimated Vegetation Clearance 60-100

Roof Construction unknown

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID F90CFAEB-95C9-4A1A-BEB6-07A0B038E636.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 1274

APN 64140006000 Address 1274 Swall Meadows Rd

City CA CA Zip 93514

Structure Type Mobile Home - Single Wide

Damage 10-25%

Assessed Improvement Value \$136,761.00

ACREAGE 0.81

Post Fire - Estimated Vegetation Clearance 60-100

Roof Construction Non-Combustible Deck or Porch present

Not-Applicable

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID {D8CD009E-321B-4D53-AD7D-5EF16A8853CA}

Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 175-1

APN 64110003000 Address 175 Foothill Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage Destroyed

Assessed Improvement Value \$136,474.00

ACREAGE 1.04

Post Fire - Estimated Vegetation Clearance 30-60

Roof Construction unknown

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 86FB36C6-DAF6-4469-8610-5F8D304AC700.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 175-2

APN 64110003000 Address 175 Foothill Dr

City CA CA Zip 93514

Structure Type Outbuilding gt 10'X12'

Damage Destroyed

Assessed Improvement Value \$136,474.00

ACREAGE 1.04

Post Fire - Estimated Vegetation Clearance 30-60

Roof Construction Non-Combustible Deck or Porch present Not-Applicable

Window Panes Single Eave Vent Screen

Eaves unknown

photoID D25F9853-B9D2-4DB5-8BEB-F1A3111387D1.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 105-1

APN 64100046000 Address 105 Sierra way

City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage Destroyed

Assessed Improvement Value \$337,311.00

ACREAGE 1.61

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present

Masonry

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 293FCDB7-40B6-4AE8-A4EE-1F51020E7EA1.jpg



—

Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round Incident Number CA-BDU-1662
Record ID 1430

APN 64130004000 Address 1430 Swall Meadows Rd
City CA CA Zip 93514

Damage Destroyed

Assessed Improvement Value \$326,077.00 ACREAGE 0.81

Post Fire - Estimated Vegetation Clearance 60-100

Roof Construction Non-Combustible Deck or Porch present Not-Applicable

Window Panes unknown Eave Vent Screen

Eaves unknown photoID 1471B4C5-7774-4D2E-913A-8C4A979E11EF.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 1430

APN 64130004000 Address 1430 Swall Meadows Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage Destroyed

Assessed improvement Value \$326,077.00

ACREAGE 0.81

Post Fire - Estimated Vegetation Clearance 60-100

Roof Construction Non-Combustible

Deck or Porch present

Wood

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID E2943329-E61F-40CE-B120-2A9D4F30DBE7.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 130-1

APN 64100057000 Address 130 Valley View Road

City CA CA Zip 93514

Structure Type Non-Inhabitable-Detached Garage

Damage 10-25%

Assessed Improvement Value \$698,500.00

ACREAGE 2.90

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present

Not-Applicable

Window Panes Multi-Pane

Eave Vent Screen

no

Eaves Enclosed

photoID 130ValleyView_garage



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 89-1

APN 64190009000 Address 89 Wilson Road

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$140,000.00

ACREAGE 0.73

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes Single

Eave Vent Screen

Eaves unknown

photoID 24C78697-5105-425B-8D1F-29CD94878369.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 301-1

APN 64100031000 Address 301 Rimrock Dr

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$330,615.00

ACREAGE 1.77

Post Fire - Estimated Vegetation Clearance >100

Roof Construction unknown

Deck or Porch present Wood

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 53AB182A-0368-4B46-A6C8-A0AF65D20F5B.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 931-1

APN 64190003000 Address 931 Swall Meadows Rd
City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$161,508.00

ACREAGE 1.81

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible Deck or Porch present Wood
Window Panes unknown Eave Vent Screen
Eaves unknown

photoID 931SwallMeadow



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round Incident Number CA-BDU-1662
Record ID 255-1

APN 64100032000 Address 255 Rimrock Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$360,000.00

ACREAGE 1.84

Post Fire - Estimated Vegetation Clearance 60-100

Roof Construction unknown

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen yes

Eaves unknown

photoID 34C1A21C-54A5-41F7-8808-D86B81FBC95F.jpg



▲ç αçç ▲çî"çç ▲||↑çâαçç ▲çê!çç å~ç°▼▲γ

çăçç▼_çă@▲çâαçⁿ▲çă!çă@▲çă!çêa▲çâαçⁿ ▲çÉB

Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 97-1

APN 64100022000 Address 97 Valley View Road

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$177,602.00

ACREAGE 2.05

Post Fire - Estimated Vegetation Clearance 30-60

Roof Construction Non-Combustible Deck or Porch present unknown

Window Panes Multi-Pane Eave Vent Screen

Eaves unknown

photoID 7A089789-5580-4284-8563-E14369800901.jpg

Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 159-1

APN 64100017000 Address 159 Willow Road

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$249,566.00

ACREAGE 5.97

Post Fire - Estimated Vegetation Clearance 60-100

Roof Construction Non-Combustible Deck or Porch present unknown

Window Panes Multi-Pane Eave Vent Screen

Eaves unknown

photoID C5031042-FF0D-4AC5-A288-3390C8D1ECCD.jpg





Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round Incident Number CA-BDU-1662
Record ID 94-1

APN 64160003000 Address 94 Mountain View Rd
City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage Destroyed

Assessed Improvement Value \$132,721.00

ACREAGE 1.29

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction unknown

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID BE6C0F8F-D790-4DCB-A05D-B15F474D36F1.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 94-2

APN 64160003000 Address 94 Mountain View Rd
City CA CA Zip 93514

Structure Type Non-Inhabitable-Detached Garage

Damage Destroyed

Assessed Improvement Value \$132,721.00

ACREAGE 1.29

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction unknown

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID A59FB4EA-B891-48A1-A93C-CBC0B1CD3BE3.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round Incident Number CA-BDU-1662
Record ID 461-1

APN 64130007000 Address 461 Mountain View Rd
City CA CA Zip 93514

Structure Type Non-Inhabitable-Detached Garage Damage Destroyed

Assessed Improvement Value \$226,872.00 ACREAGE 1.21

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible Deck or Porch present Not-Applicable

Window Panes unknown Eave Vent Screen

Eaves unknown

photoID 7A3FE2AF-28E5-4432-B4C3-C48CA92CF38F.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 739-1

APN 64110008000 Address 739 Mountain View Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$271,190.00

ACREAGE 0.82

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 2A55721E-0343-474A-8462-EDF0DF98AE53.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 1-Sep

APN 64190008000 Address 11 Wilson Road

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$367,123.00

ACREAGE 1.53

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible Deck or Porch present Wood

Window Panes Multi-Pane Eave Vent Screen

Eaves unknown

photoID 581200EB-30EC-40EE-94C6-21D4BDA6640F.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round Incident Number CA-BDU-1662
Record ID 1-Nov

APN 64190008000 Address 9 Wilson Road
City CA CA Zip 93514

Damage Destroyed

Assessed Improvement Value \$367,123.00 ACREAGE 1.53

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible Deck or Porch present Wood

Window Panes unknown Eave Vent Screen

Eaves unknown

photoID A9F2328C-BE6F-4DB9-A41D-824CFBDFCFC1.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 519-1

APN 64100009000 Address 519 Willow Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$223,596.00

ACREAGE 7.88

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 11D30136-18D5-46C4-A2CD-D8BC83E67F76.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 519-3

APN 64100009000 Address 519 Willow Rd

City CA CA Zip 93514

Structure Type Non-Inhabitable-Barn

Damage Destroyed

Assessed Improvement Value \$223,596.00

ACREAGE 7.88

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 446EBE43-7BC3-45C1-8A95-2F7DEECA1B96.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 519-2

APN 64100009000 Address 519 Willow Rd

City CA CA Zip 93514

Structure Type Non-Inhabitable-Barn

Damage Destroyed

Assessed Improvement Value \$223,596.00

ACREAGE 7.88

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID

Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 2180

APN 911003 Address 2180 Old Sherwin Grade

City CA CA Zip 93514

Structure Type Non-Inhabitable-Shop

Damage Destroyed

Assessed Improvement Value \$1,476,466.00

ACREAGE 0.00

Post Fire - Estimated Vegetation Clearance unknown

Roof Construction unknown

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID Sherwinaerial.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 2164

APN 911005 Address 2164 Old Sherwin Grade

City Ca CA Zip 93514

Structure Type Outbuilding gt 10'X12'

Damage Destroyed

Assessed Improvement Value \$0.00

ACREAGE 0.00

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible Deck or Porch present

Window Panes Eave Vent Screen

Eaves

photoID oldsherwin_shed.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round Incident Number CA-BDU-1662
Record ID 1046

APN 64170004000 Address 1046 Swall Meadows Rd
City CA CA Zip 93514

Structure Type Non-Inhabitable-Detached Garage Damage Destroyed

Assessed Improvement Value \$260,000.00 ACREAGE 0.82

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible Deck or Porch present Not-Applicable

Window Panes unknown Eave Vent Screen

Eaves unknown

photoID 1046_swall_garage.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 1046

APN 64170004000 Address 1046 Swall Meadows Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$260,000.00

ACREAGE 0.82

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible Deck or Porch present unknown

Window Panes unknown Eave Vent Screen

Eaves unknown

photoID 1046swall_house



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round Incident Number CA-BDU-1662
Record ID 1046

APN 64170004000 Address 1046 Swall Meadows Rd

City CA CA Zip 93514

Structure Type Outbuilding gt 10'X12'

Damage Destroyed

Assessed Improvement Value \$260,000.00

ACREAGE 0.82

Post Fire - Estimated Vegetation Clearance unknown

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID

Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 507-1

APN 64100010000 Address 507 Willow Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$274,141.00

ACREAGE 7.49

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Combustible

Deck or Porch present Wood

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID DCAF5942-57A0-46AB-8014-50C33A787973.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 67-1

APN 64180001000 Address 67 N Valley View Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$457,562.00

ACREAGE 0.90

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 17670F54-3D3F-4783-925F-3FAA33C63B5B.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 346-2

APN 64100013000 Address 346 Valley View Road

City CA CA Zip 93514

Structure Type Non-Inhabitable-Detached Garage

Damage Destroyed

Assessed Improvement Value \$452,449.00

ACREAGE 10.26

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID {38978D65-7B6F-42F7-B9FD-2F59A3CFDE08}

Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 346-1

APN 64100013000 Address 346 Valley View Road

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$452,449.00

ACREAGE 10.26

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 40483FED-41F5-45D6-8311-672ACA3E3B36.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 75-1

APN 64180002000 Address 75 N Valley View Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage 10-25%

Assessed Improvement Value \$203,738.00

ACREAGE 0.90

Post Fire - Estimated Vegetation Clearance 30-60

Roof Construction Non-Combustible Deck or Porch present Wood

Window Panes Multi-Pane Eave Vent Screen

Eaves Enclosed

photoID 38480529-E358-4800-A633-739CD45C362F.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662

Record ID 59-2

APN 64100021000 Address 59 Valley View Road

City CA CA Zip 93514

Structure Type Non-Inhabitable-Shop

Damage Destroyed

Assessed Improvement Value \$250,561.00

ACREAGE 2.05

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 3897FC4A-B6AF-459D-9C8D-53113EB2D949.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 59-1

APN 64100021000 Address 59 Valley View Road

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$250,561.00

ACREAGE 2.05

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present

unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 5D60A232-B3A1-47BD-BA1A-4230E5ECED77.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round Incident Number CA-BDU-1662
Record ID 72-1

APN 64180011000 Address 72 N Valley View

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$469,988.00

ACREAGE 1.93

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 72NValleyView.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round Incident Number CA-BDU-1662
Record ID 460-1

APN 64200019000 Address 460 Rimrock Dr

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$218,342.00

ACREAGE 2.10

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible Deck or Porch present Wood

Window Panes unknown Eave Vent Screen

Eaves unknown

photoID 2EB76732-030F-4E3C-9F1E-493BD26A35A2.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round Incident Number CA-BDU-1662
Record ID 826-1

APN 64190006000 Address 826 Swall Meadows Rd
City CA CA Zip 93514

Damage Destroyed

Assessed Improvement Value \$295,419.00 ACREAGE 0.89

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible Deck or Porch present Wood

Window Panes unknown Eave Vent Screen

Eaves unknown photoID 826SwallMeadow



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 1450

APN 64130002000 Address 1450 Swall Meadows Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$206,872.00

ACREAGE 0.75

Post Fire - Estimated Vegetation Clearance 60-100

Roof Construction Non-Combustible

Deck or Porch present

unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 8E516925-5082-497A-9CBC-6BC6759A3366.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 153-1

APN 64110002000 Address 153 Foothill Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$295,000.00

ACREAGE 0.91

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present

Not-Applicable

Window Panes Multi-Pane

Eave Vent Screen

Eaves unknown

photoID 028F0C23-9127-4005-A718-41546C6CFC96.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 55-1

APN 64200002000 Address 55 Pinon Dr

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$215,109.00

ACREAGE 2.02

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present

Wood

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 55Pinon



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 45-1

APN 64190007000 Address 45 Pine Dr

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$135,980.00

ACREAGE 0.95

Post Fire - Estimated Vegetation Clearance unknown

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 45Pine



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round Incident Number CA-BDU-1662
Record ID 45-2

APN 64190007000 Address 45 Pine Dr

City CA CA Zip 93514

Structure Type Non-inhabitable-Detached Garage

Damage Destroyed

Assessed Improvement Value \$135,980.00

ACREAGE 0.95

Post Fire - Estimated Vegetation Clearance unknown

Roof Construction unknown

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID {E718B251-FA29-4900-AA71-080DC734BF87}

Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 370-2

APN 64200018000 Address 370 Rimrock

City CA CA Zip 93514

Structure Type Non-Inhabitable-Detached Garage

Damage Destroyed

Assessed Improvement Value \$500,000.00

ACREAGE 2.11

Post Fire - Estimated Vegetation Clearance 60-100

Roof Construction Combustible


Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photo 370rimrock_garage



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 370-1

APN 64200018000 Address 370 Rimrock Dr

City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage Destroyed

Assessed Improvement Value \$500,000.00

ACREAGE 2.11

Post Fire - Estimated Vegetation Clearance unknown

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 370RockRim



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 171-1

APN 64180010000 Address 171 Pine Dr

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$122,585.00

ACREAGE 2.00

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible Deck or Porch present unknown

Window Panes unknown Eave Vent Screen

Eaves unknown photoID 171Pine



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 320-2

APN 64150004000 Address 320 Mountain View Rd

City CA CA Zip 93514

Structure Type Non-Inhabitable-Detached Garage

Damage Destroyed

Assessed Improvement Value \$372,847.00

ACREAGE 1.29

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction unknown

Deck or Porch present

Not-Applicable

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 04629549-7250-4957-B161-12AFF6623202.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 320-1

APN 64150004000 Address 320 Mountain View Rd
City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage 10-25%

Assessed Improvement Value \$372,847.00

ACREAGE 1.29

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present Wood

Window Panes Multi-Pane

Eave Vent Screen

Eaves Enclosed

photoID 89611AE0-E730-4C8C-BDC3-0EB2F8EEBCBD.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 788-2

APN 64120018000 Address 788 Mountain View Rd
City CA CA Zip 93514

Structure Type Non-Inhabitable-Detached Garage

Damage Destroyed

Assessed Improvement Value \$435,468.00

ACREAGE 0.78

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present

Not-Applicable

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 6876F5BE-9758-4B9A-9D2D-70EB0E433804.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 788-1

APN 64120018000 Address 788 Mountain View Rd
City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage 10-25%

Assessed Improvement Value \$435,468.00

ACREAGE 0.78

Post Fire - Estimated Vegetation Clearance unknown

Roof Construction Non-Combustible

Deck or Porch present

Wood

Window Panes Multi-Pane

Eave Vent Screen

Eaves Enclosed

photoID 616328DF-0E7E-4A10-8420-9207CD5A33BF.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 370-3

APN 64200025000 Address 370 Rimrock

City CA CA Zip 93514

Structure Type Outbuilding gt 10'X12'

Damage Destroyed

Assessed Improvement Value \$0.00

ACREAGE 0.18

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 8C698FB8-2EF6-46C5-B778-3D251FE65DD6.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 193-1

APN 64110004000 Address 193 Foothill Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage 10-25%

Assessed Improvement Value \$160,261.00

ACREAGE 1.14

Post Fire - Estimated Vegetation Clearance 30-60

Roof Construction Non-Combustible

Deck or Porch present

Wood

Window Panes Single

Eave Vent Screen

Eaves Un-Enclosed

photoID 3A23D66F-F719-44D9-A49E-1F45C3E4B7BC.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 193-2

APN 64110004000 Address 193 Foothill Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$160,261.00

ACREAGE 1.14

Post Fire - Estimated Vegetation Clearance 30-60

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID A0817C7E-B585-4283-87B2-F31B3D12AE31.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 4866

APN 26380029000 Address 4866 Deer Peak TR

City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage Destroyed

Assessed Improvement Value \$244,665.00

ACREAGE 0.39

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID DeerPeak.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 280-1

APN 64200013000 Address 280 Pinon Dr

City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage Destroyed

Assessed Improvement Value \$310,735.00

ACREAGE 2.00

Post Fire - Estimated Vegetation Clearance 60-100

Roof Construction Non-Combustible

Deck or Porch present

Not-Applicable

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 280Pinon



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 818-1

APN 64120019000 Address 818 Mountain View Rd
City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage Destroyed

Assessed Improvement Value \$125,567.00

ACREAGE 0.99

Post Fire - Estimated Vegetation Clearance 30-60

Roof Construction Non-Combustible Deck or Porch present Wood

Window Panes Multi-Pane Eave Vent Screen

Eaves unknown

photoID B122DB2B-CA49-4614-A793-7676EC5B78FA.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 140-1

APN 64100016000 Address 140 Willow Road

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$331,956.00

ACREAGE 20.35

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present

Wood

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 3C47D8F4-3E0E-4917-81DA-B97B425A4539.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 1274

APN 64140006000 Address 1274 Swall Meadows Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$136,761.00

ACREAGE 0.81

Post Fire - Estimated Vegetation Clearance 60-100

Roof Construction unknown

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID F90CFAEB-95C9-4A1A-BE86-07A0B038E636.jpg



1

2

Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 1274

APN 64140006000 Address 1274 Swall Meadows Rd

City CA CA Zip 93514

Structure Type Mobile Home - Single Wide

Assessed Improvement Value \$136,761.00

Post Fire - Estimated Vegetation Clearance 60-100

Roof Construction Non-Combustible Deck or Porch present

Window Panes unknown Eave Vent Screen

Eaves unknown

Damage 10-25%

ACREAGE 0.81

Not-Applicable

photoID {D8CD009E-321B-4D53-AD7D-5EF16A8B53CA}

Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round Incident Number CA-BDU-1662
Record ID 175-1

APN 64110003000 Address 175 Foothill Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage Destroyed

Assessed Improvement Value \$136,474.00

ACREAGE 1.04

Post Fire - Estimated Vegetation Clearance 30-60

Roof Construction unknown

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 86FB36C6-DAF6-4469-8610-5F8D304AC700.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 175-2

APN 64110003000 Address 175 Foothill Dr

City CA CA Zip 93514

Structure Type Outbuilding gt 10'X12'

Damage Destroyed

Assessed Improvement Value \$136,474.00

ACREAGE 1.04

Post Fire - Estimated Vegetation Clearance 30-60

Roof Construction Non-Combustible Deck or Porch present

Not-Applicable

Window Panes Single

Eave Vent Screen

Eaves unknown

photoID D25F9B53-B9D2-4DB5-8BEB-F1A3111387D1.jpg



Individual Damage Inspection Detail

Report Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 105-1

APN 64100046000 Address 105 Sierra way

City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage Destroyed

Assessed Improvement Value \$337,311.00

ACREAGE 1.61

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible Deck or Porch present

Masonry

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 293FCDB7-40B6-4AE8-A4EE-1F51020E7EA1.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round Incident Number CA-BDU-1662
Record ID 1430

APN 64130004000 Address 1430 Swall Meadows Rd
City CA CA Zip 93514

Structure Type Non-Inhabitable-Detached Garage Damage Destroyed

Assessed Improvement Value \$326,077.00 ACREAGE 0.81

Post Fire - Estimated Vegetation Clearance 60-100

Roof Construction Non-Combustible Deck or Porch present Not-Applicable

Window Panes unknown Eave Vent Screen

Eaves unknown

photoID 1471B4C5-7774-4D2E-913A-8C4A979E11EF.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 1430

APN 64130004000 Address 1430 Swall Meadows Rd
City CA CA Zip 93514

Structure Type Single Family Residence-Multi Story

Damage Destroyed

Assessed Improvement Value \$326,077.00

ACREAGE 0.81

Post Fire - Estimated Vegetation Clearance 60-100

Roof Construction Non-Combustible

Deck or Porch present Wood

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID E2943329-E61F-40CE-B120-2A9D4F30DBE7.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 130-1

APN 64100057000 Address 130 Valley View Road
City CA CA Zip 93514

Structure Type Non-Inhabitable-Detached Garage

Damage 10-25%

Assessed Improvement Value \$698,500.00

ACREAGE 2.90

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible Deck or Porch present Not-Applicable

Window Panes Multi-Pane Eave Vent Screen no

Eaves Enclosed

photoID 130ValleyView_garage



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 89-1

APN 64190009000 Address 89 Wilson Road

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$140,000.00

ACREAGE 0.73

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible Deck or Porch present: unknown

Window Panes Single Eave Vent Screen

Eaves unknown

photoID 24C7B697-5105-425B-8D1F-29CD94B7B369.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 301-1

APN 64100031000 Address 301 Rimrock Dr

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$330,615.00

ACREAGE 1.77

Post Fire - Estimated Vegetation Clearance >100

Roof Construction unknown

Deck or Porch present Wood

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 53AB182A-0368-4B46-A6C8-A0AF65D20F5B.jpg



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 931-1

APN 64190003000 Address 931 Swall Meadows Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$161,508.00

ACREAGE 1.81

Post Fire - Estimated Vegetation Clearance 0-30

Roof Construction Non-Combustible

Deck or Porch present

Wood

Window Panes unknown

Eave Vent Screen

Eaves unknown

photoID 931SwallMeadow



Individual Damage Inspection Detail

Start Date 2/6/2015 Incident Name Round

Incident Number CA-BDU-1662
Record ID 255-1

APN 64100032000 Address 255 Rimrock Rd

City CA CA Zip 93514

Structure Type Single Family Residence-Single Story

Damage Destroyed

Assessed Improvement Value \$360,000.00

ACREAGE 1.84

Post Fire - Estimated Vegetation Clearance 60-100

Roof Construction unknown

Deck or Porch present unknown

Window Panes unknown

Eave Vent Screen yes

Eaves unknown

photoID 34C1A21C-54A5-41F7-8808-D86B81FBC95F.jpg



10.10 - Reporting Party Email Request

Seaver, Richard@CHP

From: Bruning, Richard@CALFIRE
Sent: Monday, February 09, 2015 3:52 PM
To: Seaver, Richard@CHP
Subject: RE: Fire Investigation Status Update

Thanks.
Send it ATTN: Brian Tominaga

Respectfully,

Richard Bruning

Fire Captain

CAL FIRE

San Bernardino Emergency Command Center
(909) 881-6916
(909) 881-6970 - fax
[REDACTED] cell
Richard.Bruning@fire.ca.gov

3800 N. Sierra Way
San Bernardino, CA. 92405

From: Seaver, Richard@CHP
Sent: Sunday, February 08, 2015 6:25 PM
To: Bruning, Richard@CALFIRE
Subject: RE: Fire Investigation Status Update

Rich,

It was good talking with you earlier. I have found the log that was used for the incident, and have made that a certified copy and attached for you. I have additional logs, but I will go through all of those to see what is attached and included in this log. As mentioned, I will come in tomorrow and start all of that around noon. I will send it all to you when I am done. If you have any questions, please free to ask.

Rich

Richard A. Seaver
Public Safety Dispatch Supervisor I
California Highway Patrol
Bishop Communications Center
469 S. Main St., Bishop CA 93514
760-872-5900
760-872-5909 (direct)
760-873-8940 (fax)
RSeaver@chp.ca.gov

From: Bruning, Richard@CALFIRE
Sent: Saturday, February 07, 2015 1:58 PM
To: Seaver, Richard@CHP
Cc: Wollum, Nissa@CHP
Subject: FW: Fire Investigation Status Update

Rich,
Can you assist us with the RP info.
Thank you.

Respectfully,

Richard Bruning

Fire Captain

CAL FIRE

San Bernardino Emergency Command Center
(909) 881-6916
(909) 881-6970 - fax
[REDACTED] - cell
Richard.Bruning@fire.ca.gov

From: Tominaga, Brian@CALFIRE
Sent: Saturday, February 07, 2015 1:07 PM
To: Bruning, Richard@CALFIRE
Subject: RE: Fire Investigation Status Update

Rich

Can we work on getting the 911 audio and RP phone numbers

FW: Fire Investigation Status Update

Bruning, Richard@CALFIRE

Sent: Saturday, February 07, 2015 2:15 PM

To: Tominaga, Brian@CALFIRE

From: Kevin Frew [mailto:kfrew@inyocounty.us]

Sent: Saturday, February 07, 2015 2:08 PM


To: Bruning, Richard@CALFIRE

Subject: RE: Fire Investigation Status Update

Capt Bruning,

Original Cellular E 911 call was received in ICSO Dispatch at 14:03:12 hrs

Caller: Perea, Don



Our case number is 15-02-021

-Kevin

Inyo County Sheriff Dispatch

From: Bruning, Richard@CALFIRE [mailto:Richard.Bruning@fire.ca.gov]

Sent: Saturday, February 07, 2015 1:53 PM

To: Kevin Frew

Subject: RE: Fire Investigation Status Update

Thank you

Respectfully,

Richard Bruning

Fire Captain

CAL FIRE

San Bernardino Emergency Command Center

(909) 881-6916

(909) 881-6970 - fax

Richard.Bruning@fire.ca.gov

From: Tominaga, Brian@CALFIRE

Sent: Saturday, February 07, 2015 1:07 PM

To: Bruning, Richard@CALFIRE

Subject: RE: Fire Investigation Status Update

Rich

Can we work on getting the 911 audio and RP phone numbers

10.11 - Federal Owens Valley
Command Center CAD Report

WildCAD Incident Card - Owens Valley Interagency Communication Center: OVCC 2015-106
"ROUND" Resource Order 02/06/2015 14:04:00 Order Number: CA-BDU-1662
Area 34C (Owens Valley (North))

Reporting Party: CHP TRANS KEN SANISLO 760-914-1606

Initial Report On Conditions:

FIRE AT BOTTOM OF SHERWIN GRADE

Initial Location: LOWER RC RD

Lat: 37°29'8.89", Lon: 118°36'45.01", T5S, R31E, NWSE Sec 30

Actual Location (02/06/2015 14:27):

Lat: 37°27'12.97", Lon: 118°35'3.47", T6S, R31E, NWSW Sec 4

Incident Notes:

PIO IS 909-881-6949 CAPT LIZ
UNIFIED COMMAND W/ USFS

Dispatcher: Vradenburg, Ila **Status:** Open

Job Codes:

Notified * **DISPATCH DO::** 2/6/2015 2:10:15 PM TW NOTIFIED DEB
Notified * **INTERAGENCY DO::** 2/6/2015 2:10:22 PM TW NOTIFIED CH1
Notified * **DISTRICT DO::** 2/6/2015 2:12:47 PM TW NOTIFIED BC31/DIV3
Notified * **LE OFFICER::** 2/6/2015 2:16:21 PM 4C1 REponding
Notified + **OTHER::** 2/6/2015 2:31:17 PM CH1 ADVISING 1700, D. JOHNSON, MATT JOHN
Notified * **ALL CALL (FIRE)::** 2/6/2015 2:31:40 PM TW SENT UPDATED ALL CALL

Web Comment:

PNJH7X (1502)

Incident Commander(s):

02/06/2015 1427 BC3514B Effective

Resource Details:

E-3132:

Responding at 2/6/2015 2:12:05 PM, On Scene at 2/6/2015 9:35:19 PM, Returning at 2/7/2015 8:47:52 AM, Released at 2/7/2015 10:37:56 AM

E-3141:

Responding at 2/6/2015 2:12:16 PM, On Scene at 2/6/2015 2:53:14 PM, Returning at 2/7/2015 8:47:52 AM, Released at 2/7/2015 9:49:51 AM

E-32:

Responding at 2/6/2015 2:08:29 PM, On Scene at 2/6/2015 2:23:30 PM, Returning at 2/7/2015 8:21:58 AM, Released at 2/7/2015 9:01:42 AM

E-3561:

Committed at 2/6/2015 2:53:36 PM, On Scene at 2/6/2015 11:01:44 PM

E-3564:

Committed at 2/6/2015 2:53:38 PM, On Scene at 2/6/2015 11:01:48 PM

PT-32:

Committed at 2/6/2015 2:11:44 PM, On Scene at 2/6/2015 2:24:39 PM, Returning at 2/7/2015 8:20:28 AM, Released at 2/7/2015 8:56:06 AM

DIV-4:

Committed at 2/6/2015 5:02:21 PM, On Scene at 2/6/2015 11:01:39 PM, Released at 2/7/2015 10:17:20 AM

BC-31:

Committed at 2/6/2015 2:09:43 PM, On Scene at 2/6/2015 11:01:49 PM, Returning at 2/7/2015 8:25:58 AM, Released at 2/7/2015 9:35:07 AM

BC-41:

Committed at 2/7/2015 5:20:55 AM, Responding at 2/7/2015 5:20:57 AM

4C1*:

Committed at 2/6/2015 2:11:35 PM, On Scene at 2/6/2015 2:15:39 PM, Returning at 2/6/2015 11:31:37 PM, Released at 2/6/2015 11:44:44 PM

4E4*:

Committed at 2/7/2015 5:50:16 AM, Responding at 2/7/2015 5:50:30 AM

4E5*:

Committed at 2/6/2015 2:11:39 PM, On Scene at 2/6/2015 2:16:54 PM, Returning at 2/6/2015 8:04:55 PM, Released at 2/6/2015 9:28:09 PM

1790:

Committed at 2/7/2015 4:51:21 AM, On Scene at 2/7/2015 7:59:45 AM

Entry Date/Time	From	To	Details
02/06/2015 14:09:33	TW	BC-31	NOTIFIED RESPONDING
02/06/2015 14:12:49	CAPT31	IV	CAPT31 AND ENGR31 RESPON
02/06/2015 14:15:40			WEST WINDS, SMOKE VISIBILITY ISSUES RR ROS, JUMPED ROAD
02/06/2015 14:16:47	4C1	IV	LOWER RC RD TOWARD 395 5 AC, HEAVY WIND
02/06/2015 14:17:21	RP	TW	SHAWNA RAY DELMAS- FIRE LOOKS LIKE IT JUMPED A RD
02/06/2015 14:19:14	4C1	TW	4E5 AND 4E4 WILL SHUT DOWN THE LOWER ROCK CREEK RD PER CHP
02/06/2015 14:19:37	4C1	IV	4E4 4E5 CONTROLLING LOWER RC RD
02/06/2015 14:20:41	ENGR31	TW	+ CAPT 31 ON SCENE
02/06/2015 14:23:56	IV	PT32	ABOVE OR BELOW PARADISE? - BELOW - LAT AND LONG?
02/06/2015 14:24:16	PT32	IV	DOWN POWER LINES ON RD
02/06/2015 14:25:08	PT32	TW	POSSIBLE ORGIN, POWERLINES ON THE GROUND, 37,27,12.9 X 118,35,03.6
02/06/2015 14:30:27	4E5	IV	STAGING AT LOWER RC RD ON TOP END
02/06/2015 14:35:11	CALFIRE	AK	CMD LOCAL 3, TONE 13 / TAC 3, TONE 16
02/06/2015 14:35:48	3B	TW	RESPONDING
02/06/2015 14:37:38	IV	LOG	E3132 AND E3141 COPY FREQS AND ARE 20 MIN OUT
02/06/2015 14:40:11	TW	1790	LANDLINE DISPATCH - AFIRM WHEN I GET CELL SERVICE
02/06/2015 14:41:37	AK	1790	ADVISED - WILL BE THERE WITHIN AN HOUR
02/06/2015 14:45:13	AK	LOG	LATE ENTRY FROM INITIAL REPORT: MULTIPLE CHP TRANSFERS AND PUBLIC REPORTS GIVEN AT TIME OF INITIAL CALL, INCLUDING: MARGARET CHAVES @ [REDACTED] 2ND REPORT ADVISING PARADISE/SWALL TURNOFF AND HWY 395, WEST SIDE)
02/06/2015 14:48:47	BC31	IV	UNITS COMING? - E3132 AND E3141 - HAVE THEM COME IN AT THE TOP OF LOWER RC RD AND TIE IN WITH CAPT 31
02/06/2015 14:48:53	DW	LOG	CHIEF 1 NOTIFIED LARRY PRIMSIH WHO IS ACTING FOR blm. CHEIF 1 WILL EMAIL MATT JOHNSON
02/06/2015 14:49:43	4C1	TW	I CANNOT GET THROUGH TO THE IC, I HAVE LOWER ROCK CREEK RD CLOSED AT THE TOP END, CAN YOU CONFIRM WITH CALFIRE THIS IS WHAT IS WANTED?
02/06/2015 14:50:27	TW	CALFIRE	RELAYED
02/06/2015 14:53:09	E3141	IV	IN CONTACT W CAPT31 AND WILL BE SWITCHING OVER SHORTLY
02/06/2015 14:58:27	1790	TW	HWY395 CLOSED-NEG
02/06/2015 14:58:44	INYOSO	TW	MANDATORY EVAC OF PARADISE
02/06/2015 14:59:48	IV	LOG	SCOTT BROWN CALLED FOR INFO GAVE HIM LAT AND LONG AND LOCATION
02/06/2015 15:01:43	4C1	IV	LET MONO 1 KNOW WE HAVE THE RD CLOSED AT UPPER END - ADV
02/06/2015 15:50:07	AK	CALFIRE	CURRENT CONDITIONS? - 12 ACRES WITH A 1 ACRE SPOT. PIO IS 909-881-6949 CAPT LIZ BUILD. DO YOU HAVE ANY DIVS?
02/06/2015 15:53:35	BC31	IV	ORDER AVAIL ENG AND WT'S WILL TAKE WT FROM ENGINEERING
02/06/2015 15:59:30	AK	BC31	ALL REQUESTS NEED TO GO THROUGH CALFIRE FROM THEIR DISPATCH TO OURS
02/06/2015 16:01:29	BC31	AK	COPY - UNKNOWN WHAT WE COULD BRING TOGETHER - COPY
02/06/2015 16:26:07	AK	LOG	DIV4, SUPT3, AVAIL FOR DIVS
02/06/2015 16:29:49	4C1	IV	HAVE 4E3 RESPOND TO LOWER RC RD AT THE UPPER END
02/06/2015 16:32:38	4C1	IV	CHANGE 4E3 TO SO - DONE
02/06/2015 16:37:32	MONO1	IV	DO YOU HAVE UNITS WITH A RD CLOSURE AND WHERE - YES LWER RC RD AND 395 AT THE TOP END
02/06/2015 16:39:06	AK	LOG	ARE YOU HANDLING THE SPOT @ SWALL, ARE YOU THE ORDERING POINT CURRENTLY? - AFFIRM, WE ARE ORDERING POINT, WE ARE HANDLING, SWALL IS BEING EVAC.

Entry Date/Time	From	To	Details
02/06/2015 16:41:40	AK	ALL CALL	ADVISED OF SPOT (DUPLICATE ON CA-OVCC-110, CLOSED)
02/06/2015 17:30:20	DIV3	RD	WILL MAKE CONTACT W/ MANNY ABOUT RELOAD BASE
02/06/2015 17:40:15	CALFIRE	AK	100 ACRES, SWALL AND PARADISE EVAC.
02/06/2015 17:41:11	AK	LOG	SENT ALL CALL UPDATE
02/06/2015 17:48:45	AK	CALFIRE	POTENTIAL FOR UNIFIED COMMAND SITUATION FOR MIGRATION ONTO OUR DPA?
02/06/2015 17:50:29	CALFIRE	AK	IT IS BUMPING FED LAND NOW AND THEY ARE TELLING ME THAT IT MAY BE GOING IN TO UNIFIED COMMAND
02/06/2015 18:02:49	CAL FIRE	RD	DAVE WHT CHEVY (NO PLAT) ALLOW TO GO THROUGH TO EVAC
02/06/2015 18:07:37	CH-1	IM	REQSTD TAC FOR THIS INCIDENT
02/06/2015 18:07:44	IM	CH-1	ADV CAL FIRE TAC 3
02/06/2015 18:31:41	RD	CAL FIRE	ADVISED OF P#
02/06/2015 18:40:26	DIV-3	IM	ADV RELOAD BASE PERS. SHOULD BE AVAILABLE TOMORROW IN THE AM. BASE WILL OPEN THEN. SOPS IS IN THE LOOP.
02/06/2015 19:11:41	RD	LOG	0-20 FILL W/ GALLOWAY AS RAMP (T)
02/06/2015 20:06:22	RD	CALFIRE	FAXED ORDERS TO BDU
02/06/2015 21:02:06	RD	LOG	CREATED NEW CODE PNJH7X (1502)
02/06/2015 21:39:03	RD	LOG	IN UNIFIED COMMAND @ 2100 HRS DIV-4 WILL FED IC
02/06/2015 22:20:18	4C1	IV	395 IS CLOSED SB AT TOMS PLACE
02/06/2015 23:01:31	IC	RD	ICP @ ADIM BUILDING OF THE LEFT
02/06/2015 23:34:52	4C1	RD	CLEAR 4E4 WILL BE IN VSTIGATION TOMORROW
02/07/2015 08:20:23	IV	LOG	PT32 AND 3B RELEASED AND RTQ
02/07/2015 08:26:09	CAPT-31	TW	+ ENGR31 R/Q
02/07/2015 08:34:56	MONTES	TW	BIH RELOAD BASE I/S AVAILABLE - HOURS OF OPS? - UNSURE WAITING FOR BRIEFING FROM DIV 3
02/07/2015 08:50:09	CAPT31	IV	+ENGR31 I/Q
02/07/2015 10:22:38	CH1	IV	MYSELF AND 1700 RETURNING FROM THE ROUND FIRE
02/07/2015 11:12:50	CALFIRE EX	KA	WE WENT OVER THE LIST THAT RICK SENT ME AND SHE WILL FIX ALL ITEMS AND SEND THEM BACK TO ME.
02/07/2015 13:35:42	TW	SOPS	BISHOP RELOAD BASE WILL BE CLOSING THIS EVENING

COMMAND:

CALFIRE BDU 3: RX - 151.2500 / TX - 159.4050 ADDED 2/6/2015 2:14:00 PM
 CALFIRE BDU 3: RX - 151.2500 / TX - 159.4050 TONE 13 CHANGED 2/6/2015 2:34:38 PM

TAC:

CALFIRE TAC 3: 151.175 / TONE 16 ADDED 2/6/2015 2:14:10 PM

VOR

11nm 279° BIH: BISHOP
 51nm 213° OAL: COALDALE
 53nm 050° FRA: FRIANT
 67nm 045° CZQ: CLOVIS (FR
 72nm 184° MVA: MINA

ATB

12nm 282° BIH: BISHOP AIR
 67nm 036° FAT: FRESNO AIR
 88nm 359° PTV: PORTERVILL
 93nm 096° Q22: COLUMBIA A
 108nm 132° MEV: MINDEN AIR

Helibase

42nm 319° 207: INDEPENDEN
 48nm 030° TRM: TRIMMER HE
 54nm 357° AMH: ASH MT HEL
 59nm 129° BRG: BRIDGEPORT
 62nm 090° CFL: CRANE FLAT

Initial Report On Conditions


Fuels: Acres: 10000 **W Speed:** **Dir:** **Slope:** **Aspect:**
Spread: **Complexity:** **Jurisdiction:**
Structures:
Initial Strategy: N/A

Fire Report Information

Fire #: RESP **SubUnit:** **SubUnit #:**
Acres: 0 **Size Class:** **Elevation:** 0 **Land Status:**
Contain: **Control:** **Out:**

10.12 - Lightning Map

Lightning - Display Map: INF



Legend

Lightning Summary

<ul style="list-style-type: none"> + Positive Lightning - Negative Lightning — States — Counties — Major Roads and Highways ■ Rivers and Lakes □ National Forests 	Positive Strikes	1
	Negative Strikes	0
	Total Strikes	1
	Period Covered	01/22/2015 01:00 PST 02/06/2015 15:59 PST
	First Strike	02/06/2015 15:22 PST Latitude 38:09:13 Longitude 120:06:54
	Last Strike	02/06/2015 15:22 PST Latitude 38:09:13 Longitude 120:06:54


The lightning data provided on this network is a proprietary product. It is purchased by the federal government and made available to specified users. The wildland fire management community, as represented by the Department of the Interior and Department of Agriculture, may use this data to aid in locating potential wildland fires, to aid in suppressing those fires, and to support research into wildland fires and wildland fire suppression. Participating users may not redistribute data provided, or derivative products from which this originally transmitted data can be readily recovered, without express written permission from the contractor. Organizations not having a working relationship with a federal government user are not authorized to receive this data. Organizations, including government agencies, may not use the data for any commercial purpose.



Wildland Fire Management Information
 U.S. Department of Interior
 Bureau of Land Management
 National Interagency Fire Center




Lightning - Display Map: Shannan view



WARNING - Due to the limited accuracy of the lightning data, this map is not to be used to make tactical fire suppression decisions.

Legend	Lightning Summary	
+ Positive Lightning	Positive Strikes	0
- Negative Lightning	Negative Strikes	0
— States	Total Strikes	0
— Counties	Period Covered	02/04/2015 00:00 PST 02/07/2015 23:59 PST
— Major Roads and Highways	First Strike	
Garden City Towns	Last Strike	
 National Forests		
Western Land Ownership		
 Indian Reservations		
 BLM		
 BOR		
 County		
 DOD		



The lightning data provided on this network is a proprietary product. It is purchased by the federal government and made available to specified users. The wildland fire management community, as represented by the Department of the Interior and Department of Agriculture, may use this data to aid in locating potential wildland fires, to aid in suppressing those fires, and to support research into wildland fires and wildland fire suppression. Participating users may not redistribute data provided, or derivative products from which this originally transmitted data can be readily recovered, without express written permission from the contractor. Organizations not having a working relationship with a federal government user are not authorized to receive this data. Organizations, including government agencies, may not use the data for any commercial purpose.



Wildland Fire Management Information
 U.S. Department of Interior
 Bureau of Land Management
 National Interagency Fire Center



10.13 - Inyo Sheriff CAD Report



INYO COUNTY SHERIFF'S DEPARTMENT

CAD INCIDENT REPORT

1502060023

02/07/2015

Location TALBOT RANCH AREA/				Cross Streets			City	
Incident Type BRUSH - BRUSH FIRE				Call Taker FREW, KEVIN			Dispatcher FREW, KEVIN	
Date 02/06/2015	Priority 1	Primary Unit PAUL12	Beat 200	Fire Zone	Area 201	Map	Sonrce W	
Caller Name PEREA, DON				Caller Address			Caller Phone [REDACTED]	
Dispositions Assisted Other Agency				Weapon		Alm Level	Case Number 15-02-021	
Vehicles				Associated Incidents				

Incident Times		Special Circumstances					
Received	14:03:12	Persons					
Created	14:05:23						
Dispatched	14:05:49						
En Route	14:06:29						
On Scene	14:16:46						
Closed							
Revd-Closed	N/A						

Unit Times	Officer	Dispatched	Enroute	On Scene	Clear	Disp-On Scuee	On Scene-Clear	Disp-Clear
PAUL12	Derr, Nathaniel	14:05:49	14:06:29	14:16:46	19:14:45	10:57	4:57:59	5:08:56
PAUL2	Howard, Brian	14:05:50	14:07:24	14:23:54	00:53:48	18:04	10:29:54	10:47:58
2164		14:06:43	14:06:43	14:31:26	15:36:11	24:43	1:04:45	1:29:28
SAM2	Carter, Donny	14:07:35	14:07:39	14:24:01	19:14:17	16:26	4:50:16	5:06:42
ADAM2	Hollowell, Jeff	14:14:25	14:14:40		19:59:43	N/A	N/A	5:45:18
ADAM1	Lutze, Bill	14:17:04	14:17:15	14:53:27	00:53:53	36:23	10:00:26	10:36:49
LINC3	Baldwin, Paul	14:36:51		14:36:55	20:03:45	00:04	5:26:50	5:26:54
PAUL19	Obayashi, Edward	14:40:15	14:40:28	14:59:09	18:35:23	18:54	3:36:14	3:55:08
SAM3	Bachman, Tim	15:05:24	15:05:26	15:13:17	18:11:10	07:53	2:57:53	3:05:46
BPVFD		15:13:43	15:21:49		12:18:33	N/A	N/A	N/A
PAUL17	Hoodman, Chris	15:15:24	15:15:30		19:14:49	N/A	N/A	3:59:25
IVFD		15:15:49	15:21:53		10:45:47	N/A	N/A	N/A
DAVID1	Johnston, Kelvin	15:19:34		15:19:36	19:14:30	00:02	3:54:54	3:54:56
LINC2	Pritchard, Eric	15:22:50		15:23:05	17:01:10	00:15	1:38:05	1:38:20
LPVFD		15:24:03	15:36:56		10:53:15	N/A	N/A	N/A
NORA4	Landaverde, Franklin	15:25:27		15:25:32	18:32:52	00:05	3:07:20	3:07:25
LINC1	Marsh, Andrew	15:50:04			18:54:38	N/A	N/A	3:04:34
PAUL11	Bradley, Reuben	17:59:30	21:45:58	22:42:40	23:21:47	4:43:10	39:07	5:22:17
PAUL34	Rogers, Steve	18:58:04	20:25:28	20:51:54	00:42:07	1:53:50	3:50:13	5:44:03
ADAM2	Hollowell, Jeff	20:05:41	20:06:00		20:07:05	N/A	N/A	01:24
ADAM2	Hollowell, Jeff	20:07:09		21:23:28	00:42:58	1:16:19	3:19:30	4:35:49
CHRLS3	Connolly, Chris	21:23:12	21:23:19	22:42:49	23:27:54	1:19:37	45:05	2:04:42
PAUL9	Walston, Chris	21:47:48	21:47:57	22:40:09	00:55:35	52:21	2:15:26	3:07:47
ADAM2	Hollowell, Jeff	06:48:36	06:48:44		10:52:03	N/A	N/A	4:03:27
2201		07:00:14	07:00:19		10:46:45	N/A	N/A	3:46:31
PAUL12	Derr, Nathaniel	07:56:25			13:02:22		N/A	5:05:57
PAUL12	Derr, Nathaniel	13:33:21					N/A	N/A

Incident Comments
 Cellular E911 Call:
 Lat:37.45339 Lon:-118.58365
 Service Class: WPH2 brush fire, lines down, talbot ranch on old sherwin rd, structures threatened, high winds

TIME	#	EVENT	BY
14:05:23	1	Incident initiated at Talbot Ranch Area/, Rndvly	K. Frew
14:05:23	2	Unverified location: Talbot Ranch Area/,	K. Frew
14:05:49	3	PAUL12 DISP. Talbot Ranch Area/, Rndvly	K. Frew
14:05:50	4	PAUL2 DISP. Talbot Ranch Area/, Rndvly	K. Frew
14:06:29	5	PAUL12 ENRT.	K. Frew
14:06:43	6	2164 ENRT. Talbot Ranch Area/, Rndvly	K. Frew
14:07:24	7	PAUL2 ENRT.	K. Frew
14:07:35	8	SAM2 DISP. Talbot Ranch Area/, Rndvly	K. Frew
14:07:39	9	SAM2 ENRT.	K. Frew
14:12:22	10	mono county requesting paradise volunteers for mutual aid	K. Frew
14:13:00	11	cal fire sending BC, dozer, 2 eng, crew	K. Frew
14:13:19	12	bvfd responding	K. Frew
14:14:25	13	ADAM2 DISP. Talbot Ranch Area/, Rndvly	K. Frew
14:14:40	14	ADAM2 ENRT.	K. Frew
14:15:15	15	w wind, 5 acre, rapid spread, several structures threatened	K. Frew
14:15:46	16	visibility is an issue on 395	K. Frew
14:16:06	17	fire has jumped 395	K. Frew
14:16:22	18	winds at 10mph, gusts of 30-40 mph	K. Frew
14:16:46	19	PAUL12 10-97.	K. Frew
14:16:46	20	neg paradise evac at this time	K. Frew
14:17:04	21	ADAM1 DISP. Talbot Ranch Area/, Rndvly	K. Frew
14:17:15	22	ADAM1 ENRT.	K. Frew
14:18:12	23	sam 2 req paul15 early	K. Frew
14:19:01	24	paul12 checking residence down dirt d/w	K. Frew
14:23:54	25	PAUL2 10-97.	K. Frew
14:23:56	26	visibility on 395 manageable at this time	K. Frew
14:24:01	27	SAM2 10-97.	K. Frew
14:29:04	28	chp reqstd for traffic control on lwr rck crk rd at gorge rd	K. Frew
14:31:26	29	2164 10-97.	K. Frew
14:31:31	30	2164 10-6.	K. Frew
14:32:15	31	PAUL12 10-6.	K. Frew
14:32:18	32	SAM2 10-6.	K. Frew
14:32:46	33	PAUL2 10-6.	K. Frew
14:34:26	34	eng 32, patrol 32	K. Frew
14:34:56	35	are 97	K. Frew
14:36:51	36	LINC3 DISP. Talbot Ranch Area/, Rndvly	K. Frew
14:36:55	37	LINC3 10-97.	K. Frew
14:38:27	38	LINC3 10-6.	K. Frew
14:40:15	39	PAUL19 DISP. Talbot Ranch Area/, Rndvly	K. Frew
14:40:28	40	PAUL19 ENRT.	K. Frew
14:40:51	41	closures rqstd to road dept	K. Frew
14:46:03	42	SAM2 10-6. N END PARADISE	K. Frew
14:46:25	43	forestry has n end closed	K. Frew
14:48:40	44	mono s.o. enrt to paradise	K. Frew
14:49:04	45	paul2 at conty line, fire jumped twrd disposal ctr	K. Frew
14:49:05	46	North shift of fire to disposal site into Mnno Co.	K. Frew
14:49:34	47	LPG tank in Waste transfer site	K. Frew
14:53:27	48	ADAM1 10-97.	K. Frew
14:54:45	49	evac started for paradise	K. Frew
14:55:17	50	several units from meso enrt	K. Frew
14:56:44	51	Paul11 change to North per Sam3.	K. Frew
14:58:26	52	ADAM2 ENRT. PARADISE	K. Frew
14:59:09	53	PAUL19 10-97.	K. Frew
15:00:10	54	PAUL19 ENRT. PARADISE	K. Frew
15:00:10	55	CHP to assit with evac on Westridge Rd	K. Frew
15:00:24	56	PAUL12 10-6. PARADISE EVAC	K. Frew
15:00:55	57	icso x 7 working paradise evac	K. Frew


TIME	#	EVENT	BY
15:05:24	1	SAM3 DISP. Talbot Ranch Area/, Rndvly	K. Frew
15:05:26	2	SAM3 ENRT.	K. Frew
15:05:35	3	MSCO to call adam2 asap	K. Frew
15:09:18	4	adam2, sam3, adam1 comming in from Toms to evac paradise	K. Frew
15:11:28	5	Sam2 starting evac Westridge Rd at paradise Rd	K. Frew
15:13:17	6	SAM3 10-97. AREA	K. Frew
15:13:35	7	bpvfd dispatched for mutual aid	K. Frew
15:13:43	8	BPVFD DISP. Talbot Ranch Area/, Rndvly	K. Frew
15:14:09	9	bpvfd paged	K. Frew
15:15:24	10	PAUL17 DISP. Talbot Ranch Area/, Rndvly	K. Frew
15:15:30	11	PAUL17 ENRT.	K. Frew
15:15:49	12	IVFD DISP. Talbot Ranch Area/, Rndvly	K. Frew
15:16:24	13	2201 is 10-8	K. Frew
15:19:34	14	DAVID1 DISP. Talbot Ranch Area/, Rndvly	K. Frew
15:19:36	15	DAVID1 10-97.	K. Frew
15:20:07	16	ADAM2 10-6. PARADISE FIRE DEPT	K. Frew
15:21:49	17	BPVFD ENRT.	K. Frew
15:21:53	18	IVFD ENRT.	K. Frew
15:22:50	19	LINC2 DISP. Talbot Ranch Area/, Rndvly	K. Frew
15:23:05	20	LINC2 10-97. WITH LINC 3	K. Frew
15:24:03	21	LPVFD DISP. Talbot Ranch Area/, Rndvly	K. Frew
15:24:16	22	DAVID1 10-6.	K. Frew
15:24:59	23	PAUL17 ENRT. PARADISE FIRE STATION	K. Frew
15:25:05	24	SAM3 10-6.	K. Frew
15:25:27	25	NORA4 DISP. Talbot Ranch Area/, Rndvly	K. Frew
15:25:32	26	NORA4 10-97.	K. Frew
15:26:05	27	NORA4 ENRT. PARADISE FIRE STATION	K. Frew
15:27:20	28	BPVFD ENRT. 1 STRUCTURE. 1 TENDER	K. Frew
15:27:44	29	mono phone lines down, inyo taking 911 calls	K. Frew
15:32:40	30	call sign for mutual aid	K. Frew
	31	bpvfd engine 2312 tender 2313	
	32	ivfd engine 2215	
	33	lpvfd 2430	
15:36:02	34	PAUL17 10-6.	K. Frew
15:36:11	35	2164 10-8.	K. Frew
15:36:22	36	ADAM1 10-6.	K. Frew
15:36:36	37	LINC2 10-6.	K. Frew
15:36:44	38	PAUL19 10-97.	K. Frew
15:36:50	39	PAUL19 10-6.	K. Frew
15:36:56	40	LPVFD ENRT.	K. Frew
15:41:58	41	SAM2 10-6. FOR FUEL	K. Frew
15:42:28	42	lp tender dispatched	K. Frew
15:50:04	43	LINC1 DISP. Talbot Ranch Area/, Rndvly	K. Frew
15:50:16	44	LINC1 10-6. LATE ENTRY	K. Frew
15:56:24	45	Fire approaching residences with LPG tanks	K. Frew
	46	Parties refusing to leave	
16:01:32	47	Swall Meadows to be evac	K. Frew
16:01:58	48	All units to clear out of the lower end of the fire.	K. Frew
16:10:25	49	code red message sent	K. Frew
16:10:48	50	code red for swall meadows evacuation	K. Frew
16:16:46	51	Confirmed mandatory evac swall meadows.	K. Frew
16:20:48	52	PAUL19 TSPRT. 1 X TO ROCK CREEK RD 719	K. Frew
16:21:05	53	PAUL2 ENRT. SWALL MEADOWS	K. Frew
16:27:24	54	PAUL2 10-6.	K. Frew
16:30:40	55	Per Paul17 refusal to leave 101 Mountain View Swall Vaughan Res	K. Frew
16:32:27	56	IVFD 2215 on scene	K. Frew
16:43:41	57	per paul 17: refusal to leave 87 Mtn View	K. Frew

TIME	#	EVENT	BY
16:44:35	1	per paul 17 group of people on back road Swall Meadows attempting to return	K. Frew
16:45:13	2	NORA4 10-6.	K. Frew
16:48:06	3	PAUL19 10-6.	K. Frew
16:48:18	4	per chp 59 valley view refusing to evac	K. Frew
17:00:58	5	sam 2 reqst all patrol units 98 on pine crk rd	K. Frew
17:01:10	6	LINC2 10-8.	K. Frew
17:32:57	7	13-39 paul10	K. Frew
17:33:06	8	message left for paul18	K. Frew
17:59:30	9	PAUL11 DISP. Talbot Ranch Area/, Rndvly	K. Frew
17:59:37	10	PAUL11 10-6.	K. Frew
18:07:35	11	PAUL2 10-6. BIRCHIM RD	K. Frew
18:07:41	12	PAUL17 10-6. N RV RD & BIRCHIM LANE	K. Frew
18:07:48	13	SAM2 10-6. BIRCHIM	K. Frew
18:07:56	14	PAUL11 10-6. BIRCHIM	K. Frew
18:08:03	15	PAUL19 10-6. N RV RD & BIRCHIM	K. Frew
18:11:10	16	SAM3 10-8.	K. Frew
18:14:38	17	Linc1 request reserves to respond for security purposes	K. Frew
18:19:34	18	ADAM2 ENRT. FUEL	K. Frew
18:32:52	19	NORA4 10-8.	K. Frew
18:35:23	20	PAUL19 10-8.	K. Frew
18:38:16	21	ADAM2 10-6.	K. Frew
18:54:38	22	LINC1 10-8.	K. Frew
18:57:04	23	paul34	K. Frew
18:58:04	24	PAUL34 DISP. Talbot Ranch Area/, Rndvly	K. Frew
19:14:17	25	SAM2 10-8.	K. Frew
19:14:30	26	DAVID1 10-8.	K. Frew
19:14:45	27	PAUL12 10-8.	K. Frew
19:14:49	28	PAUL17 10-8.	K. Frew
19:59:43	29	ADAM2 10-8.	M. Marsh
20:03:45	30	LINC3 10-8.	M. Marsh
20:05:41	31	ADAM2 DISP. Talbot Ranch Area/, Rndvly	M. Marsh
20:06:00	32	ADAM2 ENRT. N RV AND BIRCHIM LANE	M. Marsh
20:07:05	33	ADAM2 10-8. Freed	K. Frew
20:07:09	34	ADAM2 DISP. Talbot Ranch Area/, Rndvly	K. Frew
20:07:12	35	ADAM2 10-6.	K. Frew
20:25:28	36	PAUL34 ENRT.	M. Marsh
20:51:54	37	PAUL34 10-97. BIRCHIM & N RV RD	M. Marsh
20:58:55	38	salvation army in bishop opening for shelter, food, beverage, etc	K. Frew
21:22:58	39	need coderd for Rock Creek Lake area & Lodge,	M. Marsh
21:23:08	40	PAUL2 ENRT. ROCK CREEK	M. Marsh
21:23:12	41	CHRLS3 DISP. Talbot Ranch Area/, Rndvly	M. Marsh
21:23:19	42	CHRLS3 ENRT. ROCK CREEK	M. Marsh
21:23:28	43	ADAM2 10-97. ROCK CREEK	M. Marsh
21:40:08	44	CODE RED ISSUED FOR ROCK CREEK AREA	M. Marsh
21:45:06	45	ADAM1 ENRT. ROCK CREEK	M. Marsh
21:45:58	46	PAUL11 ENRT. ROCK CREEK FOR EVAC NOTICE	M. Marsh
21:46:55	47	CHRLS3 10-6. TOMS PLACE	K. Frew
21:47:22	48	PAUL11 ENRT. RCK CRK LODGE	K. Frew
21:47:47	49	PAUL2 ENRT. RCK CRK LODGE	K. Frew
21:47:48	50	PAUL9 DISP. Talbot Ranch Area/, Rndvly	M. Marsh
21:47:57	51	PAUL9 ENRT. ROUND VALLEY	M. Marsh
21:50:34	52	code red for rock creek unsuccessful	K. Frew
21:56:16	53	Mono County issuing Code Red evac advisory for Sunny Slopes	K. Frew
22:03:20	54	Chp closing 395: SB at Toms Place, NB at Gorge Rd	K. Frew
22:23:48	55	PAUL11 10-6.	K. Frew
22:23:51	56	PAUL2 10-6.	K. Frew
22:23:59	57	ADAM1 10-6.	K. Frew

TIME	#	EVENT	BY
22:40:09	1	PAUL9 10-97.	M. Marsh
22:42:40	2	PAUL11 10-97. TOM'S PLACE	M. Marsh
22:42:49	3	CHRLS3 10-97. TOM'S PLACE	M. Marsh
23:21:47	4	PAUL11 10-8.	M. Marsh
23:22:12	5	PAUL2 ENRT. BIRCHIM & ROUND VALLEY RD	M. Marsh
23:27:54	6	CHRLS3 10-8.	M. Marsh
[02/07/2015]			
00:26:03	7	Hwy 395 is open	M. Marsh
00:42:07	8	PAUL34 10-8.	M. Marsh
00:42:58	9	ADAM2 10-8.	M. Marsh
00:53:48	10	PAUL2 10-8. . Disposition AO	M. Marsh
00:53:53	11	ADAM1 10-8. . Disposition AO	M. Marsh
00:55:35	12	PAUL9 10-8. . Disposition AO	M. Marsh
05:51:42	13	BPVFD 10-6.	K. Frew
05:51:44	14	IVFD 10-6.	K. Frew
05:51:48	15	LPVFD 10-6.	K. Frew
06:48:36	16	ADAM2 DISP. Talbot Ranch Area/, Rndvly	K. Frew
06:48:44	17	ADAM2 ENRT. CAMP 26	K. Frew
06:49:23	18	ADAM2 10-6. CAMP 26	K. Frew
07:00:14	19	2201 DISP. Talbot Ranch Area/, Rndvly	K. Frew
07:00:19	20	2201 ENRT.	K. Frew
07:56:25	21	PAUL12 DISP. Talbot Ranch Area/, Rndvly	K. Frew
07:56:33	22	PAUL12 10-6.	K. Frew
08:53:12	23	PAUL12 Case number 15-02-021 assigned to 1502060023	K. Frew
08:54:51	24	ADAM2 10-6. SWALL MEADOWS	K. Frew
09:04:24	25	IVFD RETURN.	K. Frew
09:04:32	26	2201 10-6.	K. Frew
09:08:05	27	LPVFD RETURN.	K. Frew
10:24:57	28	LPVFD 10-6. STATION	K. Frew
10:45:47	29	IVFD 10-8. . Disposition AO	K. Frew
10:46:45	30	2201 10-8. . Disposition AO	K. Frew
10:52:03	31	ADAM2 10-8. . Disposition AO	K. Frew
10:53:15	32	LPVFD 10-8. . Disposition AO	K. Frew
11:10:40	33	BPVFD RETURN.	K. Frew
12:18:33	34	BPVFD 10-8. . Disposition AO	K. Frew
13:02:22	35	PAUL12 10-8. Freed	K. Frew
13:02:22	36	PAUL12 Incident returned to pending status	K. Frew
13:33:21	37	PAUL12 DISP. Talbot Ranch Area/, Rndvly	K. Frew
13:33:30	38	PAUL12 10-6. FOLLOW UP	K. Frew

10.14 - Origin Diagram

SKETCH #1




SKETCH LEGEND

- ⊕ = Power Pole
- ↔ #1 = DISTANCE APPROXIMATELY 64 FEET.
- ↔ #2 = LENGTH APPROXIMATELY 70 FEET.
- ↔ #3 = DISTANCE APPROXIMATELY 73 FEET.

NOT TO SCALE

CREATED BY: FCS KELLY GALLAGHER
#2712
2-12-2015



SKETCH LEGEND

- A** : ADVANCING BURN INDICATOR
- ∧** = LATERAL BURN INDICATOR
- U** = BACKING BURN INDICATOR
- ⊘** = EDISON POLE

NOT TO SCALE

CREATED BY: FCS KELLY GAUANEER #8712 2-12-2005

POLE # 1854107E



10.15 - Witness Written Statement PEREA

INYO COUNTY SHERIFF

WRITTEN STATEMENT

C/I No. A0786932

Page No. 1

Perea, Donald Wayne

Last Name - First - Middle

Residence Address

Res. Phone

Occupation

Race

Sex

Age

D.O.B

Business/School Address

Bus. Phone

At approximately 1:30 pm I was eating lunch when an extremely large gust of wind rattled the house. I went outside and tied down the spa and patio furniture. Then at approximately 1:45 another heavy gust of wind shook the house and I saw a bright flash down in the middle of the field. The power then went out and the pasture where I saw the bright flash erupted into flames. The pasture is located between the Talbot house and Schober house. I tried to call 911 on my cell phone but it wouldn't go through. I then jumped in the truck and drove to the Schober house to warn them of the fire. I searched the house and no one was there. I tried to call 911 again and it went through - this was at 2:02 pm. By that time, all the trees between the two ranches were fully engulfed.

Signature

Donald Perea

Date

in flames and the fire had already jumped the road. I drove back to the Talbot Ranch and started setting up pumps to protect our house.

Donald Terea
Signature

2/10/2015
Date

10.16 - Origin Video



ATTACHMENT 16

ORIGN VIDEO

10.17 - CHP Incident Report

Incident Detail Report

Data Source: **Data Warehouse**
 Incident Status: **Closed**
 Incident number: **150206BI00071**
 Incident Date: **2/6/2015 14:02:10**
 Last Updated: **2/8/2015 17:51:03**

Incident Information

Incident Type:	CHP No Response	Alarm Level:	
Priority:	7	Problem:	CLOSURE of a Road
Determinant:		Agency:	CHP
Base Response#:	02062015-0000720	Jurisdiction:	BI
Confirmation#:		Division:	72-Bishop
Taken By:	Douglas V Elliott	Battalion:	72-Bishop
Response Area:	72-40	Response Plan:	
Disposition:	DUP-Duplicate Call	Command Ch:	
Cancel Reason:	UX-Cancel	Primary TAC:	
Incident Status:	Closed	Secondary TAC:	
Certification:		Delay Reason (if any):	
Longitude:	118592998	Latitude:	37462964

Incident Location

Location Name:		County:	Inyo
Address:	0 Lower Rock Creek Rd	Location Type:	
Apartment:		Cross Street:	Old Sherwin Grade Rd/Boundary Rd
Building:		Map Reference:	
City, State, Zip:	Unincorporated CA 93514		

Supplemental Information - Person

PERSON 1
Phone: [REDACTED]

PERSON 2
Phone: [REDACTED]

PERSON 3
Phone: [REDACTED]

PERSON 4
Phone: [REDACTED]

PERSON 5
Phone: [REDACTED]

PERSON 6
Phone: [REDACTED]

PERSON 7
Name: JIM Phone: [REDACTED]

PERSON 8
Name: RANCH DON CHANCE Phone: [REDACTED]

PERSON 9
Name: TODD KAREN - Passing Motorist Phone: [REDACTED]

PERSON 10
Phone: [REDACTED]

PERSON 11
Name: SHARON - Passing Motorist Phone: [REDACTED]

PERSON 12
Name: ROBERT - Witness Phone: [REDACTED]

I declare under penalty of perjury, that the document consisting of 21 pages to which this is affixed is (are) a true copy(s) of the original document(s) on file with the Department of California Highway Patrol.

RAB By RICHARD A. SCARVER
Employee
Title PSDS I

Call Receipt

Caller Name:	KEN	Call Back Phone:	[REDACTED]
Method Received:		Caller Location:	[REDACTED]
Caller Type:	Passing Motorist		

Time Stamps

Elapsed Times

Description	Date	Time	User	Description	Time
Phone Pickup	2/6/2015	14:02:08			
1st Key Stroke	2/6/2015	14:02:08			
In Waiting Queue	2/8/2015	15:22:08		Received to In Queue	00:01:25
Call Taking Complete	2/6/2015	14:07:14	Douglas V Elliott	Call Taking	00:05:04
1st Unit Assigned	2/6/2015	14:04:38		In Queue to 1st Assign	00:01:03
1st Unit Enroute	2/6/2015	14:06:30		Call Received to 1st Assign	00:02:30
1st Unit Arrived	2/6/2015	14:12:55		Assigned to 1st Enroute	00:01:52
Closed	2/8/2015	15:22:17	Jolene Hopper	Enroute to 1st Arrived	00:06:25
				Incident Duration	

Resources Assigned

Unit	Assigned	Disposition	Enroute	Staged	Arrived	At Patient	Delay Avail	Complete	Odm. Enroute	Odm. Arrived	Cancel Reason
A72-011	14:04:38				14:13:00			19:05:41			
A72-001	14:06:30		14:06:30		14:12:55			18:37:58			
71-S1	14:16:02	RU-Reassign Unit or Incident	14:16:02		14:46:50			17:37:55			RU-Reassign Unit
72-S2	14:26:43		14:26:43		14:42:28			02:43:17			
B72-004	15:00:46		15:00:47		15:06:24			18:43:43			
72-C	15:19:08		15:19:08		15:36:13			18:39:42			
A72-003	15:24:38				15:24:38			19:04:43			
71-052	15:30:21				15:30:21			17:04:27			
C72-001	17:20:46		17:20:46		17:20:46			05:24:26			
71-S1	17:52:27		17:52:27		18:41:38			21:29:05			
C72-003	17:56:23		21:03:07		21:03:10			06:27:38			
C72-011	18:29:26		18:29:26					06:16:08			
C72-009	18:29:43		18:29:43					00:06:36			
B72-004	20:57:57							00:40:27			
71-051	21:03:14				21:03:14			21:35:32			
71-052	21:45:20							23:36:12			
72-C	22:53:37	RU-Reassign Unit or Incident						22:54:11			RU-Reassign Unit
72-C	22:54:14							00:22:47			
C72-009	02:23:22		02:23:23		02:23:23			05:35:08			
72-S2	02:56:38		02:56:38		02:56:38			04:20:26			
A72-001	06:14:08							18:03:53			
A72-011	06:15:51							19:04:40			
72-S3	06:41:13							08:49:58			
A72-003	06:42:23							18:51:22			
72-S2	11:53:42							15:44:14			
C72-011	18:20:15							19:19:00			
B72-004	18:26:41							19:19:35			
C72-009	18:29:56							06:18:12			
C72-011	19:19:40							06:28:56			
A72-003	06:01:48	RU-Reassign Unit or Incident						13:38:14			RU-Reassign Unit
72-S2	06:18:24							07:41:06			
A72-001	06:27:00	RU-Reassign Unit or Incident						13:13:31			RU-Reassign Unit

B72- 13:13:31 RU-Reassign 13:13:37 13:39:09 RU-Reassign Unit
 004 Unit or
 Incident

Personnel Assigned

Unit	Name
A72-011	Justin Rader (020444)
A72-001	Gregory P Bryant (018441) - Officer
71-S1	Michael J O'sullivan (011455) - Sergeant
72-S2	Phillip S Howlett (013464) - Sergeant
B72-004	Matthew J Nibert (020810)
A72-003	Eric W Lanphear (018960) - Officer
71-052	Carina L Baldrige (019766) - Officer
C72-001	Adam H Otten (018925) - Officer
71-S1	Michael J O'sullivan (011455) - Sergeant
B72-004	Matthew J Nibert (020810)
71-051	Joshua N Johnson (019763) - Officer
71-052	Carina L Baldrige (019766) - Officer
C72-009	David J Owen Jr (020090) - Officer
72-S2	Phillip S Howlett (013464) - Sergeant
A72-001	Eric W Lanphear (018960) - Officer
A72-011	Gregory P Bryant (018441) - Officer
72-S3	Dale R Gordon (015844) - Officer
A72-003	Justin Rader (020444)
72-S2	Phillip S Howlett (013464) - Sergeant
B72-004	Matthew J Nibert (020810)
C72-009	David J Owen Jr (020090) - Officer
C72-011	Michael A Sweet (020183) - Officer
A72-003	Gregory P Bryant (018441) - Officer
A72-001	Eric W Lanphear (018960) - Officer
B72-004	Matthew J Nibert (020810)

Pre-Scheduled Information**No Pre-Scheduled Information****Transports****No Transports Information****Transport Legs****No Transports Information****Comments**

Date	Time	User	Type	Conf.	Comments
2/6/2015	12:55:00	A11053	Response		[31] [Appended, 14:07:49] [1] MM 24
2/6/2015	12:55:14	A11053	Response		[32] [Appended, 14:07:49] [2] POWER LINE ARCHIG
2/6/2015	12:56:36	A11053	Response		[33] [Appended, 14:07:49] [3] ON RS
2/6/2015	12:57:26	A11053	Response		[34] [Appended, 14:07:49] [4] 1039 MCSO FOR FD
2/6/2015	13:03:29	A11053	Response		[35] [Appended, 14:07:49] [5] 71-S1 COPIES
2/6/2015	13:07:29	A11053	Response		[36] [Appended, 14:07:49] [6] 71-S1 1097 AREA
2/6/2015	13:12:34	A11053	Response		[37] [Appended, 14:07:49] [7] 71-S1 NEG POLES DOWN OR FIRE - UTL
2/6/2015	13:12:39	A11053	Response		[38] [Appended, 14:07:49] [8] 1039 INTER AGENCY
2/6/2015	13:12:56	A11053	Response		[39] [Appended, 14:07:49] [9] 1039 MCSO FOR FD
2/6/2015	13:17:08	A15999	Response		[40] [Appended, 14:07:49] [10] Incident Re-opened:
2/6/2015	13:18:26	A11053	Response		[41] [Appended, 14:07:49] [11] MCSO ADVS FD IS 1097 AND GETTING POLE INFO
2/6/2015	13:18:37	A11053	Response		[42] [Appended, 14:07:49] [12] MCSO WILL ADVS IF CHP IS NEEDED
2/6/2015	13:22:50	A15999	Response		[43] [Appended, 14:07:49] [13] [Notification] [CHP]-Problem changed from 1125-Traffic Hazard to FIRE-Report of Fire by CHP
2/6/2015	14:02:20	SYS	Response		[14] [Appended, 14:07:34] [1] A wireless rebid occurred. A possible phase 2 update is available.
2/6/2015	14:02:22	A15999	Response		[15] [Appended, 14:07:34] [2] FIRE STARTED AT SCHOBBER RANCH
2/6/2015	14:02:25	A15999	Response		[16] [Appended, 14:07:34] [3] POSS POWER LINE
2/6/2015	14:02:55	A15999	Response		[17] [Appended, 14:07:34] [4] FIRE W/IN 20 FEET OF SCHOBBER HOUSE
2/6/2015	14:02:59	SYS	Response		[1] A wireless rebid occurred. A possible phase 2 update is available.
2/6/2015	14:03:00	A15999	Response		[18] [Appended, 14:07:34] [5] CONF ICISO
2/6/2015	14:03:01	A15999	Response		[19] [Appended, 14:07:34] [6] FOR FIRE
2/6/2015	14:03:22	A11053	Response		[2] JWO US395

2/6/2015	14:03:24	A15999	Response		[20] [Appended, 14:07:34] [7] PER RP IN INYO COUNYT
2/6/2015	14:03:28	A11053	Response		{3} BRUSH FIRE
2/6/2015	14:03:53	A11053	Response		{4} CONF W/INTER AGENCY
2/6/2015	14:04:06	A15999	Response		{5} Duplicate call appended to incident at 14:04:06
2/6/2015	14:04:32	A15127	Response		{6} 72-1 COPIES F/ 168 / RIATA
2/6/2015	14:04:48	A15127	Response		{7} Duplicate call appended to incident at 14:04:48
2/6/2015	14:04:51	SYS	Response		[21] [Appended, 14:07:34] [13] [Appended, 14:06:38] A wireless rebid occurred. A possible phase 2 update is available.
2/6/2015	14:04:57	A15999	Response		{8} CONF INTERAGENCY
2/6/2015	14:05:24	A15127	Response		[22] [Appended, 14:07:34] [8] Duplicate call appended to incident at 14:05:24
2/6/2015	14:05:36	A15999	Response		[23] [Appended, 14:07:34] [9] 71-S1 COPIES
2/6/2015	14:05:38	SYS	Response		[24] [Appended, 14:07:34] [10] A wireless rebid occurred. A possible phase 2 update is available.
2/6/2015	14:05:49	A15127	Response		[25] [Appended, 14:07:34] [11] PER DUPE BOTTOM OF SHERWIN CONF TO INTERAGENCY
2/6/2015	14:06:18	A15999	Response		[26] [Appended, 14:07:34] [12] Duplicate call appended to incident at 14:06:18
2/6/2015	14:06:18	A15127	Response		{9} DUPE CALLER BOTTOM OF GRADE - CONF TO INTERAGENCY
2/6/2015	14:06:31	A15127	Response		{10} Backed up A72-011 with A72-001
2/6/2015	14:06:39	A11053	Response		[27] [Appended, 14:07:34] [14] Duplicate call appended to incident at 14:06:39
2/6/2015	14:06:51	A11053	Response		[28] [Appended, 14:07:34] [15] DUPE CONF W/INTER AGENCY
2/6/2015	14:07:08	SYS	Response		[12] [Appended, 14:07:30] A wireless rebid occurred. A possible phase 2 update is available.
2/6/2015	14:07:10	A11053	Response		[29] [Appended, 14:07:34] [16] 72-1 AHS VISUAL OF LG AMOUNT OF SMOKE
2/6/2015	14:07:22	A15127	Response		{11} LINK: [150206BI00077] to [150206BI00071] because {150206BI00077} appends to [150206BI00071]
2/6/2015	14:07:30	A15999	Response		[13] Duplicate call appended to incident at 14:07:30
2/6/2015	14:07:35	A15127	Response		[30] LINK: [150206BI00070] to [150206BI00071] because [150206BI00070] appends to [150206BI00071]
2/6/2015	14:07:49	A15127	Response		{44} LINK: [150206BI00056] to [150206BI00071] because {150206BI00056} appends to [150206BI00071]
2/6/2015	14:11:06	A11053	Response		{45} 72-S2 COPIES AT OFC
2/6/2015	14:13:14	A15127	Response		{46} A72-001 Unit A72-001 current position updated to LOWER ROCK CRK JSO CO LINE.
2/6/2015	14:13:14	A15127	Response		{47} A72-011 Unit A72-011 current position updated to LOWER ROCK CRK JSO CO LINE.
2/6/2015	14:14:08	SYS	Response		{51} [Appended, 14:20:41] [1] A wireless rebid occurred. A possible phase 2 update is available.
2/6/2015	14:14:09	A15127	Response		{48} 72-1 REQ TO NOTIFY MONO1 FOR POSS EVACUATIONS OF PARADISE AREA - VERY STRONG SOUTH WINDS
2/6/2015	14:14:53	A15127	Response		{49} PER ICSO SMOKE IS CAUSING LIMITED VISABILITY ON 395
2/6/2015	14:15:02	A11053	Response		{50} 1039 MCSO FOR 48
2/6/2015	14:20:19	A15999	Response		[52] [Appended, 14:20:41] [2] LATE ENTRY FIRE APPRO PARADISE
2/6/2015	14:20:21	A15999	Response		[53] [Appended, 14:20:41] [3] CONF INTERAGENCY
2/6/2015	14:20:41	A15999	Response		[54] LINK: [150206BI00080] to [150206BI00071] because [150206BI00080] appends to [150206BI00071]
2/6/2015	14:22:23	A11053	Response	Y	[55] 71-S1 R 133 SUMMIT - 1039 72-1 TO CHECK ON 71-S1'S WIFE - FROM COUNTY LINE
2/6/2015	14:24:36	A11053	Response		{56} ICSO ON HOT LINE HAVE UNITS USE CAUTION FOR DOWN TREE LIMBS ON LOWER ROCK CREEK ADN DOWN POWER LINES BEHIND THE RANCH
2/6/2015	14:24:41	A11053	Response		{57} 72-1 COPIES
2/6/2015	14:26:44	A15127	Response		[58] Backed up A72-001 with 72-S2
2/6/2015	14:26:45	A15999	Response		[59] 1184 AT GORGE/LOWER ROCK CREEK TO KEEP TRAFFIC FROM NB LRC
2/6/2015	14:26:52	A15999	Response		[60] LN59 ICSO
2/6/2015	14:27:09	A15127	Response		[61] 72-11 COPIES ENRT
2/6/2015	14:27:44	SYS	Response		[86] [Appended, 15:37:59] [1] A wireless rebid occurred. A possible phase 2 update is available.
2/6/2015	14:27:45	SYS	Response		[87] [Appended, 15:37:59] [2] A wireless rebid occurred. A possible phase 2 update is available.
2/6/2015	14:27:46	SYS	Response		[88] [Appended, 15:37:59] [3] A wireless rebid occurred. A possible phase 2 update is available.
2/6/2015	14:27:47	A15127	Response		[62] Secondary Location for A72-011: LOWER ROCK CRK /

2/6/2015	14:28:31	A15127	Response	GORGE. [63] RANCH OWNERS FOR JARVIS / CHANCE RANCH WILL BE ENRT TO LET THE HORSES OUT IN A GRY CHEV AND GRY DODGE TRK
2/6/2015	14:28:58	A15127	Response	[64] 72-11 COPIES
2/6/2015	14:29:12	A15999	Response	[89] [Appended, 15:37:59] [4] ROUND VALLEY DIRT PART BEFORE INTERSECTION WITH BOUNDARY LRG COTTOWOOD CURRENTLY COMPLETELY BLKG THE RDWY
2/6/2015	14:29:37	A15999	Response	[90] [Appended, 15:37:59] [5] RP IS CONCERNED B/C IT IS THE ONLY ALTERNATE ROUTE AROUND THE FIRE
2/6/2015	14:29:43	A15999	Response	[91] [Appended, 15:37:59] [6] CANNOT GET AROUND THE TREE
2/6/2015	14:31:29	A15127	Response	[65] 72-1 1039 71-S1 SPOUSE , NOW FIXED 1184 AT LOWER ROCK CREEK / COUNTY LINE
2/6/2015	14:31:54	A15127	Response	[66] Secondary Location for A72-001: LOWER ROCK CRK / CO LINE.
2/6/2015	14:31:54	A15999	Response	[92] [Appended, 15:37:59] [7] 1039 COUNTY RDS
2/6/2015	14:32:05	SYS	Response	[67] [Appended, 14:37:04] [1] A wireless rebid occurred. A possible phase 2 update is available.
2/6/2015	14:32:12	SYS	Response	[93] [Appended, 15:37:59] [8] A wireless rebid occurred. A possible phase 2 update is available.
2/6/2015	14:32:53	SYS	Response	[68] [Appended, 14:37:04] [2] A wireless rebid occurred. A possible phase 2 update is available.
2/6/2015	14:33:02	A11053	Response	[69] [Appended, 14:37:04] [3] CONF W/INTER AGENCY
2/6/2015	14:33:24	A15999	Response	[94] [Appended, 15:37:59] [9] RP RECALLED ADVISING MULT VEHS ARE STUCK BEHIND THIS TREE AND ARE IN A DANGEROUS PLACE WITH MULT OTHER TREES THAT COULD BLOW DOWN ON TOP OF THEM
2/6/2015	14:33:36	A15999	Response	[95] [Appended, 15:37:59] [10] REC'D CLOSING ACCESS AT BIRCHIM/N ROUND VALLEY
2/6/2015	14:37:04	A11053	Response	[70] LINK: [150206BI00085] to [150206BI00071] because [150206BI00085] appends to [150206BI00071]
2/6/2015	14:41:21	A15127	Response	[96] [Appended, 15:37:59] [11] 72-1 COPIES , DOES HAVE BOUNDARY RD CLOSED TO TRAFFIC
2/6/2015	14:42:44	A15127	Response	[71] 72-S2 ADVSD VISABILITY IS ACCEPTABLE AT THIS TIME
2/6/2015	14:46:58	A15127	Response	[72] 71-S1 Unit 71-S1 current position updated to 106 -R-.
2/6/2015	14:48:20	A15999	Response	[97] [Appended, 15:37:59] [12] PER MONO1 NO EVAC YET FOR PARADISE
2/6/2015	14:50:23	A11053	Response	[73] 72-1 1184 AT LOWR ROCK CREEK AND BOUNDRY - OVER RUN WITH HOT SPOTS AND WORKING ITS WAY NB ALONG THE CREEK
2/6/2015	14:51:02	A11053	Response	[74] 72-1 SWEEPING BOUNDRY RD - ICSO MOVED CLOSURE UP TO PARADISE
2/6/2015	14:53:46	A15127	Response	[75] ICSO ADVSD SOUTH SIDE OF LOWER ROCK CREEK , HEADING TOWARDS PARADISE
2/6/2015	14:56:04	A15127	Response	[76] PER 72-S2 SMOKE IS GETTING THICKER
2/6/2015	14:57:02	A15127	Response	[77] PER ICSO MANDATORY EVACUATIONS AT PARADISE - 71-S1 COPIES
2/6/2015	15:01:23	A15999	Response	[78] MONO1 REQ ASSIST WITH EVACS
2/6/2015	15:01:41	A15999	Response	[79] PER 72-S2 SEVERAL FG WARDENS ARE IN TEH AREA AVAIL TO HELP // 72-4 ALSO ENRT F/ BISHP
2/6/2015	15:03:21	A15999	Response	[80] 72-S2 PER 72-S2 CONFIRM THAT ROUND VALLEY SCHOOL IS AWARD
2/6/2015	15:03:35	A15999	Response	[81] LL FG DISPATCH
2/6/2015	15:06:15	A15999	Response	[82] 1039 ROUND VALLEY SCHOOL THEY ARE AWARE
2/6/2015	15:19:09	A15999	Response	[83] Backed up 72-S2 with 72-C
2/6/2015	15:24:38	A15999	Response	[84] Backed up 72-S2 with A72-003
2/6/2015	15:30:21	A15999	Response	[85] Backed up 71-S1 with 71-052
2/6/2015	15:37:59	A15999	Response	[98] LINK: [150206BI00083] to [150206BI00071] because [150206BI00083] appends to [150206BI00071]
2/6/2015	15:42:20	A15999	Response	[99] 72-S2 INFO ONLY NB AND SB 395 WILL REMAIN OPEN FOR TIME BEING
2/6/2015	15:43:16	A15999	Response	[100] 71-S1 OUT WITH ALTZ PT AT 113 SUMMIT WHERE CAN THEY BE TAKEN
2/6/2015	15:43:58	A15999	Response	[101] 72-C IF THEY HAVE A SHELTER SET UP
2/6/2015	15:44:28	A15999	Response	[102] 71-S1 ATTEMPTING CROWLEY LAKE COMMUNITY CENTER
2/6/2015	15:45:57	A15999	Response	[103] 72-C CONFIRM THAT THAT INFO HAS BEEN MADE PUBLIC // PRESS RELEASE ABOUT SHELTER
2/6/2015	15:47:26	A15999	Response	[104] 72-C INYO COUNTY HAS PUT OUT A PRESS RELEASE WITH SHELTER INFO

2/6/2015	15:48:30	A15999	Response	[105] 72-C ICSO INFO IS AVAIL ON FB PAGE // NEG PRESS RELEASE // THAT WOULD HAVE TO COME FROM MONO PIO
2/6/2015	15:54:01	A15999	Response	[106] Secondary Location for 71-052: CROWLEY LAKE COMMUNITY CENTER.
2/6/2015	15:59:57	A15999	Response	[107] 71-S1 CLR
2/6/2015	16:00:08	A15999	Response	[108] 72-S2 72-C
2/6/2015	16:00:11	A15999	Response	[109] A72-001 CLR
2/6/2015	16:00:52	A15999	Response	[110] A72-003 72-11 OUT WITH A RES ON SCOTT RD PREPARING TO LEAVE NOE
2/6/2015	16:01:19	A15999	Response	[111] B72-004 WITH 72-11 PREPARING TO LEAVE
2/6/2015	16:02:12	A15999	Response	[112] 71-052 C4 STILL ENRT TO CROWLEY LK COMM CENTER
2/6/2015	16:03:00	A15999	Response	[113] 71-052 MOTORISAT 1 COUGAR RUN AT SWALL LIVESTOCK
2/6/2015	16:03:41	A15999	Response	[114] A72-003 72-4, 72-11 LEAVING PARADISE NOW
2/6/2015	16:04:14	A15999	Response	[115] 71-S1 DO NOT HAVE THE REASOURCES TO ASSIST// REFER TO MONO1
2/6/2015	16:04:53	A15999	Response	[116] 1039 LN113 MONO1
2/6/2015	16:06:35	A15999	Response	[117] Secondary Location for A72-003: SWALL MEADOWS.
2/6/2015	16:06:36	A15999	Response	[118] Secondary Location for A72-011: SWALL MEADOWS.
2/6/2015	16:06:36	A15999	Response	[119] Secondary Location for B72-004: SWALL MEADOWS.
2/6/2015	16:08:42	A15999	Response	[120] Secondary Location for A72-001: LOWER ROCK CREEK/GORGE.
2/6/2015	16:12:34	A15999	Response	[121] 71-S1 PPLE STAGING AT THE ENTRANCE TO SWALL AFFIRM ALL PERSONNEL TO CROWLEY LK COMMUNITY CENTER
2/6/2015	16:14:14	A15999	Response	[122] PER MONO1 THEY WILL NOT BE MOVING THE LIVESTOCK
2/6/2015	16:15:19	A15999	Response	[123] 71-052 CROWLEY LAKE COMM CENTER
2/6/2015	16:17:47	A15999	Response	[124] 71-052 BUILDING EMPTY AND LOCKED
2/6/2015	16:19:03	A15999	Response	[125] B72-004 LOWER ROCK CREEK JSO SWALL WITH PTY OO GAS
2/6/2015	16:19:44	A15999	Response	[126] SOCIAL SERVICES ENRT F/ MMH TO SET6 UP THE SHELTER
2/6/2015	16:19:57	A15999	Response	[127] Secondary Location for B72-004: LRC JSO SWALL.
2/6/2015	16:20:34	A15999	Response	[128] 71-S1 RE:52'S PTY S1 1021 TO SON IN RIVERSIDE
2/6/2015	16:23:15	A15999	Response	[129] B72-004 1148 X2 TO 395/ LRC NORTH END
2/6/2015	16:31:17	A15999	Response	[130] PER HOTLINE VAN DYKE 150 ACTIVE ACRES 20 STRUCTURES THREATENED
2/6/2015	16:36:25	A15999	Response	[131] ICSO EDISON TRUCK STUCK AT A CLOSURE IN ROUND VALLEY
2/6/2015	16:36:47	A15999	Response	[132] A72-001 NEG EDISON TRUCK AT HIS 1020 // 72-3 ADV FOREST SERVICE IS MANNING ADDL ROUND VALLEY CLOSURES
2/6/2015	16:38:40	A14762	Response	[133] 72-S1 REQ W/ INCIDENT COMMAND 1020 / LOWER ROCK CRK ACROSS F/ GORGE PER ICSO
2/6/2015	16:39:54	A14762	Response	[134] PER MONO1 SWALL MEADOW BEING MANDATORY EVACUATED
2/6/2015	16:40:37	A14762	Response	[135] 71-S1 COPIES
2/6/2015	16:44:21	A15999	Response	[136] Secondary Location for B72-004: SWALL MEADOWS.
2/6/2015	16:44:48	A15999	Response	[137] A72-011 RESIDENT AT 59 VALLEY VIEW REFUSING TO LEAVE HIS PROPERTY
2/6/2015	16:45:43	A14762	Response	[138] 1039 MONO1 LINE 137
2/6/2015	16:47:25	A14762	Response	[139] 72-S2 COPIES LINE 137 - 138
2/6/2015	16:51:30	A14762	Response	[140] 71-052 CROWLEY COMMUNITY CENTER NOW OPEN
2/6/2015	17:05:12	A14762	Response	[141] 71-52 INQ WHERE 71-S1 WOULD LIKE HER TO RESP / PER 71-S1 71-52 CAN RETURN TO PATROL / 71-52 COPIES
2/6/2015	17:38:30	A15999	Response	[142] PER HOTLINE 100 ACRES PARADISE AND SWALL STILL EVACUATED
2/6/2015	17:43:27	A15999	Response	[143] A72-003 CHK WITH MONO1 ABLE TO ASSIST 1 COUGAR DRIVE TO ASSIST WITH HORSES
2/6/2015	17:44:18	A15999	Response	[144] PER MONO1 NEG AND NEG ANIMAL CONTROL
2/6/2015	17:53:23	A15999	Response	[145] Secondary Location for C72-001: 1184 LRC/ GORGE.
2/6/2015	17:55:02	A15999	Response	[146] 72-S2 GRAVES 1 AT LRC / SWALL MEADOW ALL NIGHT // / LRC AND PINE CREEK// THIRD TO 395/ LRC NORTH END
2/6/2015	17:55:44	A14762	Response	[147] PER 72-S2 HAVE C72-3 RESP TO 395/ LOWER ROCK CRK TO RELIEVE FOREST SERIVES / 72-3 COPIES LINE 146 \

[148] PER ICSO THERE IS A PTY NAMED DAVE IN A WHI

2/6/2015	18:02:23	A14762	Response	CHEV PK TK THAT IS RESP'ING TO LOWER ROCK CRK TO ASSIST W/ EVACUATIONS
2/6/2015	18:03:50	A14762	Response	[149] 72-S2 COPIES
2/6/2015	18:05:42	A14762	Response	[150] Secondary Location for A72-011: 1148X F/ LOWER ROCK CRK 395 TO SWALL FOR HORSE EVACUTATION SM/24565.
2/6/2015	18:16:29	A15999	Response	[151] Secondary Location for B72-004: LRC/SWALL.
2/6/2015	18:17:54	A15999	Response	[152] 72-S2 ALL A WATCH UNITS CAN GO 1010 WHEN RELIEVED
2/6/2015	18:21:46	A15999	Response	[153] B72-004 72-4 WITH MONO SO
2/6/2015	18:22:42	A15999	Response	[154] Secondary Location for C72-003: US395/LRC NORTH.
2/6/2015	18:29:30	A15999	Response	[155] Secondary Location for C72-011: LRC/395 NORTH.
2/6/2015	18:29:56	A15999	Response	[156] Secondary Location for C72-009: LRC/SWALL.
2/6/2015	18:43:59	A14762	Response	[157] C72-009 72-4 RELIEVED BY 72-9 108
2/6/2015	19:38:31	A15885	Response	[158] C72-009 MOVING TO CLOSURE AT LOWER ROCK CREEK AND 395 - GETTING SHOWERED WITH ASH AT HIS LOC
2/6/2015	19:38:43	A15885	Response	[159] Secondary Location for C72-009: LOWER ROCK CREEK & US395.
2/6/2015	19:57:20	A15885	Response	[160] Secondary Location for C72-011: LOWER ROCK CREEK & US395.
2/6/2015	20:17:09	A14762	Response	[161] Secondary Location for C72-011: OFC.
2/6/2015	20:40:30	A15885	Response	[162] C72-009 FOREST SVCE ADV FIRE CROSSED ROCK CREEK RD IN CYN HEADED UP LOWER ROCK CREEK RD TO 395
2/6/2015	20:47:03	A14762	Response	[163] Secondary Location for C72-003: ENRT OFC FOR MORE EXTENDERS.
2/6/2015	20:57:34	A15885	Response	[164] 72-S2 REQ LET OFFICERS AT CLOSURE AT TOP OF LOWER ROCK CREEK AND 395 KNOW THE FIRE IS HEADED THEIR WAY - TO HAVE THE RDWY CLEAR AND VEHS FACING OUT IN CASE THEY NEED TO LEAVE IN A HURRY
2/6/2015	20:57:47	A15885	Response	[165] BCAST LINE 164 // 72-9, 72-3, 72-1 COPIES
2/6/2015	20:57:57	A15885	Response	[166] Secondary Location for B72-004: 1184 LRC/ GORGE.
2/6/2015	20:57:57	A15885	Response	[167] Backed up C72-001 with B72-004
2/6/2015	20:58:24	A15885	Response	[168] 71-S2 REQ NTFY COMMANDER OF ESCORTS
2/6/2015	20:58:58	A15885	Response	[169] LINE 168 ENTERED IN WRONG LOG
2/6/2015	21:02:19	A15885	Response	[170] ICSO ADV SALVATION ARMY HAS OPENED THEIR SHELTER ON NORTH SIDE OF WEST LINE ST AT TOWN AND COUNTRY CENTER FOR ANYONE THAT NEEDS SHELTER, FOOD , OR COFFEE
2/6/2015	21:03:14	A15885	Response	[171] Backed up C72-003 with 71-051
2/6/2015	21:45:20	A15885	Response	[172] Secondary Location for 71-052: 1184 LRC/ GORGE.
2/6/2015	21:45:20	A15885	Response	[173] Backed up C72-001 with 71-052
2/6/2015	21:45:30	A15885	Response	[174] 71-052 ASSISTING SO W/NOTIFICATIONS ON ROCK CREEK
2/6/2015	21:59:01	A15885	Response	[175] C72-001 72-4 SHUTTING DOWN 395 NB AT GORGE RD DUE TO FIRE
2/6/2015	21:59:06	A15885	Response	[176] Secondary Location for B72-004: NB395 AT GORGE RD.
2/6/2015	22:00:57	A15885	Response	[177] 72-S2 COPIES AND ALSO TOMS PLACE // REQ NTFY CT
2/6/2015	22:01:24	A15885	Response	[178] C72-009 72-11 SHUTTING SB 395 TOMS PLACE
2/6/2015	22:01:29	A15885	Response	[179] Secondary Location for C72-011: SB395 TOMS PLACE.
2/6/2015	22:01:48	A14762	Response	[180] 1039 CT
2/6/2015	22:02:23	A14762	Response	[181] NB AT BREAK CHK 1124 SIL SD PER 72-9
2/6/2015	22:04:28	A14762	Response	[182] PER 72-S2 HE NOTIFIED 72-C
2/6/2015	22:04:48	A14762	Response	[183] PER 72-S2 MOVE THE SB CLOSURE TO CROWLEY / 72-3 72-9 COPY
2/6/2015	22:04:52	A14762	Response	[184] 1039 CT
2/6/2015	22:06:13	A14762	Response	[185] Secondary Location for C72-003: 395/CROWLEY.
2/6/2015	22:06:21	A14762	Response	[186] Secondary Location for C72-009: 395 / CROWLEY.
2/6/2015	22:11:53	A15885	Response	[187] CT ADV 395 NOW CLOSED F/GORGE TO CROWLEY LAKE O/PASS
2/6/2015	22:32:30	A14762	Response	[188] C72-003 FIRE REQ CHP TO ROVE UP AND DOWN LOOKING FOR SPOT FIRES 72-9 COPIES WILL BOL / PER 72-9 395 IS CLR OF ANY VEHS
2/6/2015	22:33:29	A14762	Response	[189] PER 72-C INLAND2 HAS BEEN NOTIFIED
2/6/2015	22:34:21	A14762	Response	[190] PER ICSO BOB TANNER OWNER OF ROCK CRK PACK STATION WILL BE IN A RED FORD F250 AT THE SOUTHERN END OF THE CLOSURE / PTY NEEDS TO GET THROUGH TO GET TO ROCK CRK TO GET

Date	Time	Agency	Type	Priority	Description
2/6/2015	22:35:46	A15885	Response		EMPLOYEES AND BELONGING
2/6/2015	22:36:45	A14762	Response		[191] 72-S1 COPIES
2/6/2015	22:36:52	A14762	Response		[192] 72-1 COPIES LINE 190
2/6/2015	22:39:07	A14762	Response		[193] LATE ENRTY PER 72-C NOTIFY ENTAC
2/6/2015	22:47:25	A15885	Response		[194] 1039 ENTAC
2/6/2015	22:50:45	A15900	Response		[195] Secondary Location for C72-011: SB395 CROWLEY LAKE O/PASS.
2/6/2015	22:52:02	A15900	Response		[196] 71-052 HAS ONR TO SB F/SOUTH LANDING SHUT DOWN
2/6/2015	22:53:48	A15900	Response		[197] Secondary Location for 72-S2: US395 / CROWLEY.
2/6/2015	22:54:20	A15900	Response		[198] Secondary Location for 72-C: CROWLEY / 395.
2/6/2015	22:59:25	A15885	Response		[199] Secondary Location for 72-C: 395 / CROWLEY.
2/6/2015	23:04:38	A15900	Response	Y	[200] Secondary Location for 72-C: NB395 GORGE. [201] MONO1 INQ IF MLPD RESERVE CAN GO SB TO BISHOP / PER S2 AFFIRM JUST ADVS 72-11 AT NB CLOSURE / 72-11 HAS NO CELL SVC // MONO1 COPIES - WILL SEND UNIT SB
2/6/2015	23:05:10	A15900	Response	Y	[202] 72-11 COPIES
2/6/2015	23:07:46	A15900	Response		[203] Secondary Location for 72-S2: US395 / CROWLEY.
2/6/2015	23:13:45	A15900	Response		[204] [Notification] [CHP]-Problem changed from FIRE-Report of Fire to CLOSURE of a Road by CHP [Shared]
2/6/2015	23:43:03	A15900	Response	Y	[205] 1021 CT TO CHANGE CMS SIGN ON THE SOUTH END OF BISHOP TO SHOW CLOSURE AT GORGE
2/6/2015	23:46:26	A15900	Response		[206] 72-S2 CONTACT UNITS AT CROWLEY AND TOMS AND GORGE ALL OPEN RDWY BUT STAY IN PLACE IN CASE WE NEED TO CLOSE AGAIN
2/6/2015	23:46:32	A15900	Response		[207] C72-003 AT TOMS OPENING UP
2/6/2015	23:47:08	A15900	Response		[208] C72-001 COPIES WILL ADVS 4
2/6/2015	23:47:14	A15900	Response		[209] B72-004 WILL BE OPENING UP
2/6/2015	23:47:34	A15900	Response		[210] 72-S2 LOWER ROCK CREEK WILL STILL REMAIN CLOSED / 72-1 COPIES
2/6/2015	23:48:04	A15900	Response		[211] 72-S2 REQ UNIT AT TOMS GO TO LOWER ROCK CREEK AND 395 / 72-3 COPIES
2/6/2015	23:48:47	A15900	Response		[212] 72-9 COPIES
2/6/2015	23:49:05	A15900	Response		[213] 72-4 NB LANES ARE OPEN
2/6/2015	23:49:37	A15900	Response		[214] Secondary Location for C72-003: LOWER ROCK CREEK / 395.
2/6/2015	23:50:22	A15900	Response		[215] 1039 ENTAC
2/6/2015	23:50:31	A15900	Response		[216] CT COPIES
2/7/2015	00:40:23	A15900	Response		[217] B72-004 PER S2 98 F/FIRE
2/7/2015	01:18:31	A15900	Response		[218] CT LIFTING HIGH PROFILE F/PROHIBITED TO NOT RECOMMENDED
2/7/2015	01:19:00	A15900	Response		[219] BCAST
2/7/2015	01:19:09	A15900	Response		[220] 72-S2 COPIES
2/7/2015	02:12:22	A15900	Response		[221] C72-003 SNOW IS STARTING TO STICK AT TOMS
2/7/2015	03:09:57	A15885	Response		[222] CHIEF MITCHELL F/CALFIRE REQ CHP REPRESENTATIVE TO ATTEND BRIEFING AT ROUND VALLEY PRISON CAMP AT 0700 HRS
2/7/2015	04:28:23	A15900	Response		[223] 72-S2 COPIES
2/7/2015	04:44:23	A15900	Response		[225] Secondary Location for C72-011: LOWER ROCK CREEK / US395.
2/7/2015	04:44:23	A15900	Response		[224] Secondary Location for C72-009: LOWER ROCK CREEK / US395.
2/7/2015	06:14:18	A15900	Response		[226] Secondary Location for A72-001: LOWER ROCK CREEK / GORGE.
2/7/2015	06:16:00	A15900	Response		[227] Secondary Location for A72-011: LOWER ROCK / US395.
2/7/2015	06:41:38	A15900	Response		[228] Secondary Location for 72-S3: OWENS VALLEY PRISON CAMP FOR BRIEFING.
2/7/2015	06:42:30	A15900	Response		[229] Secondary Location for A72-003: US395 / LOWER ROCK.
2/7/2015	07:00:07	A15127	Response		[230] 72-1 HAS HAD PEOPLE INQ ABOUT A PRESS CONFERENCE - REQ TO FIND FIND OUT FURTHER
2/7/2015	07:01:30	A15999	Response		[231] PER ICSO RE PRESS CONF NOT THAT THEY ARE AWARE OF
2/7/2015	07:04:07	A15999	Response	Y	[232] PER INTERAGENCY CAL-FIRE WILL BE HANDLING PRESS // AFTER 7AM COMMAND MTG
2/7/2015	07:05:34	A15127	Response		[233] CORR LINE 230 72-11
2/7/2015	07:24:59	A15999	Response		[234] A72-001 VERIZON REQ ACCESS TO CLOSURE AT LRC AND GORGE
2/7/2015	07:26:17	A15999	Response		[235] A72-001 PER CALFIRE VERIZON TRUCK NEG ACCESS
					[236] PER 72-S3 VERIZON WILL BE ALLOWED ACCESS

2/7/2015	08:42:22	A15127	Response		INTO THE AREA , HOWEVER WILL BE ESCORTED BY CAL FIRE - 72-3 COPIES
2/7/2015	11:53:42	A15127	Response		[237] Secondary Location for 72-S2: LOWER ROCK CREEK / GORGE.
2/7/2015	11:53:42	A15127	Response		[238] Backed up A72-001 with 72-S2
2/7/2015	12:14:08	A15999	Response		[239] 72-11 106 ON A DETAIL WILL ADV WHEN CLR
2/7/2015	12:44:35	A15999	Response		[240] PER CALFIRE EDISON TRUCKS NEED ACCESS THROUGH OUR CLOSURES 72-3 COPIES NORTH END 72-1 COPIES AS WELL
2/7/2015	14:21:25	A15127	Response		[241] Secondary Location for 72-S2: ENRT CDF CAMP.
2/7/2015	14:22:32	A15999	Response	Y	[242] CALFIRE CAPTAIN RICH BRUNING REQ RP INFO FOR INVESTIGATION
2/7/2015	14:22:51	A15999	Response	Y	[243] PER R.SEAVER HE WILL HANDLE ON MONDAY
2/7/2015	14:23:03	A15999	Response	Y	[244] 1039 CALFIRE
2/7/2015	14:39:56	A15127	Response		[245] A72-011 Unit A72-011 current position updated to LOWER ROCK CRK / GORGE.
2/7/2015	18:20:15	A15885	Response		[246] Secondary Location for C72-011: LOWER ROCK / US395.
2/7/2015	18:20:15	A15885	Response		[247] Backed up A72-011 with C72-011
2/7/2015	18:26:41	A15885	Response		[249] Backed up A72-003 with B72-004
2/7/2015	18:26:41	A15885	Response		[248] Secondary Location for B72-004: US395 / LOWER ROCK.
2/7/2015	18:27:03	A15885	Response		[250] B72-004 RELIEVING 72-3A AT ROCK CREEK AND 395
2/7/2015	18:27:28	A15885	Response		[251] Secondary Location for B72-004: ROCK CREEK & 395.
2/7/2015	18:29:56	A15127	Response		[253] Backed up B72-004 with C72-009
2/7/2015	18:29:56	A15127	Response		[252] Secondary Location for C72-009: ROCK CREEK & 395.
2/7/2015	18:30:07	A15127	Response		[254] Secondary Location for C72-009: ENRT LOWER CLOSURE.
2/7/2015	18:42:40	A15885	Response		[255] Secondary Location for C72-009: LOWER ROCK / GORGE.
2/7/2015	18:42:50	A15885	Response		[256] Secondary Location for C72-011: LOWER ROCK / GORGE.
2/7/2015	19:19:31	A15900	Response		[257] B72-004 RELIEVED BY 72-11 / LOWER ROCK / 395 - 72-4 108 AND ROVING THE AREA
2/7/2015	19:19:48	A15900	Response		[258] Secondary Location for C72-011: LOWER ROCK / 395.
2/8/2015	06:02:53	A15900	Response		[259] Secondary Location for A72-003: US395 / GORGE.
2/8/2015	06:18:55	A15900	Response		[260] Secondary Location for 72-S2: MORNING BRIEFING / FIRE CAMP.
2/8/2015	06:27:06	A15900	Response		[261] Secondary Location for A72-001: US395 / LOWER ROCK CREEK.
2/8/2015	11:04:22	A15999	Response		[262] A72-003 ADV MONO1 INFO ONLY // RED VW HB VEH WITH PRESS PASS NBC NEWS HEADED TO PARADISE
2/8/2015	11:04:48	A15999	Response		[263] 1039 MONO1
2/8/2015	11:29:09	A15999	Response		[264] PER MONO1 SGT THEY ARE OUT WITH THE VEH STATING THEY ARE ENRT TO SWALL // INQ IF THEY ARE ALLOWED THERE PER 72-3 THAT IS UP TO THE SO
2/8/2015	13:36:02	A15999	Response		[265] 72-S2 PER CHP CAD PUBLIC SITE CLOSURE INFO HAS TIMED OUT REQ A NEW LOG
2/8/2015	13:38:35	A15999	Response		[266] LOG CONTINUED AS 150208BI00054
2/8/2015	15:22:08	A15900	Response		[267] Incident Re-opened:
2/8/2015	15:22:17	A15900	Response		[268] LINK: [150206BI00071] to [150208BI00054] because [150206BI00071] appends to [150208BI00054]

Address Changes

Date	Time	Location/Address	User
2/6/2015	23:14:27	NB 395 BOTTOM OF SHERWIN GRADE / US395 GORGE TO CROWLEY	JH
2/7/2015	05:40:41	NB 395 BOTTOM OF SHERWIN GRADE / 0 Lower Rock Creek Rd	JH

Priority Changes

Date	Time	Changed from Priority	Reason	User
2/6/2015	23:13:45	4	Additional Info	JH

Alarm Level Changes

No Alarm Level Changes

Activity Log

Date	Time	Radio	Activity	Location	Log Entry	User
2/6/2015	14:02:19		Incident Priority Change		Incident priority changed from <none> to A11053 4	

2/6/2015	14:03:36	ANI/ALI Statistics		INT Insert:Feb 06 2015 14:02:07 / INT SendNP:Feb 06 2015 14:02:06 / WS RecvNP:Feb 06 2015 14:02:07 / WS Process:Feb 06 2015 14:03:36	A11053
2/6/2015	14:04:06	Duplicate Call Warning		Duplicate Call Warning - New call appended to incident	A15999
2/6/2015	14:04:06	Supplemental Information	0 Us395	Supplemental Person record 654543 - was added for	A15999
2/6/2015	14:04:38	A72-011 ASSIGN	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Response Number (02062015-0000720)	A15127
2/6/2015	14:04:48	Duplicate Call Warning		Duplicate Call Warning - New call appended to incident	A15127
2/6/2015	14:04:48	Supplemental Information	0 Us395	Supplemental Person record 654546 - was added for	A15127
2/6/2015	14:05:01	UserAction		User clicked Exit/Save	A15999
2/6/2015	14:06:30	A72-001 ASSIGN	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Response Number (02062015-0000721)	A15127
2/6/2015	14:06:30	A72-001 ENRT	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Responding From = Red Hill Rd\Unnamed Street	A15127
2/6/2015	14:06:30	A72-011 Unit Backed up	NB 395 BOTTOM OF SHERWIN GRADE	Backed up with A72-001	A15127
2/6/2015	14:06:48	UserAction		User clicked Exit/Save	A15127
2/6/2015	14:07:14	UserAction		User clicked Exit/Save	A11053
2/6/2015	14:07:22	Append Incident		Dispatcher Appended [150206BI00077] to this incident	A15127
2/6/2015	14:07:22	Link Incident		LINK: [150206BI00077] to [150206BI00071] because [150206BI00077] appends to [150206BI00071]	A15127
2/6/2015	14:07:22	Supplemental Information	0 Us395	Supplemental Person record 654550 - was added for	A15127
2/6/2015	14:07:30	Duplicate Call Warning		Duplicate Call Warning - New call appended to incident	A15999
2/6/2015	14:07:30	Supplemental Information	0 Us395	Supplemental Person record 654551 - was added for	A15999
2/6/2015	14:07:33	UserAction		User clicked Exit/Save	A15999
2/6/2015	14:07:35	Append Incident		Dispatcher Appended [150206BI00070] to this incident	A15127
2/6/2015	14:07:35	Link Incident		LINK: [150206BI00070] to [150206BI00071] because [150206BI00070] appends to [150206BI00071]	A15127
2/6/2015	14:07:35	Supplemental Information	0 Us395	Supplemental Person record 654553 - was added for	A15127
2/6/2015	14:07:35	Supplemental Information	0 Us395	Supplemental Person record 654554 - was added for	A15127
2/6/2015	14:07:35	Supplemental Information	0 Us395	Supplemental Person record 654555 - was added for JIM	A15127
2/6/2015	14:07:35	Supplemental Information	0 Us395	Supplemental Person record 654556 - was added for DON RANCH	A15127
2/6/2015	14:07:49	Append Incident		Dispatcher Appended [150206BI00056] to this incident	A15127
2/6/2015	14:07:49	Link Incident		LINK: [150206BI00056] to [150206BI00071] because [150206BI00056] appends to [150206BI00071]	A15127
2/6/2015	14:07:49	Supplemental Information	0 Us395	Supplemental Person record 654557 - Passing Motorist was added for KAREN TODD	A15127
2/6/2015	14:10:50	Read Incident		Incident 916 was Marked as Read.	A11053
2/6/2015	14:10:50	Read Comment		Comment for Incident 916 was Marked as Read.	A11053
2/6/2015	14:12:25	UserAction		User clicked Exit/Save	A15999
2/6/2015	14:12:55	A72-001 10-97	0 Us395		A15127
2/6/2015	14:13:00	A72-011 10-97	0 Us395		A15127
2/6/2015	14:16:02	71-S1 ASSIGN	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Response Number (02062015-0000723)	A15999
2/6/2015	14:16:02	71-S1 ENRT	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Responding From = SR158 S US395 S CON / SR158 [NB JNO SR158 SOUTH JCT]	A15999
2/6/2015	14:20:41	Append Incident		Dispatcher Appended [150206BI00080] to this incident	A15999
2/6/2015	14:20:41	Link Incident		LINK: [150206BI00080] to	A15999

					[150206BI00071] because [150206BI00080] appends to [150206BI00071]	
2/6/2015	14:20:41		Supplemental Information	0 Us395	Supplemental Person record 654565 - was added for	A15999
2/6/2015	14:22:29		Update IsConfidential	0 Us395	Updated IsConfidential to True for Response_Comment record 27531171	A11053
2/6/2015	14:24:16		UserAction		User clicked Exit/Save	A15999
2/6/2015	14:26:43	72-S2	ASSIGN	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Response Number (02062015-0000724)	A15127
2/6/2015	14:26:43	72-S2	ENRT	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Responding From = Bishop	A15127
2/6/2015	14:26:43	A72-001	Unit Backed up	NB 395 BOTTOM OF SHERWIN GRADE	Backed up with 72-S2	A15127
2/6/2015	14:27:12		UserAction		User clicked Exit/Save	A11053
2/6/2015	14:27:47	A72-011	ENRT ALT	LOWER ROCK CRK / GORGE	Incident ID = 6879916, 0, 0,	A15127
2/6/2015	14:29:02	A72-011	10-97 ALT	LOWER ROCK CRK / GORGE	Incident ID = 6879916, 0, 0,	A15127
2/6/2015	14:29:16		UserAction		User clicked Exit/Save	A15127
2/6/2015	14:31:54	A72-001	ENRT ALT	LOWER ROCK CRK / CO LINE	Incident ID = 6879916, 0, 0,	A15127
2/6/2015	14:31:57	A72-001	10-97 ALT	LOWER ROCK CRK / CO LINE	Incident ID = 6879916, 0, 0,	A15127
2/6/2015	14:32:06		UserAction		User clicked Exit/Save	A15127
2/6/2015	14:34:16		UserAction		User clicked Exit/Save	A15999
2/6/2015	14:37:04		Append Incident		Dispatcher Appended [150206BI00085] to this incident	A11053
2/6/2015	14:37:04		Link Incident		LINK: [150206BI00085] to [150206BI00071] because [150206BI00085] appends to [150206BI00071]	A11053
2/6/2015	14:37:04		Supplemental Information	0 Us395	Supplemental Person record 654573 - Passing Motorist was added for SHARON	A11053
2/6/2015	14:38:04		UserAction		User clicked Exit/Save	A15999
2/6/2015	14:42:28	72-S2	10-97	0 Us395		A15127
2/6/2015	14:44:29		UserAction		User clicked Exit/Save	A15999
2/6/2015	14:46:50	71-S1	10-97	0 Us395		A15127
2/6/2015	14:47:24		UserAction		User clicked Exit/Save	A15127
2/6/2015	14:49:39		Read Comment		Comment for Incident 916 was Marked as Read.	A11053
2/6/2015	14:54:59		UserAction		User clicked Exit/Save	A15127
2/6/2015	14:59:35		UserAction		User clicked Exit/Save	A11053
2/6/2015	14:59:38		UserAction		User clicked Exit/Save	A15127
2/6/2015	15:00:46	B72-004	ASSIGN	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Response Number (02062015-0000726)	A15999
2/6/2015	15:00:47	B72-004	ENRT	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Responding From = US395MM395	A15999
2/6/2015	15:01:00		Read Comment		Comment for Incident 916 was Marked as Read.	A15999
2/6/2015	15:06:24	B72-004	10-97	0 Us395		A15999
2/6/2015	15:07:48		UserAction		User clicked Exit/Save	A15127
2/6/2015	15:08:32		UserAction		User clicked Exit/Save	A15999
2/6/2015	15:10:36		UserAction		User clicked Exit/Save	A14762
2/6/2015	15:19:08	72-C	ASSIGN	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Response Number (02062015-0000727)	A15999
2/6/2015	15:19:08	72-C	ENRT	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Responding From = Bishop	A15999
2/6/2015	15:19:08	72-S2	Unit Backed up	NB 395 BOTTOM OF SHERWIN GRADE	Backed up with 72-C	A15999
2/6/2015	15:24:38	A72-003	ASSIGN	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Response Number (02062015-0000728)	A15999
2/6/2015	15:24:38	A72-003	10-97	0 Us395		A15999
2/6/2015	15:24:38	72-S2	Unit Backed up	NB 395 BOTTOM OF SHERWIN GRADE	Backed up with A72-003	A15999
2/6/2015	15:30:21	71-052	ASSIGN	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Response Number (02062015-0000729)	A15999
2/6/2015	15:30:21	71-052	10-97	0 Us395		A15999
2/6/2015	15:30:21	71-S1	Unit Backed up	NB 395 BOTTOM OF SHERWIN GRADE	Backed up with 71-052	A15999
2/6/2015	15:36:13	72-C	10-97	0 Us395		A15999
2/6/2015	15:37:59		Append Incident		Dispatcher Appended [150206BI00083]	A15999

2/6/2015	15:37:59		Link Incident		to this incident LINK: [150206BI00083] to [150206BI00071] because [150206BI00083] appends to [150206BI00071]	A15999
2/6/2015	15:37:59		Supplemental Information	0 Us395	Supplemental Person record 654612 - Witness was added for ROBERT	A15999
2/6/2015	15:51:18		Read Comment		Comment for Incident 916 was Marked as Read.	A15999
2/6/2015	15:51:26		UserAction		User clicked Exit/Save	A15999
2/6/2015	15:54:02	71-052	ENRT ALT	CROWLEY LAKE COMMUNITY CENTER	Incident ID = 6879916, 0, 0,	A15999
2/6/2015	16:04:31		Read Comment		Comment for Incident 916 was Marked as Read.	A15999
2/6/2015	16:06:35	A72-003	ENRT ALT	SWALL MEADOWS	Incident ID = 6879916, 0, 0,	A15999
2/6/2015	16:06:36	A72-011	ENRT ALT	SWALL MEADOWS	Incident ID = 6879916, 0, 0,	A15999
2/6/2015	16:06:36	B72-004	ENRT ALT	SWALL MEADOWS	Incident ID = 6879916, 0, 0,	A15999
2/6/2015	16:08:10		UserAction		User clicked Exit/Save	A15999
2/6/2015	16:08:15		UserAction		User clicked Exit/Save	A14762
2/6/2015	16:08:42	A72-001	10-97 ALT	LOWER ROCK CREEK/GORGE	Incident ID = 6879916, 0, 0,	A15999
2/6/2015	16:12:46		Read Comment		Comment for Incident 916 was Marked as Read.	A15999
2/6/2015	16:15:19	71-052	10-97 ALT	CROWLEY LAKE COMMUNITY CENTER	Incident ID = 6879916, 0, 0, CROWLEY LAKE COMM CENTER	A15999
2/6/2015	16:15:28		UserAction		User clicked Exit/Save	A15999
2/6/2015	16:19:20		Read Comment		Comment for Incident 916 was Marked as Read.	A15999
2/6/2015	16:19:57	B72-004	10-97 ALT	LRC JSO SWALL	Incident ID = 6879916, 0, 0,	A15999
2/6/2015	16:20:17		UserAction		User clicked Exit/Save	A14762
2/6/2015	16:25:04		UserAction		User clicked Exit/Save	A15999
2/6/2015	16:33:11		UserAction		User clicked Exit/Save	A14762
2/6/2015	16:44:21	B72-004	ENRT ALT	SWALL MEADOWS	Incident ID = 6879916, 0, 0,	A15999
2/6/2015	16:45:44	A72-011	10-97 ALT	SWALL MEADOWS	Incident ID = 6879916, 0, 0,	A15999
2/6/2015	16:45:44	A72-003	10-97 ALT	SWALL MEADOWS	Incident ID = 6879916, 0, 0,	A15999
2/6/2015	16:47:07		Read Comment		Comment for Incident 916 was Marked as Read.	A15999
2/6/2015	16:47:17		UserAction		User clicked Exit/Save	A15999
2/6/2015	16:48:47		UserAction		User clicked Exit/Save	A14762
2/6/2015	17:04:27	71-052	10-8	CROWLEY LAKE COMMUNITY CENTER		A14762
2/6/2015	17:05:14		UserAction		User clicked Exit/Save	A14762
2/6/2015	17:07:27		Read Comment		Comment for Incident 916 was Marked as Read.	A15999
2/6/2015	17:07:56		UserAction		User clicked Exit/Save	A15999
2/6/2015	17:12:15		UserAction		User clicked Exit/Save	A15999
2/6/2015	17:20:46	C72-001	ASSIGN	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Response Number (02062015-0000730)	A15999
2/6/2015	17:20:46	C72-001	ENRT	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Responding From = Gorge Rd\US395	A15999
2/6/2015	17:20:46	C72-001	10-97	0 Us395		A15999
2/6/2015	17:37:55	71-S1	ReAssign Vehicle	NB 395 BOTTOM OF SHERWIN GRADE	ReAssign Reason: RU-Reassign Unit	A15999
2/6/2015	17:37:55		ReAssign Response	NB 395 BOTTOM OF SHERWIN GRADE	Clearing Primary Vehicle Flag	A15999
2/6/2015	17:43:44		Read Comment		Comment for Incident 916 was Marked as Read.	A15999
2/6/2015	17:44:40		UserAction		User clicked Exit/Save	A15999
2/6/2015	17:52:27	71-S1	ASSIGN	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Response Number (02062015-0000732)	A15999
2/6/2015	17:52:27	71-S1	ENRT	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Responding From = US395 / CROWLEY O/C [SB JNO O/CROSS]	A15999
2/6/2015	17:53:23	C72-001	10-97 ALT	1184 LRC/ GORGE	Incident ID = 6879916, 0, 0,	A15999
2/6/2015	17:55:09		Read Comment		Comment for Incident 916 was Marked as Read.	A15999
2/6/2015	17:55:46		UserAction		User clicked Exit/Save	A14762
2/6/2015	17:55:49		UserAction		User clicked Exit/Save	A15999
2/6/2015	17:56:23	C72-003	ASSIGN	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Response Number (02062015-0000733)	A14762
2/6/2015	17:58:02		Read Comment		Comment for Incident 916 was Marked as Read.	A15999
2/6/2015	18:03:51		UserAction		User clicked Exit/Save	A14762
2/6/2015	18:05:43	A72-011	ENRT ALT	1148X F/ LOWER ROCK	Incident ID = 6879916, 0, 0,	A14762

2/6/2015	18:14:25	A72-011 10-97 ALT	CRK 395 TO SWALL FOR HORSE EVACUTATION SM/24565 1148X F/ LOWER ROCK	Incident ID = 6879916, 0, 0,	A14762
2/6/2015	18:15:28	UserAction		User clicked Exit/Save	A15999
2/6/2015	18:16:29	B72-004 ENRT ALT	LRC/SWALL	Incident ID = 6879916, 0, 0,	A15999
2/6/2015	18:21:46	B72-004 10-97 ALT	LRC/SWALL	Incident ID = 6879916, 0, 0, 72-4 WITH MONO SO	A15999
2/6/2015	18:22:42	C72-003 ENRT ALT	US395/LRC NORTH	Incident ID = 6879916, 0, 0,	A15999
2/6/2015	18:22:46	UserAction		User clicked Exit/Save	A14762
2/6/2015	18:29:26	C72-011 ASSIGN	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Response Number (02062015-0000734)	A15999
2/6/2015	18:29:26	C72-011 ENRT	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Responding From = Bishop	A15999
2/6/2015	18:29:30	C72-011 10-97 ALT	LRC/395 NORTH	Incident ID = 6879916, 0, 0,	A15999
2/6/2015	18:29:43	C72-009 ASSIGN	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Response Number (02062015-0000735)	A15999
2/6/2015	18:29:43	C72-009 ENRT	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Responding From = Bishop	A15999
2/6/2015	18:29:56	C72-009 ENRT ALT	LRC/SWALL	Incident ID = 6879916, 0, 0,	A15999
2/6/2015	18:30:54	Read Comment		Comment for Incident 916 was Marked as Read.	A15999
2/6/2015	18:35:46	UserAction		User clicked Exit/Save	A15999
2/6/2015	18:35:50	UserAction		User clicked Exit/Save	A15999
2/6/2015	18:37:26	C72-009 10-97 ALT	LRC/SWALL	Incident ID = 6879916, 0, 0,	A15999
2/6/2015	18:37:58	A72-001 10-8	LOWER ROCK CRK / CO LINE		A15999
2/6/2015	18:39:42	72-C 10-8	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]		A14762
2/6/2015	18:41:38	71-S1 10-97	0 Us395		A15999
2/6/2015	18:43:43	B72-004 10-8	LRC/SWALL		A14762
2/6/2015	18:45:28	UserAction		User clicked Exit/Save	A15999
2/6/2015	19:04:43	A72-003 10-8	SWALL MEADOWS		A14762
2/6/2015	19:05:41	A72-011 10-8	1148X F/ LOWER ROCK CRK 395 TO SWALL FOR HORSE EVACUTATION SM/24565		A15885
2/6/2015	19:15:41	Read Comment		Comment for Incident 916 was Marked as Read.	A15885
2/6/2015	19:16:03	UserAction		User clicked Exit/Save	A15885
2/6/2015	19:24:08	UserAction		User clicked Exit/Save	A15885
2/6/2015	19:38:43	C72-009 ENRT ALT	LOWER ROCK CREEK & US395	Incident ID = 6879916, 0, 0,	A15885
2/6/2015	19:41:55	Read Comment		Comment for Incident 916 was Marked as Read.	A15885
2/6/2015	19:42:07	UserAction		User clicked Exit/Save	A15885
2/6/2015	19:51:03	C72-009 10-97 ALT	LOWER ROCK CREEK & US395	Incident ID = 6879916, 0, 0,	A14762
2/6/2015	19:57:20	C72-011 ENRT ALT	LOWER ROCK CREEK & US395	Incident ID = 6879916, 0, 0,	A15885
2/6/2015	19:57:22	C72-011 10-97 ALT	LOWER ROCK CREEK & US395	Incident ID = 6879916, 0, 0,	A15885
2/6/2015	20:13:56	UserAction		User clicked Exit/Save	A14762
2/6/2015	20:17:09	C72-011 ENRT ALT	OFC	Incident ID = 6879916, 0, 0,	A14762
2/6/2015	20:26:36	C72-011 10-97 ALT	OFC	Incident ID = 6879916, 0, 0,	A14762
2/6/2015	20:26:42	UserAction		User clicked Exit/Save	A14762
2/6/2015	20:47:04	C72-003 ENRT ALT	ENRT OFC FOR MORE EXTENDERS	Incident ID = 6879916, 0, 0,	A14762
2/6/2015	20:47:24	Read Comment		Comment for Incident 916 was Marked as Read.	A15885
2/6/2015	20:50:36	UserAction		User clicked Exit/Save	A15885
2/6/2015	20:57:57	B72-004 ASSIGN	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Response Number (02062015-0000737)	A15885
2/6/2015	20:57:57	B72-004 10-97 ALT	1184 LRC/ GORGE	Incident ID = 6879916, 0, 0,	A15885
2/6/2015	20:57:57	C72-001 Unit Backed up	1184 LRC/ GORGE	Backed up with B72-004	A15885
2/6/2015	20:58:45	Read Comment		Comment for Incident 916 was Marked as Read.	A15885
2/6/2015	20:58:47	UserAction		User clicked Exit/Save	A15885
2/6/2015	21:01:25	Read Comment		Comment for Incident 916 was Marked as Read.	A15885

2/6/2015	21:03:07	C72-003	ENRT	ENRT OFC FOR MORE EXTENDERS	Responding From = Lower Rock Creek Rd\US395 S LOWER ROCK CREEK RD OFR	A15885
2/6/2015	21:03:10	C72-003	10-97	0 Us395		A15885
2/6/2015	21:03:14	71-051	ASSIGN	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Response Number (02062015-0000738)	A15885
2/6/2015	21:03:14	71-051	10-97	0 Us395		A15885
2/6/2015	21:03:14	C72-003	Unit Backed up	NB 395 BOTTOM OF SHERWIN GRADE	Backed up with 71-051	A15885
2/6/2015	21:08:23		Read Comment		Comment for Incident 916 was Marked as Read.	A15885
2/6/2015	21:10:33		UserAction		User clicked Exit/Save	A15885
2/6/2015	21:29:05	71-S1	10-8	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]		A15885
2/6/2015	21:30:10		UserAction		User clicked Exit/Save	A15885
2/6/2015	21:35:32	71-051	10-8	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]		A15885
2/6/2015	21:45:20	71-052	ASSIGN	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Response Number (02062015-0000739)	A15885
2/6/2015	21:45:20	71-052	10-97 ALT	1184 LRC/ GORGE	Incident ID = 6879916, 0, 0,	A15885
2/6/2015	21:45:20	C72-001	Unit Backed up	1184 LRC/ GORGE	Backed up with 71-052	A15885
2/6/2015	21:59:07	B72-004	ENRT ALT	NB395 AT GORGE RD	Incident ID = 6879916, 0, 0,	A15885
2/6/2015	21:59:08	B72-004	10-97 ALT	NB395 AT GORGE RD	Incident ID = 6879916, 0, 0,	A15885
2/6/2015	22:00:30		Read Comment		Comment for Incident 916 was Marked as Read.	A15885
2/6/2015	22:01:29	C72-011	ENRT ALT	SB395 TOMS PLACE	Incident ID = 6879916, 0, 0,	A15885
2/6/2015	22:01:32	C72-011	10-97 ALT	SB395 TOMS PLACE	Incident ID = 6879916, 0, 0,	A15885
2/6/2015	22:01:35		UserAction		User clicked Exit/Save	A15885
2/6/2015	22:06:13	C72-003	ENRT ALT	395/CROWLEY	Incident ID = 6879916, 0, 0,	A14762
2/6/2015	22:06:21	C72-009	ENRT ALT	395 / CROWLEY	Incident ID = 6879916, 0, 0,	A14762
2/6/2015	22:06:30		UserAction		User clicked Exit/Save	A14762
2/6/2015	22:07:53		Read Comment		Comment for Incident 916 was Marked as Read.	A15885
2/6/2015	22:08:37		UserAction		User clicked Exit/Save	A15885
2/6/2015	22:08:46		UserAction		User clicked Exit/Save	A14762
2/6/2015	22:12:12		UserAction		User clicked Exit/Save	A14762
2/6/2015	22:18:05		UserAction		User clicked Exit/Save	A15885
2/6/2015	22:34:37		Update IsConfidential	0 Us395	Updated IsConfidential to True for Response_Comment record 27547181	A14762
2/6/2015	22:35:37		Read Comment		Comment for Incident 916 was Marked as Read.	A15885
2/6/2015	22:38:04		UserAction		User clicked Exit/Save	A15885
2/6/2015	22:39:36		UserAction		User clicked Exit/Save	A14762
2/6/2015	22:45:49		UserAction		User clicked Exit/Save	A15900
2/6/2015	22:46:01		Read Comment		Comment for Incident 916 was Marked as Read.	A15885
2/6/2015	22:46:18		UserAction		User clicked Exit/Save	A15900
2/6/2015	22:47:25	C72-011	ENRT ALT	SB395 CROWLEY LAKE O/PASS	Incident ID = 6879916, 0, 0,	A15885
2/6/2015	22:47:27	C72-011	10-97 ALT	SB395 CROWLEY LAKE O/PASS	Incident ID = 6879916, 0, 0,	A15885
2/6/2015	22:48:28		UserAction		User clicked Exit/Save	A15885
2/6/2015	22:49:03		Read Comment		Comment for Incident 916 was Marked as Read.	A15885
2/6/2015	22:49:11		UserAction		User clicked Exit/Save	A15885
2/6/2015	22:49:19		UserAction		User clicked Exit/Save	A15885
2/6/2015	22:51:39		UserAction		User clicked Exit/Save	A15900
2/6/2015	22:52:03	72-S2	10-97 ALT	US395 / CROWLEY	Incident ID = 6879916, 0, 0,	A15900
2/6/2015	22:53:37	72-C	ASSIGN	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Response Number (02062015-0000740)	A15900
2/6/2015	22:53:48	72-C	10-97 ALT	CROWLEY / 395	Incident ID = 6879916, 0, 0,	A15900
2/6/2015	22:53:56	C72-003	10-97 ALT	395/CROWLEY	Incident ID = 6879916, 0, 0,	A15900
2/6/2015	22:53:56	C72-009	10-97 ALT	395 / CROWLEY	Incident ID = 6879916, 0, 0,	A15900
2/6/2015	22:54:11	72-C	ReAssign Vehicle	NB 395 BOTTOM OF SHERWIN GRADE	ReAssign Reason: RU-Reassign Unit	A15900
2/6/2015	22:54:11		ReAssign Response	NB 395 BOTTOM OF SHERWIN GRADE	Clearing Primary Vehicle Flag	A15900
2/6/2015	22:54:14	72-C	ASSIGN	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]	Response Number (02062015-0000741)	A15900
2/6/2015	22:54:20	72-C	ENRT ALT	395 / CROWLEY	Incident ID = 6879916, 0, 0,	A15900
2/6/2015	22:55:11		UserAction		User clicked Exit/Save	A15900
2/6/2015	22:55:11		Read Comment		Comment for Incident 916 was Marked as Read.	A15885

2/6/2015	22:58:47		UserAction		User clicked Exit/Save	A15885
2/6/2015	22:59:25	72-C	ENRT ALT	NB395 GORGE	Incident ID = 6879916, 0, 0,	A15885
2/6/2015	22:59:26	72-C	10-97 ALT	NB395 GORGE	Incident ID = 6879916, 0, 0,	A15885
2/6/2015	23:04:21		Read Comment		Comment for Incident 916 was Marked as Read.	A15885
2/6/2015	23:04:24		UserAction		User clicked Exit/Save	A15885
2/6/2015	23:05:17		UserAction		User clicked Exit/Save	A15900
2/6/2015	23:07:46	72-S2	10-97 ALT	US395 / CROWLEY	Incident ID = 6879916, 0, 0,	A15900
2/6/2015	23:13:45	C72-011	Change Unit Priority		Change Unit Priority from 4 to 7	A15900
2/6/2015	23:13:45	C72-009	Change Unit Priority		Change Unit Priority from 4 to 7	A15900
2/6/2015	23:13:45	B72-004	Change Unit Priority		Change Unit Priority from 4 to 7	A15900
2/6/2015	23:13:45	71-052	Change Unit Priority		Change Unit Priority from 4 to 7	A15900
2/6/2015	23:13:45	72-C	Change Unit Priority		Change Unit Priority from 4 to 7	A15900
2/6/2015	23:13:45		Incident Priority Change		Incident priority changed from 4 to 7 due to Additional Info	A15900
2/6/2015	23:13:46		Read Comment		Comment for Incident 916 was Marked as Read.	A15885
2/6/2015	23:14:43		Sector Change		From Sector No Sector to Sector 72	A15900
2/6/2015	23:14:45		UserAction		User clicked Exit/Save	A15900
2/6/2015	23:18:43		UserAction		User clicked Exit/Save	A15900
2/6/2015	23:24:58		UserAction		User clicked Exit/Save	A15900
2/6/2015	23:33:20		UserAction		User clicked Exit/Save	A15885
2/6/2015	23:36:12	71-052	10-8	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]		A15900
2/6/2015	23:43:06		Update IsConfidential	US395 GORGE TO CROWLEY	Updated IsConfidential to True for Response_Comment record 27548462	A15900
2/6/2015	23:43:08		UserAction		User clicked Exit/Save	A15900
2/6/2015	23:49:38	C72-003	ENRT ALT	LOWER ROCK CREEK / 395	Incident ID = 6879916, 0, 0,	A15900
2/6/2015	23:51:25		UserAction		User clicked Exit/Save	A15900
2/7/2015	00:06:36	C72-009	10-8	395 / CROWLEY		A15900
2/7/2015	00:09:38		UserAction		User clicked Exit/Save	A15900
2/7/2015	00:16:39	C72-003	10-97 ALT	LOWER ROCK CREEK / 395	Incident ID = 6879916, 0, 0,	A15900
2/7/2015	00:22:47	72-C	10-8	NB395 GORGE		A15900
2/7/2015	00:40:27	B72-004	10-8	NB395 AT GORGE RD		A15900
2/7/2015	01:29:05		UserAction		User clicked Exit/Save	A15900
2/7/2015	02:07:44		UserAction		User clicked Cancel	A16245
2/7/2015	02:08:02		UserAction		User clicked Exit/Save	A16245
2/7/2015	02:23:22	C72-009	ASSIGN	US395 GORGE TO CROWLEY [NB 395 BOTTOM OF SHERWIN GRADE]	Response Number (02072015-0000742)	A15900
2/7/2015	02:23:23	C72-009	ENRT	US395 GORGE TO CROWLEY [NB 395 BOTTOM OF SHERWIN GRADE]	Responding From = OFC FOR FUEL	A15900
2/7/2015	02:23:23	C72-009	10-97	US395 GORGE TO CROWLEY		A15900
2/7/2015	02:43:17	72-S2	10-8	0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]		A15900
2/7/2015	02:56:38	72-S2	ASSIGN	US395 GORGE TO CROWLEY [NB 395 BOTTOM OF SHERWIN GRADE]	Response Number (02072015-0000743)	A15900
2/7/2015	02:56:38	72-S2	ENRT	US395 GORGE TO CROWLEY [NB 395 BOTTOM OF SHERWIN GRADE]	Responding From = Bishop	A15900
2/7/2015	02:56:38	72-S2	10-97	US395 GORGE TO CROWLEY		A15900
2/7/2015	03:06:17		Read Comment		Comment for Incident 916 was Marked as Read.	A15900
2/7/2015	03:19:59		UserAction		User clicked Exit/Save	A15900
2/7/2015	03:31:21		Read Comment		Comment for Incident 916 was Marked as Read.	A15900
2/7/2015	03:33:15		UserAction		User clicked Exit/Save	A15900
2/7/2015	04:20:26	72-S2	10-8	US395 GORGE TO CROWLEY [NB 395 BOTTOM OF SHERWIN GRADE]		A15900
2/7/2015	04:28:25		UserAction		User clicked Exit/Save	A15900
2/7/2015	04:31:06		UserAction		User clicked Exit/Save	A15885

2/7/2015	04:44:23	C72-009 10-97 ALT		LOWER ROCK CREEK / US395	Incident ID = 6879916, 0, 0,	A15900
2/7/2015	04:44:23	C72-011 10-97 ALT		LOWER ROCK CREEK / US395	Incident ID = 6879916, 0, 0,	A15900
2/7/2015	05:24:26	C72-001 10-8		0 Us395 [NB 395 BOTTOM OF SHERWIN GRADE]		A15900
2/7/2015	05:35:08	C72-009 10-8		US395 GORGE TO CROWLEY [NB 395 BOTTOM OF SHERWIN GRADE]		A15900
2/7/2015	05:40:21		Read Comment		Comment for Incident 916 was Marked as Read.	A15900
2/7/2015	05:40:48		UserAction		User clicked Exit/Save	A15900
2/7/2015	05:41:10		UserAction		User clicked Exit/Save	A15900
2/7/2015	06:14:08	A72-001 ASSIGN		0 Lower Rock Creek Rd	Response Number (02072015-0000744)	A15900
2/7/2015	06:14:18	A72-001 10-97 ALT		LOWER ROCK CREEK / GORGE	Incident ID = 6879916, 0, 0,	A15900
2/7/2015	06:15:51	A72-011 ASSIGN		0 Lower Rock Creek Rd	Response Number (02072015-0000745)	A15900
2/7/2015	06:16:01	A72-011 10-97 ALT		LOWER ROCK / US395	Incident ID = 6879916, 0, 0,	A15900
2/7/2015	06:16:08	C72-011 10-8		SB395 CROWLEY LAKE O/PASS		A15900
2/7/2015	06:27:38	C72-003 10-8		LOWER ROCK CREEK / 395		A15900
2/7/2015	06:41:13	72-S3 ASSIGN		0 Lower Rock Creek Rd	Response Number (02072015-0000746)	A15900
2/7/2015	06:41:38	72-S3 ENRT ALT		OWENS VALLEY PRISON CAMP FOR BRIEFING	Incident ID = 6879916, 0, 0,	A15900
2/7/2015	06:41:42	72-S3 10-97 ALT		OWENS VALLEY PRISON CAMP FOR BRIEFING	Incident ID = 6879916, 0, 0,	A15900
2/7/2015	06:42:23	A72-003 ASSIGN		0 Lower Rock Creek Rd	Response Number (02072015-0000747)	A15900
2/7/2015	06:42:31	A72-003 10-97 ALT		US395 / LOWER ROCK	Incident ID = 6879916, 0, 0,	A15900
2/7/2015	06:59:30		Read Comment		Comment for Incident 916 was Marked as Read.	A15127
2/7/2015	07:04:35		Update IsConfidential	0 Lower Rock Creek Rd	Updated IsConfidential to True for Response_Comment record 27554187	A15999
2/7/2015	07:05:25		Read Comment		Comment for Incident 916 was Marked as Read.	A15127
2/7/2015	07:05:38		UserAction		User clicked Exit/Save	A15999
2/7/2015	07:11:26		UserAction		User clicked Exit/Save	A15999
2/7/2015	07:18:04		Update IsConfidential	0 Lower Rock Creek Rd	Updated IsConfidential to True for Response_Comment record 27535795	A15999
2/7/2015	07:21:25		UserAction		User clicked Exit/Save	A15127
2/7/2015	07:23:18		UserAction		User clicked Exit/Save	A15999
2/7/2015	07:26:21		Read Comment		Comment for Incident 916 was Marked as Read.	A15999
2/7/2015	07:26:26		UserAction		User clicked Exit/Save	A15999
2/7/2015	08:43:58		UserAction		User clicked Exit/Save	A15127
2/7/2015	08:49:58	72-S3 10-8		OWENS VALLEY PRISON CAMP FOR BRIEFING		A15127
2/7/2015	09:20:27		Read Comment		Comment for Incident 916 was Marked as Read.	A15999
2/7/2015	09:21:00		UserAction		User clicked Exit/Save	A15999
2/7/2015	09:39:03		UserAction		User clicked Exit/Save	A15999
2/7/2015	11:53:42	72-S2 ASSIGN		0 Lower Rock Creek Rd	Response Number (02072015-0000750)	A15127
2/7/2015	11:53:42	72-S2 ENRT ALT		LOWER ROCK CREEK / GORGE	Incident ID = 6879916, 0, 0,	A15127
2/7/2015	11:53:42	A72-001 Unit Backed up		LOWER ROCK CREEK / GORGE	Backed up with 72-S2	A15127
2/7/2015	12:13:32		Read Comment		Comment for Incident 916 was Marked as Read.	A15999
2/7/2015	12:14:11		UserAction		User clicked Exit/Save	A15999
2/7/2015	12:37:32		Read Comment		Comment for Incident 916 was Marked as Read.	A15999
2/7/2015	12:37:36		UserAction		User clicked Exit/Save	A15999
2/7/2015	12:44:38		UserAction		User clicked Exit/Save	A15999
2/7/2015	12:51:36		UserAction		User clicked Exit/Save	A15127
2/7/2015	14:16:23		Read Comment		Comment for Incident 916 was Marked as Read.	A15999
2/7/2015	14:21:26	72-S2 ENRT ALT		ENRT CDF CAMP	Incident ID = 6879916, 0, 0,	A15127
2/7/2015	14:22:36		Update IsConfidential	0 Lower Rock Creek Rd	Updated IsConfidential to True for Response_Comment record 27563354	A15999
2/7/2015	14:22:54		Update IsConfidential	0 Lower Rock Creek Rd	Updated IsConfidential to True for Response_Comment record 27563358	A15999
2/7/2015	14:23:07		Update IsConfidential	0 Lower Rock Creek Rd	Updated IsConfidential to True for	A15999

					Response_Comment record 27563359	
2/7/2015	14:24:21		UserAction		User clicked Exit/Save	A15999
2/7/2015	15:38:30		Read Comment		Comment for Incident 916 was Marked as Read.	A15885
2/7/2015	15:38:41		UserAction		User clicked Exit/Save	A15885
2/7/2015	15:39:10		UserAction		User clicked Exit/Save	A15885
2/7/2015	15:44:14	72-S2	10-8	ENRT CDF CAMP		A15127
2/7/2015	16:23:41		UserAction		User clicked Exit/Save	A15885
2/7/2015	16:31:19		UserAction		User clicked Exit/Save	A15885
2/7/2015	18:03:53	A72-001	10-8	0 Lower Rock Creek Rd		A15127
2/7/2015	18:20:15	C72-011	ASSIGN	0 Lower Rock Creek Rd	Response Number (02072015-0000760)	A15885
2/7/2015	18:20:15	C72-011	ENRT ALT	LOWER ROCK / US395	Incident ID = 6879916, 0, 0,	A15885
2/7/2015	18:20:15	A72-011	Unit Backed up	LOWER ROCK / US395	Backed up with C72-011	A15885
2/7/2015	18:26:41	B72-004	ASSIGN	0 Lower Rock Creek Rd	Response Number (02072015-0000761)	A15885
2/7/2015	18:26:41	B72-004	10-97 ALT	US395 / LOWER ROCK	Incident ID = 6879916, 0, 0,	A15885
2/7/2015	18:26:41	A72-003	Unit Backed up	US395 / LOWER ROCK	Backed up with B72-004	A15885
2/7/2015	18:27:28	B72-004	ENRT ALT	ROCK CREEK & 395	Incident ID = 6879916, 0, 0,	A15885
2/7/2015	18:27:29	B72-004	10-97 ALT	ROCK CREEK & 395	Incident ID = 6879916, 0, 0,	A15885
2/7/2015	18:29:56	C72-009	ASSIGN	0 Lower Rock Creek Rd	Response Number (02072015-0000762)	A15127
2/7/2015	18:29:56	C72-009	ENRT ALT	ROCK CREEK & 395	Incident ID = 6879916, 0, 0,	A15127
2/7/2015	18:29:56	B72-004	Unit Backed up	ROCK CREEK & 395	Backed up with C72-009	A15127
2/7/2015	18:30:08	C72-009	ENRT ALT	ENRT LOWER CLOSURE	Incident ID = 6879916, 0, 0,	A15127
2/7/2015	18:35:15	C72-011	10-97 ALT	LOWER ROCK / US395	Incident ID = 6879916, 0, 0,	A15885
2/7/2015	18:42:40	C72-009	ENRT ALT	LOWER ROCK / GORGE	Incident ID = 6879916, 0, 0,	A15885
2/7/2015	18:42:42	C72-009	10-97 ALT	LOWER ROCK / GORGE	Incident ID = 6879916, 0, 0,	A15885
2/7/2015	18:42:50	C72-011	ENRT ALT	LOWER ROCK / GORGE	Incident ID = 6879916, 0, 0,	A15885
2/7/2015	18:42:54	C72-011	10-97 ALT	LOWER ROCK / GORGE	Incident ID = 6879916, 0, 0,	A15885
2/7/2015	18:51:22	A72-003	10-8	0 Lower Rock Creek Rd		A15900
2/7/2015	19:01:02		UserAction		User clicked Exit/Save	A15900
2/7/2015	19:04:40	A72-011	10-8	0 Lower Rock Creek Rd		A15900
2/7/2015	19:19:00	C72-011	10-8	LOWER ROCK / GORGE		A15900
2/7/2015	19:19:35	B72-004	10-8	ROCK CREEK & 395		A15900
2/7/2015	19:19:40	C72-011	ASSIGN	0 Lower Rock Creek Rd	Response Number (02072015-0000765)	A15900
2/7/2015	19:19:48	C72-011	10-97 ALT	LOWER ROCK / 395	Incident ID = 6879916, 0, 0,	A15900
2/8/2015	01:22:24		Read Comment		Comment for Incident 916 was Marked as Read.	A15900
2/8/2015	01:22:29		UserAction		User clicked Exit/Save	A15900
2/8/2015	05:05:50		UserAction		User clicked Exit/Save	A15900
2/8/2015	06:01:48	A72-003	ASSIGN	0 Lower Rock Creek Rd	Response Number (02082015-0000772)	A15900
2/8/2015	06:02:53	A72-003	ENRT ALT	US395 / GORGE	Incident ID = 6879916, 0, 0,	A15900
2/8/2015	06:13:03	A72-003	10-97 ALT	US395 / GORGE	Incident ID = 6879916, 0, 0,	A15900
2/8/2015	06:18:12	C72-009	10-8	LOWER ROCK / GORGE		A15900
2/8/2015	06:18:24	72-S2	ASSIGN	0 Lower Rock Creek Rd	Response Number (02082015-0000773)	A15900
2/8/2015	06:18:55	72-S2	ENRT ALT	MORNING BRIEFING / FIRE CAMP	Incident ID = 6879916, 0, 0,	A15900
2/8/2015	06:27:00	A72-001	ASSIGN	0 Lower Rock Creek Rd	Response Number (02082015-0000774)	A15900
2/8/2015	06:27:07	A72-001	10-97 ALT	US395 / LOWER ROCK CREEK	Incident ID = 6879916, 0, 0,	A15900
2/8/2015	06:28:56	C72-011	10-8	0 Lower Rock Creek Rd		A15900
2/8/2015	07:09:13		Read Comment		Comment for Incident 916 was Marked as Read.	A15999
2/8/2015	07:11:36		UserAction		User clicked Exit/Save	A15999
2/8/2015	07:41:00	72-S2	10-97 ALT	MORNING BRIEFING / FIRE CAMP	Incident ID = 6879916, 0, 0,	A15999
2/8/2015	07:41:06	72-S2	10-8	MORNING BRIEFING / FIRE CAMP		A15999
2/8/2015	11:04:43		Read Comment		Comment for Incident 916 was Marked as Read.	A15999
2/8/2015	11:23:21		UserAction		User clicked Exit/Save	A15999
2/8/2015	11:27:42		Read Comment		Comment for Incident 916 was Marked as Read.	A15999
2/8/2015	12:03:15		UserAction		User clicked Exit/Save	A15999
2/8/2015	13:13:31	A72-001	ReAssign Vehicle	0 Lower Rock Creek Rd	ReAssign Reason: RU-Reassign Unit	A13927
2/8/2015	13:13:31		ReAssign Response	0 Lower Rock Creek Rd	Clearing Primary Vehicle Flag	A13927
2/8/2015	13:13:31	B72-004	ASSIGN	0 Lower Rock Creek Rd	Response Number (02082015-0000782)	A13927
2/8/2015	13:13:37	B72-004	10-97	0 Lower Rock Creek Rd		A13927
2/8/2015	13:13:53		Read Comment		Comment for Incident 916 was Marked as Read.	A15999
2/8/2015	13:20:00		UserAction		User clicked Exit/Save	A15999
2/8/2015	13:38:14	A72-003	ReAssign Vehicle	0 Lower Rock Creek Rd	ReAssign Reason: RU-Reassign Unit	A15999
2/8/2015	13:38:14		ReAssign Response	0 Lower Rock Creek Rd	Clearing Primary Vehicle Flag	A15999
2/8/2015	13:38:38		UserAction		User clicked Cancel	A15999
2/8/2015	13:39:09	B72-004	ReAssign Vehicle	0 Lower Rock Creek Rd	ReAssign Reason: RU-Reassign Unit	A15999

2/8/2015	13:39:09	ReAssign Response	0 Lower Rock Creek Rd	Clearing Primary Vehicle Flag	A15999
2/8/2015	13:39:09	ReAssign Response	0 Lower Rock Creek Rd		A15999
2/8/2015	13:39:14	Read Comment		Comment for Incident 916 was Marked as Read.	A15999
2/8/2015	13:39:18	UserAction		User clicked Cancel	A15999
2/8/2015	13:39:24	Cancel Response	0 Lower Rock Creek Rd	Cancellation Reason: RD-Radio Desk, Response Disposition: F-File	A15999
2/8/2015	15:22:04	UserAction		User clicked Exit/Save	A15900
2/8/2015	15:22:08	Incident Reopen		Incident 150206BI00071 was reopened.	A15900
2/8/2015	15:22:17	Cancel Response	0 Lower Rock Creek Rd	Cancellation Reason: UX-Cancel, Response Disposition: DUP-Duplicate Call	A15900
2/8/2015	15:22:17	Append Incident		Incident closed, Appended to Inc [150208BI00054]	A15900
2/8/2015	15:22:17	Link Incident		LINK: [150206BI00071] to [150208BI00054] because [150206BI00071] appends to [150208BI00054]	A15900

Edit Log

Date	Time	Field	Changed From	Changed To	Reason	Table	Workstation	User
2/6/2015	14:02:08	Call_Back_Phone		(760) 914-1606	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:02:11	Address	(Blank)	(Blank)	New Entry	Response_Master_Incident	BI001	A11053
2/6/2015	14:02:12	Address	(Blank)	0 US395	New Entry	Response_Master_Incident	BI001	A11053
2/6/2015	14:02:12	Address		0 US395	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:02:12	City		Mesa	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:02:12	State		CA	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:02:12	Postal_Code		93514	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:02:12	Latitude	0	37429544	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:02:12	Longitude	0	118562065	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:02:12	Street_Id	NULL	26077	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:02:12	Cross_Street		MM395/MM395	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:02:12	County		Inyo	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:02:12	Jurisdiction		BI	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:02:12	Division		.72-Bishop	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:02:12	Battalion		72-Bishop	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:02:12	Response_Area		72-1	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:02:19	Problem		FIRE-Report of Fire	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:02:19	Priority_Description		4		Response_Master_Incident	BI001	A11053
2/6/2015	14:02:19	Priority_Number	0	4		Response_Master_Incident	BI001	A11053
2/6/2015	14:02:19	Incident_Type		1 CHP Unit Incident	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:02:57	Location_Name		NB 395	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:03:03	Caller_Name		KEN	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:03:17	Location_Name	NB 395	NB 395 BOTTOM OF SHERWIN GRADE	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:03:41	Caller_Type		Passing Motorist	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:10:50	Read Call	False	True	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:10:50	Read Comment	False	True	(Response Viewer)	Response_Master_Incident	BI001	A11053
2/6/2015	14:22:29	IsConfidential	False	True	Change	IncidentComment	BI001	A11053

2/6/2015 14:49:39	Read Comment	False	True	Confidential Comment (Response Viewer)	Response_Master_Incident BI001	A11053
2/6/2015 15:01:00	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15999
2/6/2015 15:51:18	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15999
2/6/2015 16:04:31	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15999
2/6/2015 16:12:46	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15999
2/6/2015 16:19:20	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15999
2/6/2015 16:47:07	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15999
2/6/2015 17:07:27	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15999
2/6/2015 17:43:44	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15999
2/6/2015 17:55:09	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15999
2/6/2015 17:58:02	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15999
2/6/2015 18:30:54	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15999
2/6/2015 19:15:41	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15885
2/6/2015 19:41:55	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15885
2/6/2015 20:47:24	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15885
2/6/2015 20:58:45	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15885
2/6/2015 21:01:25	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15885
2/6/2015 21:08:23	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15885
2/6/2015 22:00:30	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15885
2/6/2015 22:07:53	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15885
2/6/2015 22:34:37	IsConfidential	False	True	Change Confidential Comment	IncidentComment BI002	A14762
2/6/2015 22:35:37	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15885
2/6/2015 22:46:01	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15885
2/6/2015 22:49:03	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15885
2/6/2015 22:55:11	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15885
2/6/2015 23:04:21	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI001	A15885
2/6/2015 23:13:45	Current_UnitRespPrC72-011: 4 iorityDesc		7	Additional Info	Response_Vehicles_AssignBI002	A15900
2/6/2015 23:13:45	Current_UnitRespPrC72-009: 4 iorityDesc		7	Additional Info	Response_Vehicles_AssignBI002	A15900
2/6/2015 23:13:45	Current_UnitRespPrB72-004: 4 iorityDesc		7	Additional Info	Response_Vehicles_AssignBI002	A15900
2/6/2015 23:13:45	Current_UnitRespPr71-052: 4 iorityDesc		7	Additional Info	Response_Vehicles_AssignBI002	A15900
2/6/2015 23:13:45	Current_UnitRespPr72-C: 4 iorityDesc		7	Additional Info	Response_Vehicles_AssignBI002	A15900
2/6/2015 23:13:45	Problem	FIRE-Report of Fire	CLOSURE of a Road	(Response Viewer)	Response_Master_Incident BI002	A15900
2/6/2015 23:13:45	Priority_Description	4	7	Additional Info	Response_Master_Incident BI002	A15900
2/6/2015 23:13:45	Priority_Number	4	7	Additional Info	Response_Master_Incident BI002	A15900
2/6/2015 23:13:45	Incident_Type	1 CHP Unit Incident	CHP No Response	(Response Viewer)	Response_Master_Incident BI002	A15900

2/6/2015 23:13:46	Read Comment	False	True	(Comment Notification Window)	Response_Master_Incident BI001	A15885
2/6/2015 23:14:03	Address	0 Us395	US395 GORGE TO CROWLEY	Address Change	Response_Master_Incident BI002	A15900
2/6/2015 23:14:16	Address	0 Us395	US395 GORGE TO CROWLEY	Address Change	Response_Master_Incident BI002	A15900
2/6/2015 23:14:27	Address	0 Us395	US395 GORGE TO CROWLEY	(Response Viewer)	Response_Master_Incident BI002	A15900
2/6/2015 23:14:27	Postal_Code	93514		(Response Viewer)	Response_Master_Incident BI002	A15900
2/6/2015 23:14:27	Latitude	37429544	0	(Response Viewer)	Response_Master_Incident BI002	A15900
2/6/2015 23:14:27	Longitude	118562065	0	(Response Viewer)	Response_Master_Incident BI002	A15900
2/6/2015 23:14:27	Street_Id	26077	NULL	(Response Viewer)	Response_Master_Incident BI002	A15900
2/6/2015 23:14:27	Cross_Street	MM395/MM395		(Response Viewer)	Response_Master_Incident BI002	A15900
2/6/2015 23:14:27	Jurisdiction	BI		(Response Viewer)	Response_Master_Incident BI002	A15900
2/6/2015 23:14:27	Division	.72-Bishop		(Response Viewer)	Response_Master_Incident BI002	A15900
2/6/2015 23:14:27	Battalion	72-Bishop		(Response Viewer)	Response_Master_Incident BI002	A15900
2/6/2015 23:14:27	Response_Area	72-1		(Response Viewer)	Response_Master_Incident BI002	A15900
2/6/2015 23:14:27	Address	US395 GORGE TO CROWLEY	US395 GORGE TO CROWLEY	Change Verified	Response_Master_Incident BI002	A15900
2/6/2015 23:14:36	Jurisdiction		BI	(Response Viewer)	Response_Master_Incident BI002	A15900
2/6/2015 23:14:43	Division		.72-Bishop	(Response Viewer)	Response_Master_Incident BI002	A15900
2/6/2015 23:14:43	CurrentDivision		.72-Bishop	(Response Viewer)	Response_Master_Incident BI002	A15900
2/6/2015 23:14:43	HomeSectorID	0	3	(Response Viewer)	Response_Master_Incident BI002	A15900
2/6/2015 23:14:43	CurrentSectorID	0	3	(Response Viewer)	Response_Master_Incident BI002	A15900
2/6/2015 23:14:43	CurrentDivision		.72-Bishop	(Response Viewer)	Response_Master_Incident BI002	A15900
2/6/2015 23:14:44	Battalion		72-Bishop	(Response Viewer)	Response_Master_Incident BI002	A15900
2/6/2015 23:43:06	IsConfidential	False	True	Change Confidential Comment	IncidentComment BI002	A15900
2/7/2015 03:06:17	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI002	A15900
2/7/2015 03:31:21	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI002	A15900
2/7/2015 05:40:21	Read Comment	False	True	(Response Viewer)	Response_Master_Incident BI002	A15900
2/7/2015 05:40:30	Address	US395 GORGE TO CROWLEY	LOWER ROCK CREEK	Address Change	Response_Master_Incident BI002	A15900
2/7/2015 05:40:36	Address	US395 GORGE TO CROWLEY	LOWER ROCK CREEK	Address Change	Response_Master_Incident BI002	A15900
2/7/2015 05:40:41	Address	LOWER ROCK CREEK	0 Lower Rock Creek Rd	Change Verified	Response_Master_Incident BI002	A15900
2/7/2015 05:40:41	Response_Area		72-40	(Response Viewer)	Response_Master_Incident BI002	A15900
2/7/2015 05:40:41	Cross_Street		Old Sherwin Grade Rd/Boundary Rd	(Response Viewer)	Response_Master_Incident BI002	A15900
2/7/2015 05:40:41	Street_Id	NULL	23053	(Response Viewer)	Response_Master_Incident BI002	A15900
2/7/2015 05:40:41	Longitude	0	118592998	(Response Viewer)	Response_Master_Incident BI002	A15900
2/7/2015 05:40:41	Latitude	0	37462964	(Response Viewer)	Response_Master_Incident BI002	A15900
2/7/2015 05:40:41	Postal_Code		93514	(Response Viewer)	Response_Master_Incident BI002	A15900
2/7/2015 05:40:41	City	Mesa	Unincorporated	(Response Viewer)	Response_Master_Incident BI002	A15900

2/7/2015 05:40:41	Address	US395 GORGE TO CROWLEY	0 Lower Rock Creek Rd	(Response Viewer)	Response_Master_Incident	BI002	A15900
2/7/2015 05:40:47	Location_Name	NB 395 BOTTOM OF SHERWIN GRADE		(Response Viewer)	Response_Master_Incident	BI002	A15900
2/7/2015 06:59:30	Read Comment	False	True	(Response Viewer)	Response_Master_Incident	BI002	A15127
2/7/2015 07:04:35	IsConfidential	False	True	Change Confidential Comment	IncidentComment	BI001	A15999
2/7/2015 07:05:25	Read Comment	False	True	(Response Viewer)	Response_Master_Incident	BI002	A15127
2/7/2015 07:18:04	IsConfidential	False	True	Change Confidential Comment	IncidentComment	BI001	A15999
2/7/2015 07:26:21	Read Comment	False	True	(Response Viewer)	Response_Master_Incident	BI001	A15999
2/7/2015 09:20:27	Read Comment	False	True	(Response Viewer)	Response_Master_Incident	BI001	A15999
2/7/2015 12:13:32	Read Comment	False	True	(Response Viewer)	Response_Master_Incident	BI001	A15999
2/7/2015 12:37:32	Read Comment	False	True	(Response Viewer)	Response_Master_Incident	BI001	A15999
2/7/2015 14:16:23	Read Comment	False	True	(Response Viewer)	Response_Master_Incident	BI001	A15999
2/7/2015 14:22:36	IsConfidential	False	True	Change Confidential Comment	IncidentComment	BI001	A15999
2/7/2015 14:22:54	IsConfidential	False	True	Change Confidential Comment	IncidentComment	BI001	A15999
2/7/2015 14:23:07	IsConfidential	False	True	Change Confidential Comment	IncidentComment	BI001	A15999
2/7/2015 15:38:30	Read Comment	False	True	(Response Viewer)	Response_Master_Incident	BI001	A15885
2/8/2015 01:22:24	Read Comment	False	True	(Response Viewer)	Response_Master_Incident	BI001	A15900
2/8/2015 07:09:13	Read Comment	False	True	(Response Viewer)	Response_Master_Incident	BI002	A15999
2/8/2015 11:04:43	Read Comment	False	True	(Response Viewer)	Response_Master_Incident	BI002	A15999
2/8/2015 11:27:42	Read Comment	False	True	(Response Viewer)	Response_Master_Incident	BI002	A15999
2/8/2015 13:13:53	Read Comment	False	True	(Response Viewer)	Response_Master_Incident	BI002	A15999
2/8/2015 13:39:14	Read Comment	False	True	(Response Viewer)	Response_Master_Incident	BI002	A15999
2/8/2015 15:22:17	Call_Disposition	F-File	DUP-Duplicate Call	Reopened Incident	Response_Master_Incident	BI002	A15900
2/8/2015 15:22:17	Cancel_Reason	RD-Radio Desk	UX-Cancel	Reopened Incident	Response_Master_Incident	BI002	A15900
2/8/2015 15:22:17	Time_CallClosed	02/08/2015 13:39:24	Feb 08 2015 15:22:17	Reopened Incident	Response_Master_Incident	BI002	A15900

Custom Time Stamps
 No Custom Time Stamps

Custom Data Fields

Description	Data	User
EMS	BPD	A11053
FIRE	BISFD	A11053
LAW	INYSO	A11053

Attachments
 No Attachment

Incident Detail Report

Data Source: **Data Warehouse**
 Incident Status: **Closed**
 Incident number: **150206BI00079**
 Incident Date: **2/6/2015 14:08:46**
 Last Updated: **2/9/2015 13:00:10**

Incident Information

Incident Type:	1 CHP Unit Incident	Alarm Level:	911 Hang Up
Priority:	5	Problem:	CHP
Determinant:		Agency:	BI
Base Response#:		Jurisdiction:	.72-Bishop
Confirmation#:		Division:	72-Bishop
Taken By:	Nissa Wollum	Battalion:	72-030
Response Area:	72-30	Response Plan:	
Disposition:	F-File	Command Ch:	
Cancel Reason:	SD-Service Desk	Primary TAC:	
Incident Status:	Closed	Secondary TAC:	
Certification:		Delay Reason (if any):	
Longitude:	118632009	Latitude:	37544560

Incident Location

Location Name:	County:
Address:	Mono
1.01 Mi S/o L Rock Crk Rd & 1.64mi E/o Ushwy 3	Location Type:
Apartment:	No Cross Street/No Cross Street
Building:	Map Reference:
City, State, Zip:	Unincorporated CA 93514

Call Receipt

Caller Name:	Call Back Phone:
Method Received:	(760) 914-1971
Caller Type:	Caller Location:
	1.01 MI S/O L ROCK CRK RD & 1.64MI E/O USHWY 3

Time Stamps

Description	Date	Time	User	Elapsed Times Description	Time
Phone Pickup	2/6/2015	14:08:44			
1st Key Stroke	2/6/2015	14:08:44		Received to In Queue	00:00:16
In Waiting Queue	2/6/2015	14:09:02		Call Taking	00:00:17
Call Taking Complete	2/6/2015	14:09:03	Nissa Wollum	In Queue to 1st Assign	
1st Unit Assigned				Call Received to 1st Assign	
1st Unit Enroute				Assigned to 1st Enroute	
1st Unit Arrived				Enroute to 1st Arrived	
Closed	2/6/2015	14:09:03	Nissa Wollum	Incident Duration	00:00:19

Resources Assigned

No Resources Assigned

Personnel Assigned

No Personnel Assigned

Pre-Scheduled Information

No Pre-Scheduled Information

Transports

No Transports Information

Transport Legs

No Transports Information

I declare under penalty of perjury that the document consisting of 3 pages to which this is affixed is (are) a true copy(s) of the original document(s) on file with the Department of California Highway Patrol.

By RICHARD A. SEAVEC
Employee
Title PSDS I

Comments

Date	Time	User	Type	Conf.	Comments
2/6/2015	14:08:59	A15999	Response		[1] BLU ABAN
2/6/2015	14:10:46	SYS	Response		[2] A wireless rebid occurred. A possible phase 2 update is available.

Address Changes

No Address Changes

Priority Changes

No Priority Changes

Alarm Level Changes
No Alarm Level Changes

Activity Log

Date	Time	Radio	Activity	Location	Log Entry	User
2/6/2015	14:08:50		Incident Priority Change		Incident priority changed from <none> to 5	A15999
2/6/2015	14:09:03		ANI/ALI Statistics		INT Insert:Feb 06 2015 14:08:43 / INT SendNP:Feb 06 2015 14:08:42 / WS RecvNP:Feb 06 2015 14:08:43 / WS Process:	A15999
2/6/2015	14:09:03		Cancel Response	1.01 Mi S/o L Rock Crk Rd & 1.64mi E/o Ushwy 3	Cancellation Reason: SD-Service Desk, A15999 Response Disposition: F-File	

Edit Log

Date	Time	Field	Changed From	Changed To	Reason	Table	Workstation User
2/6/2015	14:08:44	Call_Back_Phone		(760) 914-1971	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:08:45	Address	(Blank)	1.01 MI S/O L ROCK CRK RD & 1.64MI E/O USHWY 3	New Entry	Response_Master_IncidentBI003	A15999
2/6/2015	14:08:48	Response_Area		72-30	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:08:48	Battalion		72-Bishop	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:08:48	Division		.72-Bishop	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:08:48	Jurisdiction		BI	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:08:48	County		Mono	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:08:48	Cross_Street		No Cross Street/No Cross Street	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:08:48	Street_Id	NULL	75452	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:08:48	Longitude	0	118632009	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:08:48	Latitude	0	37544560	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:08:48	Postal_Code		93514	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:08:48	State		CA	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:08:48	City		Unincorporated	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:08:48	Address		1.01 MI S/O L ROCK CRK RD & 1.64MI E/O USHWY 3	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:08:48	Address	(Blank)	1.01 MI S/O L ROCK CRK RD & 1.64MI E/O USHWY 3	New Entry	Response_Master_IncidentBI003	A15999
2/6/2015	14:08:50	Incident_Type		1 CHP Unit Incident	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:08:50	Priority_Number	0	5		Response_Master_IncidentBI003	A15999
2/6/2015	14:08:50	Priority_Description		5		Response_Master_IncidentBI003	A15999
2/6/2015	14:08:50	ResponsePlanType	0	1	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:08:50	DispatchLevel		Default	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:08:50	Response_Plan		72-030	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:08:50	Problem		911 Hang Up	(Response Viewer)	Response_Master_IncidentBI003	A15999

Custom Time Stamps
No Custom Time Stamps

Custom Data Fields



Description

EMS
FIRE
LAW

Data

MONO1
MONO1
MNOSO

User

A15999
A15999
A15999

Attachments

No Attachment

Incident Detail Report

Data Source: **Data Warehouse**
 Incident Status: **Closed**
 Incident number: **150206BI00080**
 Incident Date: **2/6/2015 14:13:42**
 Last Updated: **2/9/2015 13:01:28**

Incident Information

Incident Type:	1 CHP Unit Incident	Alarm Level:	FIRE-Report of Fire
Priority:	4	Problem:	CHP
Determinant:		Agency:	BI
Base Response#:		Jurisdiction:	.72-Bishop
Confirmation#:		Division:	72-Bishop
Taken By:	Nissa Wollum	Battalion:	
Response Area:	72-70	Response Plan:	
Disposition:	DUP-Duplicate Call	Command Ch:	
Cancel Reason:	UX-Cancel	Primary TAC:	
Incident Status:	Closed	Secondary TAC:	
Certification:		Delay Reason (if any):	
Longitude:	118624478	Latitude:	37503643

Incident Location

Location Name:	County:
Address:	0 Rimrock Cir
Apartment:	Location Type:
Building:	Unincorporated CA 93514
City, State, Zip:	Cross Street:
	Unnamed Street/No Cross Street
	Map Reference:

Call Receipt

Caller Name:	Call Back Phone:
Method Received:	(760) 567-9688
Caller Type:	Caller Location:

Time Stamps

Description	Date	Time	User	Elapsed Times Description	Time
Phone Pickup	2/6/2015	14:13:40			
1st Key Stroke	2/6/2015	14:13:40		Received to In Queue	00:06:42
In Waiting Queue	2/6/2015	14:20:24		Call Taking	
Call Taking Complete	2/6/2015	14:20:24	Nissa Wollum	In Queue to 1st Assign	
1st Unit Assigned				Call Received to 1st Assign	
1st Unit Enroute				Assigned to 1st Enroute	
1st Unit Arrived				Enroute to 1st Arrived	
Closed	2/6/2015	14:20:41	Nissa Wollum	Incident Duration	00:07:01

Resources Assigned
 No Resources Assigned

Personnel Assigned
 No Personnel Assigned

Pre-Scheduled Information
 No Pre-Scheduled Information

Transports
 No Transports Information

Transport Legs
 No Transports Information

Comments

Date	Time	User	Type	Conf.	Comments
2/6/2015	14:14:08	SYS	Response		[1] A wireless rebid occurred. A possible phase 2 update is available.
2/6/2015	14:20:19	A15999	Response		[2] LATE ENTRY FIRE APPRO PARADISE
2/6/2015	14:20:21	A15999	Response		[3] CONF INTERAGENCY
2/6/2015	14:20:41	A15999	Response		[4] LINK: [150206BI00080] to [150206BI00071] because [150206BI00080] appends to [150206BI00071]
2/6/2015	23:13:45	A15900	Response		[5] [Notification] [CHP]-Problem changed from FIRE-Report of Fire to CLOSURE of a Road by CHP [Shared]
2/8/2015	13:39:24	A15999	Response		[6] [CHP] has closed their incident [150206BI00071]
2/8/2015	15:22:17	A15900	Response		[7] LINK: [150206BI00080] to [150208BI00054] because [150206BI00071] appends to [150208BI00054]

I declare that the document consisting of 3 pages to which this is affixed is a true copy(s) of the original document(s) on file with the Department of California Highway Patrol.
 By RICHARD A. SCAVCE
 Employee
 Title PSDS I

Address Changes
No Address Changes

Priority Changes
No Priority Changes

Alarm Level Changes
No Alarm Level Changes

Activity Log

Date	Time	Radio	Activity	Location	Log Entry	User
2/6/2015	14:14:34		Incident Priority Change		Incident priority changed from <none> to 4	A15999
2/6/2015	14:20:25		ANI/ALI Statistics		INT Insert:Feb 06 2015 14:13:39 / INT SendNP:Feb 06 2015 14:13:37 / WS RecvNP:Feb 06 2015 14:13:39 / WS Process:Feb 06 2015 14:20:25	A15999
2/6/2015	14:20:41		Cancel Response	0 Rimrock Cir	Cancellation Reason: UX-Cancel, Response Disposition: DUP-Duplicate Call	A15999
2/6/2015	14:20:41		Append Incident		Incident closed, Appended to Inc [150206BI00071]	A15999
2/6/2015	14:20:41		Link Incident		LINK: [150206BI00080] to [150206BI00071] because [150206BI00080] appends to [150206BI00071]	A15999
2/8/2015	15:22:17		Link Incident		LINK: [150206BI00080] to [150208BI00054] because [150206BI00071] appends to [150208BI00054]	A15900

Edit Log

Date	Time	Field	Changed From	Changed To	Reason	Table	Workstation User
2/6/2015	14:13:40	Call_Back_Phone		(760) 567-9688	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:14:15	Response_Area		72-70	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:14:15	Battalion		72-Bishop	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:14:15	Division		.72-Bishop	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:14:15	Jurisdiction		BI	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:14:15	County		Mono	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:14:15	Cross_Street		Unnamed Street/No Cross Street	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:14:15	Street_Id	NULL	76168	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:14:15	Longitude	0	118624478	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:14:15	Latitude	0	37503643	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:14:15	Postal_Code		93514	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:14:15	State		CA	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:14:15	City		Unincorporated	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:14:15	Address		0 Rimrock Cir	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:14:15	Address	(Blank)	0 Rimrock Cir	New Entry	Response_Master_IncidentBI003	A15999
2/6/2015	14:14:15	Address	(Blank)	(Blank)	New Entry	Response_Master_IncidentBI003	A15999
2/6/2015	14:14:33	Incident_Type		1 CHP Unit Incident	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:14:33	Priority_Number	0	4		Response_Master_IncidentBI003	A15999
2/6/2015	14:14:33	Priority_Description		4		Response_Master_IncidentBI003	A15999
2/6/2015	14:14:33	Problem		FIRE-Report of Fire	(Response Viewer)	Response_Master_IncidentBI003	A15999

Custom Time Stamps
No Custom Time Stamps

Custom Data Fields

Description

EMS
FIRE
LAW

Data

MONO1
MONO1
MNOSO

User

A15999
A15999
A15999

Attachments

No Attachment

Incident Detail Report

Data Source: **Data Warehouse**
 Incident Status: **Closed**
 Incident number: **150206BI00081**
 Incident Date: **2/6/2015 14:21:23**
 Last Updated: **2/9/2015 13:02:02**

Incident Information

Incident Type:	1 CHP Unit Incident	Alarm Level:	911 Hang Up
Priority:	5	Problem:	CHP
Determinant:		Agency:	BI
Base Response#:		Jurisdiction:	.72-Bishop
Confirmation#:		Division:	72-Bishop
Taken By:	Douglas V Elliott	Battalion:	72-030
Response Area:	72-30	Response Plan:	
Disposition:	F-File	Command Ch:	
Cancel Reason:	911 Hang up	Primary TAC:	
Incident Status:	Closed	Secondary TAC:	
Certification:		Delay Reason (if any):	
Longitude:	118632009	Latitude:	37544560

Incident Location

Location Name:		County:	Mono
Address:	1.01 Mi S/o L Rock Crk Rd & 1.64mi E/o Ushwy 3	Location Type:	
Apartment:		Cross Street:	No Cross Street/No Cross Street
Building:		Map Reference:	
City, State, Zip:	Unincorporated CA 93514		

Call Receipt

Caller Name:		Call Back Phone:	
Method Received:		Caller Location:	1.01 MI S/O L ROCK CRK RD & 1.64MI E/O USHWY 3
Caller Type:			

Time Stamps

Description	Date	Time	User	Elapsed Times Description	Time
Phone Pickup	2/6/2015	14:21:21			
1st Key Stroke	2/6/2015	14:21:22		Received to In Queue	00:00:19
In Waiting Queue	2/6/2015	14:21:42		Call Taking	00:00:21
Call Taking Complete	2/6/2015	14:21:44	Douglas V Elliott	In Queue to 1st Assign	
1st Unit Assigned				Call Received to 1st Assign	
1st Unit Enroute				Assigned to 1st Enroute	
1st Unit Arrived				Enroute to 1st Arrived	
Closed	2/6/2015	14:27:07	Douglas V Elliott	Incident Duration	00:05:46

Resources Assigned

No Resources Assigned

Personnel Assigned

No Personnel Assigned

Pre-Scheduled Information

No Pre-Scheduled Information

Transports

No Transports Information

Transport Legs

No Transports Information

Comments

Date	Time	User	Type	Conf.	Comments
2/6/2015	14:21:39	A11053	Response		[1] NR

Address Changes

No Address Changes

Priority Changes

No Priority Changes

Alarm Level Changes

I hereby declare under penalty of perjury that the document consisting of 3 pages to which this is affixed is (are) a true copy(s) of the original document(s) on file with the Department of California Highway Patrol.

By RICHARD A. SEAVER
Employee
Title PSPT

No Alarm Level Changes

Activity Log

Date	Time	Radio	Activity	Location	Log Entry	User
2/6/2015	14:21:35		Incident Priority Change		Incident priority changed from <none> to 5	A11053
2/6/2015	14:21:42		ANI/ALI Statistics		INT Insert:Feb 06 2015 14:21:21 / INT SendNP:Feb 06 2015 14:21:19 / WS RecvNP:Feb 06 2015 14:21:21 / WS Process:Feb 06 2015 14:21:42	A11053
2/6/2015	14:21:44		UserAction		User clicked Exit/Save	A11053
2/6/2015	14:26:55		Read Incident		Incident 090 was Marked as Read.	A11053
2/6/2015	14:26:55		Read Comment		Comment for Incident 090 was Marked as Read.	A11053
2/6/2015	14:27:00		UserAction		User clicked Cancel	A11053
2/6/2015	14:27:07		Cancel Response	1.01 Mi S/o L Rock Crk Rd & 1.64mi E/o Ushwy 3	Cancellation Reason: 911 Hang up, Response Disposition: F-File	A11053

Edit Log

Date	Time	Field	Changed From	Changed To	Reason	Table	Workstation User
2/6/2015	14:21:21	Call_Back_Phone		(208) 720-8679	(Response Viewer)	Response_Master_IncidentBI001	A11053
2/6/2015	14:21:30	Address	(Blank)	1.01 MI S/O L ROCK CRK RD & 1.64MI E/O USHWY 3	New Entry	Response_Master_IncidentBI001	A11053
2/6/2015	14:21:30	Address	(Blank)	(Blank)	New Entry	Response_Master_IncidentBI001	A11053
2/6/2015	14:21:31	Response_Area		72-30	(Response Viewer)	Response_Master_IncidentBI001	A11053
2/6/2015	14:21:31	Battalion		72-Bishop	(Response Viewer)	Response_Master_IncidentBI001	A11053
2/6/2015	14:21:31	Division		.72-Bishop	(Response Viewer)	Response_Master_IncidentBI001	A11053
2/6/2015	14:21:31	Jurisdiction		BI	(Response Viewer)	Response_Master_IncidentBI001	A11053
2/6/2015	14:21:31	County		Mono	(Response Viewer)	Response_Master_IncidentBI001	A11053
2/6/2015	14:21:31	Cross_Street		No Cross Street/No Cross Street	(Response Viewer)	Response_Master_IncidentBI001	A11053
2/6/2015	14:21:31	Street_Id	NULL	75452	(Response Viewer)	Response_Master_IncidentBI001	A11053
2/6/2015	14:21:31	Longitude	0	118632009	(Response Viewer)	Response_Master_IncidentBI001	A11053
2/6/2015	14:21:31	Latitude	0	37544560	(Response Viewer)	Response_Master_IncidentBI001	A11053
2/6/2015	14:21:31	Postal_Code		93514	(Response Viewer)	Response_Master_IncidentBI001	A11053
2/6/2015	14:21:31	State		CA	(Response Viewer)	Response_Master_IncidentBI001	A11053
2/6/2015	14:21:31	City		Unincorporated	(Response Viewer)	Response_Master_IncidentBI001	A11053
2/6/2015	14:21:31	Address		1.01 MI S/O L ROCK CRK RD & 1.64MI E/O USHWY 3	(Response Viewer)	Response_Master_IncidentBI001	A11053
2/6/2015	14:21:35	Incident_Type		1 CHP Unit Incident	(Response Viewer)	Response_Master_IncidentBI001	A11053
2/6/2015	14:21:35	Priority_Number	0	5		Response_Master_IncidentBI001	A11053
2/6/2015	14:21:35	Priority_Description		5		Response_Master_IncidentBI001	A11053
2/6/2015	14:21:35	ResponsePlanType0		1	(Response Viewer)	Response_Master_IncidentBI001	A11053
2/6/2015	14:21:35	DispatchLevel		Default	(Response Viewer)	Response_Master_IncidentBI001	A11053
2/6/2015	14:21:35	Response_Plan		72-030	(Response Viewer)	Response_Master_IncidentBI001	A11053
2/6/2015	14:21:35	Problem		911 Hang Up	(Response Viewer)	Response_Master_IncidentBI001	A11053
2/6/2015	14:26:55	Read Comment	False	True	(Response Viewer)	Response_Master_IncidentBI001	A11053
2/6/2015	14:26:55	Read Call	False	True	(Response Viewer)	Response_Master_IncidentBI001	A11053

Viewer)

Custom Time Stamps
No Custom Time Stamps

Custom Data Fields
Description
EMS
FIRE
LAW

Data	User
MONO1	A11053
MONO1	A11053
MNOSO	A11053

Attachments
No Attachment

Incident Detail Report

Data Source: **Data Warehouse**
 Incident Status: **Closed**
 Incident number: **150206BI00082**
 Incident Date: **2/6/2015 14:12:28**
 Last Updated: **2/9/2015 13:02:42**

Incident Information

Incident Type:	1 CHP Unit Incident	Alarm Level:	911 Hang Up
Priority:	5	Problem:	CHP
Determinant:		Agency:	BI
Base Response#:		Jurisdiction:	.72-Bishop
Confirmation#:		Division:	72-Bishop
Taken By:	Nissa Wollum	Battalion:	72-030
Response Area:	72-30	Response Plan:	
Disposition:	F-File	Command Ch:	
Cancel Reason:	SD-Service Desk	Primary TAC:	
Incident Status:	Closed	Secondary TAC:	
Certification:		Delay Reason (if any):	
Longitude:	118632009	Latitude:	37544560

Incident Location

Location Name:	County:
Address:	Mono
1.01 Mi S/o L Rock Crk Rd & 1.64mi E/o Ushwy 3	Location Type:
Apartment:	
Building:	Cross Street:
City, State, Zip:	No Cross Street/No Cross Street
Unincorporated CA 93514	Map Reference:

Call Receipt

Caller Name:	Call Back Phone:
Method Received:	[REDACTED]
Caller Type:	Caller Location:
	1.01 MI S/O L ROCK CRK RD & 1.64MI E/O USHWY 3

Time Stamps

Description	Date	Time	User	Elapsed Times Description	Time
Phone Pickup	2/6/2015	14:12:26			
1st Key Stroke	2/6/2015	14:12:26		Received to In Queue	00:11:04
In Waiting Queue	2/6/2015	14:23:32		Call Taking	00:11:04
Call Taking Complete	2/6/2015	14:23:32	Nissa Wollum	In Queue to 1st Assign	
1st Unit Assigned				Call Received to 1st Assign	
1st Unit Enroute				Assigned to 1st Enroute	
1st Unit Arrived				Enroute to 1st Arrived	
Closed	2/6/2015	14:23:32	Nissa Wollum	Incident Duration	00:11:06

Resources Assigned
 No Resources Assigned

Personnel Assigned
 No Personnel Assigned

Pre-Scheduled Information
 No Pre-Scheduled Information

Transports
 No Transports Information

Transport Legs
 No Transports Information

Comments

Date	Time	User	Type	Conf.	Comments
2/6/2015	14:23:26	A15999	Response		[1] BLU ABAN

Address Changes
 No Address Changes

Priority Changes
 No Priority Changes

Alarm Level Changes

I declare under penalty of perjury that the foregoing is a true and correct copy of the original document(s) on file with the Department of California Highway Patrol.
 By Richard A. Seaver
 Employee
 Title PSDS E

No Alarm Level Changes

Activity Log

Date	Time	Radio	Activity	Location	Log Entry	User
2/6/2015	14:12:36		Incident Priority Change		Incident priority changed from <none> to 5	A15999
2/6/2015	14:23:32		ANI/ALI Statistics		INT Insert:Feb 06 2015 14:12:23 / INT SendNP:Feb 06 2015 14:12:22 / WS RecvNP:Feb 06 2015 14:12:25 / WS Process:	A15999
2/6/2015	14:23:32		Cancel Response	1.01 Mi S/o L Rock Crk Rd & 1.64mi E/o Ushwy 3	Cancellation Reason: SD-Service Desk, A15999 Response Disposition: F-File	A15999

Edit Log

Date	Time	Field	Changed From	Changed To	Reason	Table	Workstation User
2/6/2015	14:12:26	Call_Back_Phone		(661) 733-2864	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:12:29	Address	(Blank)	1.01 MI S/O L ROCK CRK RD & 1.64MI E/O USHWY 3	New Entry	Response_Master_IncidentBI003	A15999
2/6/2015	14:12:34	Response_Area		72-30	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:12:34	Battalion		72-Bishop	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:12:34	Division		.72-Bishop	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:12:34	Jurisdiction		BI	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:12:34	County		Mono	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:12:34	Cross_Street		No Cross Street/No Cross Street	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:12:34	Street_Id	NULL	75452	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:12:34	Longitude	0	118632009	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:12:34	Lalitude	0	37544560	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:12:34	Postal_Code		93514	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:12:34	State		CA	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:12:34	City		Unincorporated	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:12:34	Address		1.01 MI S/O L ROCK CRK RD & 1.64MI E/O USHWY 3	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:12:34	Address	(Blank)	1.01 MI S/O L ROCK CRK RD & 1.64MI E/O USHWY 3	New Entry	Response_Master_IncidentBI003	A15999
2/6/2015	14:12:36	Incident_Type		1 CHP Unit Incident	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:12:36	Priority_Number	0	5		Response_Master_IncidentBI003	A15999
2/6/2015	14:12:36	Priority_Description		5		Response_Master_IncidentBI003	A15999
2/6/2015	14:12:36	ResponsePlanType0		1	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:12:36	DispatchLevel		Default	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:12:36	Response_Plan		72-030	(Response Viewer)	Response_Master_IncidentBI003	A15999
2/6/2015	14:12:36	Problem		911 Hang Up	(Response Viewer)	Response_Master_IncidentBI003	A15999

Custom Time Stamps

No Custom Time Stamps

Custom Data Fields

Description	Data	User
-------------	------	------

EMS
FIRE
LAW

MONO1
MONO1
MNOSO

A15999
A15999
A15999

Attachments
No Attachment

10.18 - CHP 911 System Audio

ATTACHMENT 18

CD-R 52x
CD-R 52x
CHP 911 AUDIO

10.19 - Inyo Sheriff Fax HOLLOWELL

Sheriff's Department
County of Inyo
550 South Clay Street
P.O. Box "S"
Independence, California 93526

WILLIAM R. LUTZE
SHERIFF

TELEPHONE (760) 878-0383

ADMINISTRATIVE FAX (760) 878-0389

DATE: 2/18/15
TO: BRIAN TOMINALIA
DEPARTMENT: CAL FIRE ARSON INVESTIGATIONS
PHONE #: _____
FROM: JEFF HOLLOWELL UNDERSHERIFF
DEPARTMENT: ICSO
PHONE: _____
NUMBER OF PAGES SENT (INCLUDING COVER PAGE): 2
COMMENTS: SURPRISE - HE NAMED THE RANCH MURDER FOREMAN FROM THE RANCH HE LOST IN THE CRIMINAL CONVICTION.

PLEASE ACKNOWLEDGE: YES: _____ NO: _____

WHEN ACKNOWLEDGEMENT IS REQUESTED, PLEASE FILL OUT THE PORTION BELOW AND SEND BACK THROUGH FAX. THANK YOU.

RECEIVED BY: _____

DATE: _____

NUMBER OF PAGES RECEIVED (INCLUDING COVER PAGE): _____

LT PAUL BALDWIN WILL ASSIGN AN INVESTIGATOR TO LOOK THEM INTO A STORY

INYO COUNTY SHERIFF'S DEPARTMENT
VICTIM/WITNESS STATEMENT FORM

CI# _____ DATE 2/18/15 ^{11:50 am} TYPE OF INCIDENT _____
NAME Joe Mendiburn ADDRESS [REDACTED] PHONE [REDACTED]
DOB [REDACTED] AGE [REDACTED] BUSINESS ADDRESS 3

DETAILS: (List all witnesses, times, dates, places, etc.)

To my knowledge the Round fire started at Tom Talbot's ranch by George "Mickey" Jarvis and Nick Brown. They were at the ranch cutting scrap metal using blow torches and angle grinders and the sparkes got away from them. I heard from Cher: Heorstin which is a cousin to Nick Brown. Mickey Jarvis told the news it was from an arc from the power lines and not from him.

SIGNATURE: JH

DATE: 2/18/15

TIME: 11:57 am

10.20 - LE-71 Supplemental Report RICCI



SUPPLEMENTARY INVESTIGATION REPORT

STATE OF CALIFORNIA
DEPARTMENT OF FORESTRY AND FIRE PROTECTION
LE 71 (REV. 7/2011)

INCIDENT NUMBER
15CABDU001662
CASE NAME
ROUND
DAY
MONTH
DATE
YEAR
COUNTY
REGION
UNIT
CASE NUMBER

DAY	MONTH	DATE	YEAR	COUNTY	REGION	UNIT	CASE NUMBER
Wed	Feb	11	2015	Inyo	CSR	BDU	n/a

1 On Wednesday February 11, 2015 at approximately 8:30 AM I, California Department of Forestry
 2 and Fire Protection (CAL FIRE) Battalion Chief Jennifer RICCI, arrived at the base camp for the
 3 ROUND Fire in the Owens Valley, CA. The ROUND Fire began on February 5, 2015 and was
 4 located in the San Bernardino Unit (BDU) of CAL FIRE. After checking in I proceeded to the general
 5 origin area and met up with Fire Captain Specialist Brian TOMINAGA who was managing the cause
 6 and origin investigation. Also present and assisting with the investigation was Fire Captain
 7 Specialist Kelly GALLAHER, Fire Captain Specialist Branden SMITH and Fire Captain Specialist
 8 Shannon HARRIS.

9
 10 TOMINAGA assigned me to assist with evidence collection. As evidence was collected I maintained
 11 the Evidence Log by noting and writing down the item number, date and time collected, person who
 12 collected the item and the description of each item. Once all the evidence had been photographed,
 13 packaged, marked and collected it was loaded onto a CAL FIRE stake-side pick-up truck driven by
 14 CAL FIRE Firefighter Josh WILLIAMS. Driving my Department-owned sedan I followed the pick-up
 15 truck to the BDU Evidence Storage room located on the BDU Headquarters property at 3800 North
 16 Sierra Way, San Bernardino CA 92405. The Evidence room is on the north end of the BDU
 17 Headquarters compound behind a self-closing gate. It consists of a "Tuff Shed" which has two
 18 locked doors and a monitored alarm system. The keys to the doors are secured in a locked box in a
 19 locked closet in the BDU Fire Prevention Bureau office.

20
 21 At approximately 9:40 PM we arrived at the BDU Evidence Storage room. WILLIAMS assisted me
 22 with unloading the evidence and placing into the evidence room. At approximately 10:00 PM all
 23 evidence had been moved. I then updated the evidence room entry log, locked both doors and set
 24 the alarm on the buildings and departed.

25
 26 On Thursday February 12, 2015 I entered the information regarding the evidence from the ROUND
 27 Fire into our Evidence Tracker Program.

28

1 On May 2, 2015 TOMINAGA, Rusty MCCULLEY, Jack MARKLE, Joe PIDGEON and I re-organized
2 the BDU Evidence Storage room. During this re-organization the evidence from the ROUND fire
3 was moved to new racks and shelves in the BDU Evidence Storage room. The new locations were
4 updated in the Evidence Tracker Program.

5
6
7 INVESTIGATING OFFICER:

8 
9 _____ 6/11/15
10 Signature Date

11
12 Jennifer Ricci, ID #3588
13 Battalion Chief
14 CAL FIRE/San Bernardino Unit
15 3800 N. Sierra Way
16 San Bernardino, CA 92402
17 (909) 881-6920

18
19

PRINTED NAME	SIGNATURE	BADGE NUMBER	DATE
Jennifer Ricci		3588	04/28/2015

10.21 - LE-92 Property Report



PROPERTY REPORT

STATE OF CALIFORNIA
DEPARTMENT OF FORESTRY AND FIRE PROTECTION
LE-92 (REV. 1/2012)

INCIDENT NUMBER

CA-BDU-001662

CASE NAME

ROUND

DAY	MONTH	DATE	YEAR	COUNTY	REGION	UNIT	CASE NUMBER
WED	FEB	11	2015	INYO	CSR	BDU	

Receipt Release Evidence Found Property Safe Keeping 12028.5 PC (See Below)

1. Name: Southern California Edison (Scott Hamashi)

2. Residence Address: _____ Phone: _____

3. Business Address: PO Box 900 Rosemead, CA 91770 Phone: 626)302-6032

4. Item No.	5. Quantity	6. Description
8A	1	12 KV DEADEND INSULATOR (POLY) AND WIRE SHOE AND JUMPER WIRE (PLW)
8b	1	POWERLINE SECTION, END 2+3
8c	1	POWERLINE SECTION, END 4+5 AND SMALL PIECES
8d	1	POWERLINE SECTION, END 6+7
8e	1	POWERLINE SECTION, END 8+9
9A	1	12 KV DEADEND INSULATOR (POLY) AND WIRE SHOE AND JUMPER WIRE (SOUTH WIRE)
9b	1	POWERLINE SECTION, END 3+4
9c	1	POWERLINE SECTION, END 5+6
9d	1	POWERLINE SECTION, END 7+8
9e	1	POWERLINE SECTION, END 9+10
9f	1	POWERLINE SECTION, END 11+12, LAST SECTION OF SPAN 1
9g	1	POWERLINE SECTION, END 13+14
1	1	SINGLE BOLT CONNECTOR
6+7	1	BRANCH WITH TWO BURN MARKS
10A,B,C	3	TREE SECTIONS WITH POWERLINE CONTACT POINTS
11	1	TREE SECTION WITH PHONE LINE CONTACT POINTS
12A	1	PHONE LINE FROM HOME POLE # 1854107E
12B	1	PHONE LINE FROM DOWNED TREE TO THE WEST

7. Signature of Owner:

BRANDON SMITH
FES #3574

8. Received or Released by: _____

9. AFFIDAVIT OF FINDER OF PROPERTY

I declare that on: DATE: _____ TIME: _____ I found or saved the above-described property and that the owner is not known to me. I have not secreted, withheld, or disposed of any part of said property; and I have saved the property from _____ in the following manner _____

I declare under PENALTY OF PERJURY that the foregoing is true.
Signed: _____ Date: _____
Witness: _____ Date: _____

10. 12028.5 PC WEAPON/FIREARMS SEIZURE

Weapon and/or firearms seized and taken into temporary custody pursuant to 12028.5 PC shall be held by the agency for no less than 48 hours but no later than 72 hours, unless in accordance with 12028.5(e) PC, forfeiture proceedings are initiated by the seizing agency. To inquire about the return of your weapon(s) and/or firearm(s), contact the property Room Clerk of the _____ Station at phone number (____) _____ during normal business hours. You will be notified within ten (10) business days if forfeiture proceedings are initiated. Weapons and/or firearms not claimed within twelve (12) months of the date of seizure shall be deemed a nuisance and disposed of in accordance with 12028.5(e) PC.

10.22 - LE-75e Evidence Log



EVIDENCE LOG

STATE OF CALIFORNIA
DEPARTMENT OF FORESTRY AND FIRE PROTECTION
LE 75e (REV. 7/2011)

INCIDENT NUMBER							
15CABDU001662							
CASE NAME							
ROUND							
DAY	MONTH	DATE	YEAR	COUNTY	REGION	UNIT	CASE NUMBER
Friday	Feb	6	2015	Inyo	CSR	BDU	

ITEM NO	DATE COLLECTED	TIME COLLECTED	COLLECTED BY	ITEM DESCRIPTION	LOCATION RECOVERED
1	02/11/2015	10:34 AM	Smith, Branden	12 KV dead-end poly insulator with wire shoe and jumper wire; North wire.	general origin area
2	02/11/2015	11:10 AM	Smith, Branden	Powerline section from north wire, ends 2 & 3	general origin area
3	02/11/2015	11:38 AM	Smith, Branden	Powerline section from north wire, ends 4 & 5 and small pieces	general origin area
4	02/11/2015	02:11 PM	Smith, Branden	Powerline section from north wire, ends 6 & 7	west of general origin area
5	02/11/2015	12:05 PM	Smith, Branden	12 KV dead-end poly insulator with wire shoe and jumper wire; South wire.	general origin area
6	02/11/2015	12:26 PM	Smith, Branden	powerline section, south wire.	general origin area
7	02/11/2015	12:46 PM	Smith, Branden	powerline section, south wire.	general origin area
8	02/11/2015	01:00 PM	Smith, Branden	powerline section, south wire.	general origin area
9	02/11/2015	01:09 PM	Smith, Branden	powerline section, south wire.	west of general origin area
10	02/11/2015	02:12 PM	Smith, Branden	powerline section, south wire.	west of general origin area
11	02/11/2015	02:17 PM	Smith, Branden	powerline section, south wire.	west of general origin area
12	02/11/2015	02:15 PM	Smith, Branden	powerline section, north wire.	west of general origin area
13	02/11/2015	02:20 PM	Smith, Branden	single bolt connector	general origin area
14	02/11/2015	02:40 PM	Smith, Branden	tree branch with two burn marks	general origin area
15	02/11/2015	02:58 PM	Smith, Branden	tree section with powerline contact points.	general origin area

PRINTED NAME	SIGNATURE	BADGE NUMBER	DATE
Jennifer RICCI		3588	6/11/15

10.23 - LE-76 Custody Report

Chain of Custody Report (LE-76)

BDU - San Bernardino Unit
3800 N. Sierra Way
San Bernardino, CA 92404

6/11/2015 2:32:09 PM

Incident #: 15CABDU001662 Incident Name: ROUND

Incident Date: 02/06/2015
Case Officer: Jennifer Ricci

Item ID: 1

Category: Power Distribution
Power Dist. Type: Conductor
Description: 12 KV dead-end poly insulator with wire shoe and jumper wire; North wire; From pole#1854107E east of origin area

Time & Date Collected: 02/11/2015 10:34 AM
Reason Taken: Evidence
Location Recovered: general origin area
Reference Number: 8a
Current Status: IN
Evidence Room Loc: BDU - San Bernardino Unit => Rack 2 => Shelf C

Item Submitted By: Jennifer Ricci

	Date	Issued From	Issued To	Room Loc/Reason out
Move	5/2/2015 10:01:01 AM	Jennifer Ricci		New Location: BDU - San Bernardino Unit => Rack 2 => Shelf C
In	02/12/2015 01:29 PM	Jennifer Ricci	[TO SYSTEM]	Location: BDU - San Bernardino Unit => Rack 3 => Shelf A

Item ID: 2

Category: Power Distribution
Power Dist. Type: Conductor
Description: Powerline section from north wire, ends 2 & 3

Time & Date Collected: 02/11/2015 11:10 AM
Reason Taken: Evidence
Location Recovered: general origin area
Reference Number: 8b
Current Status: IN
Evidence Room Loc: BDU - San Bernardino Unit => Rack 2 => Shelf C

Item Submitted By: Jennifer Ricci

	Date	Issued From	Issued To	Room Loc/Reason out
Move	5/2/2015 10:01:01 AM	Jennifer Ricci		New Location: BDU - San Bernardino Unit => Rack 2 => Shelf C
In	02/12/2015 01:30 PM	Jennifer Ricci	[TO SYSTEM]	Location: BDU - San Bernardino Unit => Rack 3 => Shelf A

Item ID: 3

Category: Power Distribution
Power Dist. Type: Conductor
Description: Powerline section from north wire, ends 4 & 5 and small pieces

Time & Date Collected: 02/11/2015 11:38 AM
Reason Taken: Evidence
Location Recovered: general origin area
Reference Number: 8c
Current Status: IN
Evidence Room Loc: BDU - San Bernardino Unit => Rack 2 => Shelf A

Item Submitted By: Jennifer Ricci

	Date	Issued From	Issued To	Room Loc/Reason out
Move	5/2/2015 10:02:26 AM	Jennifer Ricci		New Location: BDU - San Bernardino Unit => Rack 2 => Shelf A
In	02/12/2015 01:32 PM	Jennifer Ricci	[TO SYSTEM]	Location: BDU - San Bernardino Unit => Rack 3 => Shelf A

Item ID: 4

Category: Power Distribution
Power Dist. Type: Conductor
Description: Powerline section from north wire, ends 6 & 7

Time & Date Collected: 02/11/2015 02:11 PM
Reason Taken: Evidence
Location Recovered: west of general origin area
Reference Number: 8d
Current Status: IN
Evidence Room Loc: BDU - San Bernardino Unit => Rack 2 => Shelf C

Item Submitted By: Jennifer Ricci

	Date	Issued From	Issued To	Room Loc/Reason out